

**Addendum #1, March 30, 2023**

**Tennis Center Patio Project**

**All addenda to bidders shall be incorporated into the bid documents. Each bidder submitting a bid must acknowledge receipt of any and every addendum received.**

**All bidders shall include a printed and signed copy of this addendum with their bid submittal.**

**All bidders must complete and submit with their bid the Contractor's Certifications, Bid Form, and the bid bond as specified in the bid packet along with this signed addendum to have their bid considered by the District.**

1. Regarding the contraction joints in the concrete, the Park District is requiring these joints to be tooled. Saw cutting the concrete after installation will not be accepted as an alternative to tooled joints.
2. Regarding the concrete footings for the by-owner shade structures, the Park District has not yet purchased the 12'x12' shade structures. The footing detail shown in the plans represents the **maximum size** footing that will be required for the shade structures purchased. Final footing dimension and anchor bolt patten will be provided to the contractor prior to project commencement. Bids should be based on the maximum footing size depicted in the detail on page 50 of the bid packet.

**The Bidder's signature below acknowledges the receipt of Addendum #1, issued March 30, 2023 for the Tennis Center Patio Project.**

**Bidder's Signature:** \_\_\_\_\_

**Bidder's Name:** \_\_\_\_\_

**Company Name:** \_\_\_\_\_

**Date:** \_\_\_\_\_