

Addendum #2, April 4, 2023

Tennis Center Patio Project

All addenda to bidders shall be incorporated into the bid documents. Each bidder submitting a bid must acknowledge receipt of any and every addendum received.

All bidders shall include a printed and signed copy of this addendum with their bid submittal.

All bidders must complete and submit with their bid the Contractor's Certifications, Bid Form, and the bid bond as specified in the bid packet along with this signed addendum to have their bid considered by the District.

1. Regarding the underdrainage alternate, the plans call for 6-inch drain pipe with a 4-inch miter drain. The miter drain should be a 6-inch size instead of 4 inch.

The Bidder's signature below acknowledges the receipt of Addendum #1, issued April 4, 2023 for the Tennis Center Patio Project.

Bidder's Signature: _____

Bidder's Name: _____

Company Name: _____

Date: _____