

**ADDENDUM #2 June 26th, 2026**

**Family Recreation Center Exterior Maintenance Project**

**All addenda to bidders shall be incorporated into the bid documents. Each bidder submitting a bid must acknowledge receipt of any and every addendum received.**

**All bidders shall include a printed and signed copy of this addendum with their bid submittal.**

**All bidders must complete and submit with their bid the Contractor's Certifications, Bid Form, and the bid bond as specified in the bid packet along with this signed addendum to have their bid considered by the District.**

1. Contractor is requesting approval to use Sherwin-Williams products as an approved equal to the Benjamin Moore products specified in the bid.

**Answer: SuperPaint Exterior Acrylic Low Sheen is an approved equivalent replacement for Benjamin Moore Ultra Spec Exterior Paint – Low Lustre and Pro Industrial DTM Acrylic is an approved equivalent replacement for Benjamin Moore High Performance Command (Direct-to-Metal).**

**The Bidder's signature below acknowledges the receipt of Addendum #2, issued June 26th, 2026 for the Family Recreation Center Exterior Maintenance Project.**

**Bidder's Signature: \_\_\_\_\_**

**Bidder's Name: \_\_\_\_\_**

**Company Name: \_\_\_\_\_**

**Date: \_\_\_\_\_**