

Gabion Weir Bid Addendum 1

All addenda to bidders shall be incorporated into the bid documents. Each bidder submitting a bid must acknowledge receipt of any and every addendum received. All bidders shall include a printed and signed copy of this addendum with their bid submittal.

See below for a list of questions that have been posed regarding the gabion weir project.

Question 1. *Can you provide a view or cross-section of the final grade/depth of the creek? Refer to page 4 of the plan set for final installation elevations of stone. No cross section is available of the creek final depth and grade.*

Question 2. *Will we be able to use the rock from the existing gabion as a base for the cross vanes to be installed? Yes*

Question 3. *Do you have a GIS Shapefile of the project area that we can use for mapping and pricing purposes? No*

Question 4. *I see that Cardno is specified in this project to provide pre-vegetated Root Carpets. Is there a plant list for what goes into the carpets? The Cardno RootCarpet Mat is manufactured with native wetland plants embedded into the matting. The project does not specify a particular mixture of native wetland plants, only that the matting be pre-vegetated with native wetland plants. The contractor may propose an approved equivalent mat pre-vegetated with native wetland plants other than the Cardno brand. The contractor is responsible for providing and installing the mats.*

The Bidder's signature below acknowledges the receipt of Addendum #1, issued May 4, 2018 for the Gabion Weir Project.

Bidder's Signature: _____

Bidder's Name: _____

Company Name: _____

Date: _____