

Oak Brook Park District
Central Park West
Door and Window Replacement Project
Bid Packet



Dave Thommes, Director of Recreation
630-645-9534
dthommes@obparks.org

Laure Kosey, Executive Director
630-645-9535
lkosey@obparks.org

Ted Haug
Legat Architects
THaug@legat.com

INDEX
CENTRAL PARK WEST DOOR AND WINDOW REPLACEMENT PROJECT

INVITATION TO BID	3
INSTRUCTIONS TO BIDDERS	4
CONDITIONS OF THE CONTRACT	12
General Conditions	
Supplementary Conditions	
Special Conditions	
BID FORM	19
LIST OF SUBCONTRACTORS	22
BIDDER'S REFERENCE LIST	23
CONTRACTOR'S COMPLIANCE CERTIFICATION ATTACHMENT	24
SUBSTANCE ABUSE PREVENTION PROGRAM CERTIFICATION	27
IMPORTANT NOTICE OF RESPONSIBILITY FOR PERIODIC REVISIONS TO PREVAILING WAGE RATES	28
OWNER/CONTRACTOR AGREEMENT	29
TECHNICAL SPECIFICATIONS	30

INVITATION TO BID
OAK BROOK PARK DISTRICT
Central Park West Door and Window Replacement Project

The Oak Brook Park District (the “District”) is accepting bids for the Central Park West Door and Window Replacement Project.

Specifications and Contract Documents may be obtained beginning February 21, 2020, at the Administrative Office at the District’s Family Recreation Center, 1450 Forest Gate Road, Oak Brook, IL 60523, Monday - Friday, 9:00 a.m. – 5:00 p.m., or in PDF format at the District’s website: <https://www.obparks.org/bids-rfps>.

Each bid must be placed in a sealed opaque envelope with the Bidder’s name, the date and time of the bid deadline and marked “**Sealed Bid**: – Oak Brook Park District Central Park West Door and Window Replacement Project,” and addressed to the Oak Brook Park District, 1450 Forest Gate Road, Oak Brook, IL 60523, **Attention: Executive Director**. Bids will be received until 10:00 a.m. on March 9, 2020, at which time the bid proposals will be publicly opened and read aloud at the District’s Administrative Office, located at the District’s Family Recreation Center, 1450 Forest Gate Road, Oak Brook, IL 60523.

The Oak Brook Park District Board of Park Commissioners reserves the right to waive all technicalities, to accept or reject any or all bids, to accept only portions of a proposal and reject the remainder without disclosure for any reason. Failure to make such a disclosure will not result in accrual of any right, claim or cause of action by any Bidder against the Oak Brook Park District.

Bids shall not include federal excise tax or state sales tax for materials and equipment to be incorporated in, or fully consumed in the performance of, the work. An Exemption Certificate will be furnished by the Oak Brook Park District on request of the Bidder, for use in connection with this project only.

The Work of this Project is subject to the Illinois *Prevailing Wage Act*, 820 ILCS 130/0.01 *et seq.* A prevailing wage determination has been made by the Illinois Department of Labor for public works projects in DuPage County. The Contract entered into for the Work will be drawn in compliance with said law and proposals should be prepared accordingly and provide for payment of all laborers, workmen, and mechanics needed to perform the Work at no less than the prevailing rate of wages (or the prevailing rate for legal holiday and overtime work) for each craft, type of worker, or mechanic.

All bid proposals must be accompanied by a bid bond or bank cashier’s check payable to the Oak Brook Park District for ten percent (10%) of the amount of the bid as provided in the Instructions to Bidders. No proposals or bids will be considered unless accompanied by such bond or check.

The Contractor selected will also be required to comply with all applicable federal, state and local laws, rules, regulations and executive orders including but not limited to those pertaining to equal employment opportunity.

The District encourages women and minority business firms to submit bids and encourages bidders to utilize minority businesses for supplies, equipment and services.

Laure Kosey, Executive Director
Oak Brook Park District

**INSTRUCTIONS TO BIDDERS
OAK BROOK PARK DISTRICT
CENTRAL PARK WEST DOOR AND WINDOW REPLACEMENT PROJECT**

INSTRUCTIONS TO BIDDERS

The Oak Brook Park District and Owner are one and the same. "Architect" or "Engineer" shall mean Legat Architects which shall, through its designated representative, Ted Haug, THaug@legat.com, respond to questions and provide interpretations of the Specifications for this Project.

The words "Contractor" and "Bidder" shall mean the party bidding for or entering the Contract for the performance of the Work covered by the written Specifications and Drawings, and his/her legal representatives or authorized agents.

A. BID DOCUMENTS

1. The Bid Documents may be downloaded in PDF format from the Owner's website: <https://www.obparks.org/bids-rfps>. The Bid Documents are also available in printed format from the Administrative Office at the District's Family Recreation Center, 1450 Forest Gate Road, Oak Brook, IL 60523, Monday - Friday, 9:00 a.m. – 5:00 p.m. Please note the printed Drawings available at the Administration Office will be on 11" x 17" paper.

B. BID FORM

1. Each bid shall be made on the "Bid Form" furnished by the District. The Bid Form shall be executed properly and all writing, including all signatures, shall be with black ink. Failure to use the Bid Form provided could result in rejection of the bid.
2. All applicable blank spaces on the "Bid Form" shall be fully completed, including the List of Subcontractors and the Bidder's Reference List, and all amounts shall be in words as well as in figures where applicable.
3. The bid shall bear the legal name of the business organization. The signatures shall be in longhand and executed by a duly authorized official of the Bidder's organization and the name of the official and title shall be typed below the signature.
4. Erasures, interlineations, corrections, or other changes on the "Bid Form" shall be explained or noted over the signature of the Bidder. No bid submitted with deviations or reservations from the full contract called for will be considered.
5. Bidders' prices are to include the delivery of all materials; including plant, equipment, supplies, tools, scaffolding, transportation, insurances, bonds, warranties, and all other items and facilities, and the performance of all labor and services, necessary for the proper completion of the Work except as may be otherwise expressly provided in the Contract Documents. Bids shall not include federal excise tax or state sales tax for materials to be incorporated in, or totally consumed in the prosecution of, the Work.

An exemption certificate will be furnished by the Park District upon request of the Bidder.

6. Bidder must acknowledge all Addenda received in the spaces provided on the Contractor Bid Form. By submitting a bid, Bidder indicates that all considerations issued by Addendum are incorporated in the bid.
7. Attached to the Bid Form will be the Contractor's Compliance and Certification Attachment/ Substance Abuse Prevention Program Certification regarding the Bidder's compliance with applicable laws. **Failure of a Bidder to complete/submit a required certification shall be the basis for immediate rejection of that Bidder's bid.** The certification of the successful Bidder shall become a part of the Contract with the Park District.
8. The bids shall be sealed in an opaque envelope, marked with the name of the Bidder, the date and time of the bid, and addressed as follows:

Sealed Bid: Central Park West Door and Window Replacement Project
Oak Brook Park District
1450 Forest Gate Road
Oak Brook, IL 60523

9. Bid documents shall be delivered or mailed in time for delivery to the foregoing address no later than March 9, 2020 at 10:00 a.m. Oral bids or oral modifications to bids will not be considered. It is the sole responsibility of the Bidder to see that his bid is received in proper time. **No faxed or e-mail bid or modification of a bid will be considered.** The Park District is not responsible for the premature opening of bids not marked as required. Any bid opened prematurely due to the failure of the Bidder to mark the envelope in accordance with these Bid Documents will be considered non-responsive.
10. No bid can be withdrawn prior to the opening of the bids unless a written request for any such withdrawal, showing good cause for said withdrawal, is first delivered to the District at the foregoing address prior to commencement of the opening of bids. No Bidder may withdraw a bid after opening of the bids.
11. Bids will be publicly opened on the due date.

C. REQUIREMENTS OF BIDDERS

Bidders must be able to demonstrate that they: a) have experience in performing and have successfully performed and are still actively engaged in performing work similar in kind and scope to the Work of the Project; and b) are able to show that they have adequate laborers and materials to successfully complete the Work as indicated in the Bid Documents and within the time required by the Bid Documents. The Contractor shall not have been debarred or determined ineligible for public contracts by any governmental agency.

The following information must be attached to the bid proposal. Failure to do so may result in disqualification of the Bidder.

1. On a separate sheet, list all construction projects your organization has in progress, giving the name of the project, project description, project address, owner and telephone number, architect and telephone number, contract amount, percent complete, and scheduled completion date.

2. On the Bidder's Reference List form provided herein, list at least three (3) construction projects your organization has completed in the past five (5) years, which are comparable in scope, giving the name of the project, project description, project address, owner and telephone number.

3. On the List of Subcontractors form provided herein, provide a list of anticipated subcontractors, if any, including their firm names, addresses and telephone numbers. All subcontractors to be used shall be approved by the Owner. If the Contractor subcontracts any part of the Work for this project, the Contractor shall not under any circumstances be relieved of his liabilities and obligations; any subcontractor for this project will be recognized only in the capacity of an employee of the Contractor.

4. On a separate sheet, list all administrative proceedings and litigation filed by or against Bidder in the past five (5) years, including the name and case number, name/jurisdiction of the court or administrative agency, and a summary of each claim/case, including current status and if no longer pending, the disposition. The foregoing includes but is not limited to information regarding any proceedings and actions taken by any governmental agency to debar or disqualify the Bidder from bidding on public contracts, including the name of the agency initiating the proceeding/action, the nature of the proceeding/action, the claimed basis for the proceeding/action and the current status or disposition of the proceeding/action.

Other required submittals include: Bid Form; Contractor's Compliance and Certification Attachment/ Substance Abuse Prevention Program Certification. **Failure of a Bidder to complete/submit these documents shall be the basis for immediate rejection of that Bidder's bid.**

The Park District reserves the right to require of any Bidder such information to verify the Bidder's qualifications and financial status and to withhold formal signing of the contract until such information is received.

D. MODIFICATION OF BIDS

Any Bidder may modify his bid by written notice (signed by the Bidder) at any time prior to the scheduled closing time for receipt of bids, provided that such written notice is received by the District prior to the closing time. Modifications of bid submittals sent by facsimile will not be permitted.

E. EXAMINATION OF CONTRACT DOCUMENTS AND SITE

Each Bidder shall visit the site(s) of the proposed Work and fully acquaint himself with conditions, as they exist, and shall undertake such additional inquiry and investigation as he shall deem necessary so that he may fully understand the requirements, facilities, possible difficulties and restrictions attending the execution of the Work under the Contract. Bidder shall thoroughly examine and be familiar with all of the Bid Documents including, but not limited to, the Drawings and the written Specifications. Any conflicts or discrepancies found between or among Bid Documents including, but not limited to, the Drawings and written Specifications and the site conditions, or any errors, omissions or ambiguities in the Drawings or written Specifications shall be immediately reported to the Architect and written clarification requested prior to submission of a bid.

The failure or omission of any Bidder to obtain, receive or examine any form, instrument, or information or to visit the Project site(s), and become knowledgeable with respect to conditions there existing, or to seek needed clarification shall in no way relieve any Bidder from any obligations with respect to his bid. By submitting a bid, the Bidder agrees, represents and warrants that he has undertaken such investigation as he deemed necessary, has examined the site(s) and the Bid Documents, has obtained all needed clarifications and where the Bid Documents indicate in any part of the Work, that a given result be produced, that the Bid Documents are adequate and the required result can be produced as indicated in the Specifications and Drawing(s). Once the award has been made, failure to have undertaken and completed the foregoing tasks shall not be cause to alter the original Contract or to request additional compensation.

F. ACCEPTANCE OR REJECTION OF BIDS

The Park District may accept the bid of, and award the contract for the Work to, the lowest responsive and responsible Bidder as determined by and in the sole discretion of the Park District.

The Owner reserves the right to (1) reject all bids; (2) reject only certain bids which are non-conforming or non-responsive to the bid requirements; (3) accept only a portion, part or specific items of Work of all and reject others, as the Owner shall in its sole discretion determine to be in its best interest; and/or (4) award the Contract to the responsible Bidder submitting the lowest bid responsive to the bidding requirements. No bid will be accepted from or Contract awarded to any person, firm or corporation that is in arrears or is in default to the Park District upon any debt or contract, or that is a defaulter, as surety or otherwise, upon any obligation to said Park District or that has failed to perform faithfully any previous contract with the Park District.

In the event of a rejection of a portion, part, or certain items of Work of all bids, the bid of each Bidder shall automatically be deemed reduced by the amount of such rejected part or item at the unit price or other cost designated therefore by that Bidder on its submitted Contractor Bid Form. The successful Bidder so selected may not refuse to enter into a Contract with the Owner on the basis that the Owner awarded a Contract for less than all

portions or items of the Work specified in the Bid Documents. The Oak Brook Park District Board of Park Commissioners reserves the right to waive any technicalities or irregularities, and to disregard any informality on the bids and bidding, when in its opinion the best interest of the Park District will be served by such actions and in accordance with applicable law.

G. SURETY

All bids must be accompanied by a bid bond or bank cashier's check payable to the Oak Brook Park District for ten percent (10%) of the amount of the bid and drawn on a responsive and responsible bank doing business in the United States. All bids not accompanied by a bid security, when required, will be rejected.

The bid security of all except the three (3) lowest responsible Bidders will be returned after the decision to accept or reject bids by the Oak Brook Park District Board of Park Commissioners. The bid security of the three (3) lowest responsible Bidders will be returned after acceptance by the Park District from the successful Bidder, an acceptable Performance Bond, Labor and Materials/Payment Bond and a certificate of insurance naming the Oak Brook Park District as the certificate holder and as additional insured, and the successful Bidder has executed and returned to the Park District the Contract for the Work presented by the Park District.

Prior to beginning Work, the successful Bidder shall furnish a Performance Bond, and Labor and Materials/Payment Bond in the amount of 110% of the Contract Sum, using a form similar to the AIA-A312-2010 form, or its current equivalent, or one acceptable to Owner, cosigned by a surety company licensed to conduct business in the State of Illinois and with at least an "A" rating and a financial rating of at least "X" in the latest edition of the Best Insurance Guide. Said bond shall guarantee the faithful performance of the Work in accordance with the Contract, the payment of all indebtedness incurred for labor and materials, and guarantee correction of Work. The cost of each bond shall be included in the Contract Sum. The Bidder and all Subcontractors shall name the Park District as an obligee on all bonds. Said bonds shall meet the requirements of the Illinois Public Construction Bond Act, 30 ILCS 550/0.01 *et seq.* and any further amendments thereto. Bidder shall include in its Performance Bond and Labor and Material Payment Bond such language as shall guarantee the faithful performance of the Prevailing Wage Act as required in these Bid Documents.

The Performance Bond and Labor and Material Payment Bond will become a part of the Contract. The failure of the successful Bidder to enter into the Contract and supply the required bonds and evidence of insurance within ten (10) days after the Contract is presented for signature, or within such extended period as the Park District may grant, shall constitute a default, and the Park District may either award the Contract to the next responsible Bidder, or re-advertise for bids. In the event of a default, the Owner need not return the defaulting Bidder's bid surety and may charge against the defaulting Bidder for the full difference between the amount for the bid and the amount for which a Contract for the Work is subsequently executed, irrespective of whether the amount thus due exceeds the amount of

the defaulting Bidder's bid surety, provided that the District's retention of the bid guarantee shall not preclude the District from holding the Bidder fully liable for any and all damages which are in excess of said partial liquidated damages, and which shall otherwise be incurred by the District, including reasonable attorneys' fees, arising from the Bidder's failure to enter into said Contract and to deliver the same back to the District within said ten (10) day period.

H. WITHDRAWAL OF BID

Bidders may withdraw or cancel their bids at any time prior to the advertised bid opening time by signing and submitting a request for said withdrawal. After the bid opening time, no bid shall be withdrawn or canceled for a period of sixty (60) calendar days.

I. ACCEPTANCE AND CONTRACT

Owner will award the Contract to the lowest most responsible and responsive Bidder, as determined by Owner. In considering the Bidder's responsibility, the Owner may evaluate, among other factors, the ability of the Bidder to provide experienced labor sufficient in numbers to timely and properly complete the services, conformity with the Specifications, serviceability, quality, and the financial capability of the Bidder, and the performance of the Bidder on other projects.

The Owner shall have the right to accept Alternates in any order or combination, and to determine the low Bidder on the basis of the sum of the Base Bid and Alternates accepted.

Bids will be awarded to one Bidder for the entire Project or to any series of Bidders for an appropriate proportion of the Project. If specified in the Bid Form, awards will be based upon the submitted unit prices.

The acceptance of a bid will be by a Notice of Award, signed by a duly authorized representative of the Park District; no other act by the Park District shall constitute the acceptance of a bid. The acceptance of a bid by the Park District shall bind the successful Bidder to execute and perform the Work of the Contract. The successful Bidder to whom the Contract is awarded by the Park District shall sign and deliver to the Park District for execution by the Park District all required copies of the Contract, along with all required insurance and surety documents within ten (10) days after presentation to him of the Contract for signature. In case the Bidder shall fail or neglect to do so, he will be considered as having abandoned the Contract, and as being in default to the Owner. The Owner may thereupon re-advertise or otherwise award said Contract and forfeit the Bid Security.

The Advertisement for Bids, Instructions to Bidders, General Conditions, Supplementary and/or Special Conditions, if any, Drawings, Specifications, Contractor Bid Form, Addenda, if any, Contractors Compliance and Certifications Attachment, and Substance Abuse Certification and the Prevailing Wage Determination and Supersedes Notice comprise the Bid Documents. The Bid Documents, together with the Standard Abbreviated

Form of Agreement Between Owner and Contractor, AIA Document A104-2017, as modified by the Park District and included in these Bid Documents, and the Performance Bond and Labor Material Payment Bond and proof of insurance comprise the Contract Documents.

J. INTERPRETATION OF THE CONTRACT DOCUMENTS

The Park District shall in all cases determine the amount or quantity of the several kinds of Work which are to be paid for under this Contract, and shall decide all questions which may arise relative to the execution of the Contract on the part of the Contractor, and all estimates and decisions shall be final and conclusive. The Park District shall have the right to make alterations in the lines, grades, plans, forms, or dimensions of the Work herein contemplated either before or after the commencement of the Work. If such alterations diminish the quantity of the Work to be done, they shall not constitute a claim for damage or for anticipated profits on the work dispensed with, or if they increase the amount of Work, such increase shall be paid according to the quantity actually done and at the price or prices stipulated for such Work in the Contract. The Park District reserves the right to approve, an equal to or superior to product or equipment required under the Specifications, or to reject as not being and equal to or superior to the product or equipment required under the Specifications. If the Bidder is in doubt as to the interpretation of any part of the Bid Documents, or finds errors, discrepancies or omissions from any part of the Contract Documents, he must submit a written request for interpretation thereof not later than five (5) days prior to opening of bids to the Park District. Address all communications to the Architect. If an error or omission is discovered in the Bid Documents after the bid opening, the Park District reserves the right: 1) to determine whether to require the submission of new bids; or 2) if the error or omission is of such a nature that it was reasonably discoverable upon a careful review of the Bid Documents, to award the Contract to the lowest responsive and responsible Bidder as determined by the Park District and to require that Contractor to perform the Work in accordance with an issued correction by the Park District and for the amount bid by the Contractor. Such decisions are final and not subject to recourse. Errors and omissions made by the Bidder cannot be corrected after the bid opening.

K. ADDENDA

Any interpretation, correction to, or addition to the Bid Documents will be made by written Addendum and will be delivered by mail or fax to each prime Bidder of record. The written Addenda constitute the only interpretations of the Bid Documents; the Park District accepts no responsibility for any other claimed interpretations or communications.

It is the responsibility of each Bidder to verify that he has received all Addenda prior to submitting a bid. It is also the responsibility of each Bidder to verify that all subcontractors and material suppliers whose prices are incorporated in the Bidder's bid are familiar with the Bid Documents in their entirety, including all Addenda issued up to the time of bid opening.

In the event a conflict or omission is discovered in the Bid Documents after the issuing of the last Addendum such that an interpretation cannot be issued by the Architect or Park District prior to bidding, the Bidder is directed to estimate on and provide the quantity and quality of material and labor consistent with the overall represented and indicated Work so as to provide all materials, equipment, labor, and services necessary for the completion of the Work in accordance with the Bid Documents.

L. SUBSTITUTIONS DURING BIDDING

Unless otherwise indicated, the use of brand names in the Specifications is used for the purpose of establishing a grade or quality. Bidders proposing to use an alternate that is equal to or superior to in every respect to that required by the Specifications must request approval for the proposed substitution by submitting the request and any additional information as required by these Instruction to Bidders and the Specifications to the Architect at least seven (7) business days prior to the bid opening.

Additionally, Bidders requesting approval for use of an alternate must provide certification by the manufacturer that the substitute proposed is equal to or superior in every respect to that required by the Contract Documents, and that its in-place performance will be equal to or superior to the product or equipment specified in the application indicated. The Bidder, in submitting the request for substitution, waives the right to additional payment or an extension of Contract Time because of the failure of the substitute to perform as represented in the request for substitution.

The Architect may request additional information or documentation necessary for evaluation of the request for substitution. The Architect will notify all Bidders of acceptance of the proposed substitute by means of an Addendum to the Bid Documents. The Architect's approval of a substitute during bidding does not relieve the Contractor of the responsibility to submit required shop drawings and to comply with all other requirements of the Contract Documents, including but not limited to proper performance of all components of the Work and suitability for the uses specified.

Bids proposing alternates not previously approved by the Architect will be considered non-responsive and rejected. The Architect and Park District reserve the right to determine whether a substituted selection, in their judgment, is equal to or better quality and therefore an acceptable alternate. Such decisions are final and not subject to recourse.

**CONDITIONS OF THE CONTRACT
OAK BROOK PARK DISTRICT
CENTRAL PARK WEST DOOR AND WINDOW REPLACEMENT PROJECT**

GENERAL CONDITIONS

The General Conditions are the General Provisions of the Standard Abbreviated Form of Agreement Between Owner and Contractor, AIA Document A104-2017, as modified by the Park District and included in these Bid Documents (the “General Conditions”).

SUPPLEMENTARY CONDITIONS

The General Conditions are hereby amended to include the following:

1. COMMENCEMENT AND COMPLETION DATE

All materials and supplies required to complete the Work must be delivered on site by April 31, 2020. Installation of the Work for the Contract shall commence on May 4, 2020, or on such earlier date as may be agreed upon by the parties. Contractor shall achieve Substantial Completion on or before June 4, 2020 and shall achieve Final Completion on or before June 11, 2020, unless otherwise extended by agreement of the parties pursuant to the General Conditions.

2. USE OF THE SITE

The Contractor shall confine all equipment, the storage of materials and the operations of its workers, to limits indicated by law, ordinances, permits, or directions of the Owner and shall not unreasonably encumber the site with such materials. The site shall not be utilized for the storage of vehicles, materials, equipment, or fixtures not intended for the Work to be performed.

3. COOPERATION WITH UTILITIES

The Contractor shall notify all utility companies, public and private, as necessary in advance of commencing performance of the Work. The responsibility for moving water lines, gas lines, wire lines, service connections, water and gas meter boxes, water and gas valve boxes, light standards, cable ways, signals and all other utility appurtenances which are within the limits of the proposed construction will be assumed by the Contractor, at no additional compensation.

The Contractor shall verify the location of all utilities prior to the start of construction and shall be responsible for the preservation of existing utility installation and the cost of providing precautionary supports, braces, etc. to insure against damage to said utility installation.

The cost to repair and replace any new or existing utilities damaged will be paid for by the Contractor.

It is understood and agreed that the Contractor has considered in its bid all of the permanent and temporary utility appurtenances in their present or relocated positions and that no additional compensation will be allowed for delays, inconvenience, or damage sustained by the Contractor, due to any interference from the said utility appurtenances or the operation of moving them either by the utility company or by the Contractor, or on account of any special construction methods required in performing the Work due to the existence of said appurtenances whether in their present or relocated positions.

4. PROTECTION OF PROPERTY -SAFETY RESPONSIBILITY

In accordance with the Specifications, the Contractor shall protect all existing property and improvements within the Project site and those adjacent to the Owner's property in a manner agreed upon between the Owner and Contractor. The Contractor shall be responsible for the repair cost of any damage created by its operations or the operations of any subcontractors.

Contractor shall comply with State and Federal regulations as outlined in the latest revision of the Federal Construction Safety Standards and with applicable provisions and regulations of Occupation Safety and Health Administration (OSHA), Standards of the William-Steiger Occupational Health and Safety Act of 1970 (revised). The Contractor and Owner shall each be responsible for their respective agents and employees.

The Contractor shall be obligated to indemnify, hold harmless and protect the Owner, its officers, employees and agents, from any actions or suits instituted as a direct or indirect result of any injury or damage consequent upon any failure to use or misuse by the Contractor, its agents and employees and any subcontractor, its agents and employees, of any ladder, support or other mechanical contrivance erected or constructed by any person or any or all kinds of equipment whether or not Owner or furnished by the Owner.

5. INSURANCE

BIDDER'S ATTENTION IS DIRECTED TO THE INSURANCE REQUIREMENTS BELOW. IT IS HIGHLY RECOMMENDED THAT THE BIDDER CONFER WITH ITS INSURANCE CARRIER REGARDING THESE REQUIREMENTS. FAILURE TO MEET THESE REQUIREMENTS IS CAUSE FOR CANCELLATION OF THE CONTRACT.

The successful Bidder shall obtain insurance of the types and in the amounts listed below.

a. Commercial General and Umbrella Liability Insurance

The successful Bidder shall maintain commercial general liability (CGL) and, if necessary, commercial umbrella insurance with a limit of not less

then \$2,000,000 each occurrence. If such CGL insurance contains a general aggregate limit, it shall apply separately to this project/location.

CGL insurance shall be written on Insurance Services Office (ISO) occurrence form CG 00 01 04 13, or a substitute form providing equivalent coverage, and shall cover liability arising from premises, operations, independent contractors, products-completed operations, personal injury and advertising injury, and liability assumed under an insured contract (including the tort liability of another assumed in a business contract).

The District, its elected and appointed officials, employees, agents and volunteers shall be included as an additional named insured under the CGL, using ISO additional insured endorsement CG 20 26 or a substitute providing equivalent coverage, and under the commercial umbrella, if any. This insurance shall apply as primary insurance with respect to any other insurance or self-insurance afforded to District. Any insurance or self-insurance maintained by the District shall be deemed excess of such bidder's insurance and shall not contribute with it.

b. Continuing Completed Operations Liability Insurance

Contractor shall maintain commercial general liability (CGL) and, if necessary, commercial umbrella liability insurance with a limit of not less than \$2,000,000 each occurrence for at least three years following Substantial Completion of the Work.

Continuing CGL insurance shall be written on ISO occurrence form CG 00 01 04 13, or substitute form providing equivalent coverage, and shall, at minimum, cover liability arising from products-completed operations and liability assumed under an insured contract.

Continuing CGL insurance shall have a products-completed operations aggregate of at least two times its each occurrence limit.

Continuing commercial umbrella coverage, if any, shall include liability coverage for damage to the insured's completed work equivalent to that provided under ISO form CG 00 01.

c. Business Auto and Umbrella Liability Insurance

The successful Bidder shall maintain business auto liability and, if necessary, commercial umbrella liability insurance with a limit of not less than \$1,000,000 each accident. Such insurance shall cover liability arising out of any auto including owned, hired and non-owned autos.

Business auto insurance shall be written on Insurance Services Office (ISO) form CA 00 01, CA 00 05, CA 00 12, CA 00 20, or a substitute form providing equivalent liability coverage. If necessary, the policy shall be endorsed to provide contractual liability coverage equivalent to that provided in the 1990 and later editions of CA 00 01.

d. Workers Compensation Insurance

The successful Bidder shall maintain workers compensation and employers liability insurance. The commercial umbrella and/or employers liability limits shall not be less than \$1,000,000 each accident for bodily injury by accident or \$1,000,000 each employee for bodily injury by disease.

Such Bidder waives all rights against District and its officers, officials, employees, volunteers and agents for recovery of damages arising out of or incident to such Bidder's activities.

e. General Insurance Provisions

i. Evidence of Insurance: The successful Bidder shall furnish the District with a certificate(s) of insurance and applicable policy endorsement(s), executed by a duly authorized representative of each insurer, showing compliance with the insurance requirements set forth above.

All certificates shall provide for 30 days' written notice to the District prior to the cancellation or material change of any insurance referred to therein. Written notice to the District shall be by certified mail, return receipt requested.

Failure of the District to demand such certificate, endorsement or other evidence of full compliance with these insurance requirements, or failure of the District to identify a coverage deficiency from evidence that is provided, shall not be construed as a waiver of such Bidder's obligation to maintain such insurance.

The District shall have the right, but not the obligation, of prohibiting such Bidder from entering the premises until such certificates or other evidence that insurance has been placed in complete compliance with these requirements is received and approved by District.

Failure to maintain the required insurance may result in termination of the Contract entered by the parties at the District's option.

Such Bidder shall provide certified copies of all insurance policies required above within 10 days of the District's written request for said copies.

ii. Acceptability of Insurers: All insurance companies shall maintain a rating no less than A-VII from A.M. Best, based on the most recent edition of the A.M. Best's Key Rating Guide. If the Best's rating is less than A-VII or a Best's rating is not obtained, the District has the right to reject insurance written by an insurer it deems unacceptable.

iii. Deductibles and Self-Insured Retentions: Any deductibles or self-insured retentions must be declared to the District. At the option of the District, the successful Bidder may be asked to eliminate such deductibles or self-insured retentions as respects the District, its officers, officials, employees, volunteers and agents, or such Bidder may be required to procure a bond guaranteeing payment of losses and other related costs, including, but not limited to, investigations, claims administration and defense expenses.

f. Subcontractors

Contractor shall cause each subcontractor employed by Contractor to purchase and maintain insurance of the type specified above. When requested by the Owner, Contractor shall furnish copies of certificates of insurance evidencing coverage for each subcontractor.

6. INDEMNIFICATION

To the fullest extent permitted by law, the Contractor shall indemnify and hold harmless the Owner and its officers, officials, employees, volunteers and agents from and against all claims, damages, losses and expenses including but not limited to legal fees (attorney's and paralegals' fees and court costs), arising out of or resulting from the performance of the Contractor's work, provided that any such claim, damage, loss or expense (i) is attributable to bodily injury, sickness, disease or death, or injury to or destruction of tangible property, other than the work itself, including the loss of use resulting there from and (ii) is caused in whole or in part by any wrongful or negligent act or omission of the Contractor, any subcontractor, anyone directly or indirectly employed by any of them or anyone for whose acts any of them may be liable, regardless of whether or not it is caused in part by a party indemnified hereunder. Such obligation shall not be construed to negate, abridge, or otherwise reduce any other right or obligation of indemnity which would otherwise exist as to any party or person described in this Paragraph. Contractor shall similarly protect, indemnify and hold and save harmless the Owner, its officers, officials, employees, volunteers and agents against and from any and all claims, costs, causes, actions and expenses including but not limited to legal fees, incurred by reason of Contractor's breach of any of its obligations under, or Contractor's default of, any provision of the Contract.

Nothing contained herein shall be construed as prohibiting the District, its officers, employees or agents from defending, through the selection and use of their own agents, attorneys and experts, any claims, suits, demands, proceedings or actions brought against

them. The District's participation in its defense shall not remove the successful Bidder's duty to indemnify, defend and hold the District harmless as set forth herein.

The indemnification required hereunder shall not be limited by reason of the enumeration of insurance coverage herein provided.

The successful Bidder's indemnification of the District shall survive the termination or expiration of the Contract.

7. WARRANTY

- A. The Work performed and the materials and equipment installed under this Contract shall be in compliance with the Contract Documents and must be guaranteed by the Contractor and the Surety for a period of twenty four (24) months from Substantial Completion against defective workmanship and material of any nature, unless a longer period is required by the Specifications. On all material or equipment incorporated, the Contractor and its Surety must guarantee that the type, quality, design and performance will fully meet the requirements of the Specifications and Drawings.

- B. The Contractor shall provide the Owner with manufacturer's warranties for all materials and equipment installed under the Contract.

SPECIAL CONDITIONS

- 1. Time is of the essence to the Contract. Should the Contractor fail to complete the Work on or before the Substantial Completion date as stipulated in the Contract or within such extended time as may be have been allowed, the Contractor shall be liable and shall pay to the Owner the sum of \$200.00 per calendar day, not as a penalty but as a liquidated damages for each day of overrun in the Contract Time or such extended time as may have been allowed. The liquidated damages for failure to complete the Contract on time are approximate, due to the impracticality of calculating and proving actual delay costs. The costs of delay represented by the liquidated damage amount are understood to be a fair and reasonable estimate of the costs that will be borne by the Owner during extended and delayed performance by the Contractor for the Work. The liquidated damage amount specified will accrue and be assessed until Final Completion of the total physical Work of the Contract even though the Work may be substantially complete. The Owner will deduct these liquidated damages from any monies due or to become due to the Contractor from the Owner.

- 2. Central Park West shall remain open to the public during weekends for the duration of the Project. As such, Contractor shall maintain the Project site in a manner that ensures safe access to Central Park West amenities by the public, Park District staff and others requiring access to Central Park West. Additionally, the Contractor shall ensure that the Project site is clean, all tools are either removed from the Project site or safely security on-site in a manner that will not restrict access to Central Park West by the public and Park District

staff, and Central Park West is otherwise able to be occupied and operated as a rental space during the weekends by the public. Contractor shall comply with and give notices required by applicable laws, statutes, ordinances, codes, rules and regulations, and lawful orders of public authorities bearing on safety of persons or property or their protection from damage, injury or loss.

3. Contractor shall only perform work four (4) days a week and only on the designated days as specified on the Central Park West Monthly Calendar included in these Bid Documents.

**BID FORM
OAK BROOK PARK DISTRICT
CENTRAL PARK WEST DOOR AND WINDOW REPLACEMENT PROJECT**

(Please complete in ink, and print or type)

TO: Oak Brook Park District
1450 Forest Gate Road
Oak Brook, IL 60523

FROM: _____
NAME OF BIDDER

STREET ADDRESS

CITY STATE ZIP

PHONE

EMAIL ADDRESS

FOR: Central Park West Door and Window Replacement Project

By submission of its bid, the Bidder acknowledges, agrees, represents, declares and warrants:

- A. That he has carefully examined the written Specifications and Drawings and is thoroughly familiar therewith, and that he has visited the site of the proposed Work to arrive at a clear understanding of the conditions under which the Work is to be done, and that he has compared the site with the Drawings and Specifications and has satisfied himself as to all conditions affecting the execution of the Work;
- B. That all modifications have been submitted with this bid;
- C. That he has checked carefully the bid figures and understands that he shall be responsible for any errors or omissions based on these Specifications and alternates as submitted on the Bid Proposal Form;
- D. That it is understood and agreed that the Oak Brook Park District reserves the right to accept or reject any or all bids, or to combine or separate any section or work, and to waive any technicalities;
- E. To hold the bid open for sixty (60) days subsequent to the date of the bid opening;
- F. To enter into and execute a Contract with the Owner within ten (10) days after the date of the Notice of Award, if awarded on the basis of this bid, and in connection therewith to:
 - (a) Furnish all bonds and insurance required by the Contract Documents;
 - (b) Accomplish the Work in accordance with the Contract Documents; and
 - (c) Complete the Work within the time requirements as set forth in the Bid Documents.

- G. That if this bid is accepted, the Bidder is to provide all of the necessary equipment, tools, apparatus, labor, and other means of construction, and to do all of the Work and to furnish all of the materials specified in the Bid Documents in the manner and at the time therein prescribed, and in accordance with the requirements set forth;
- H. To commence Work as specified in the Instructions to Bidders, and to prosecute the Work in such a manner, and with sufficient materials, equipment and labor as will ensure its completion within reasonable time, it being understood and agreed that the completion within such reasonable time is an essential part of this Contract;
- I. That any and all prices stated in the proposal include all costs of labor, materials, equipment, insurance, bonds, overhead and profit, and any and all other costs normal to doing business.

The undersigned Bidder agrees to perform the Work for the following lump sum price:

Base Bid	Amount
Replacement of the sliding glass exterior doors in the main community room at Central Park West with swinging patio doors with side lights.	\$

Total Lump Sum Bid: _____

Alternate No. 1	Amount
East Window Replacement - To replace east window and frame with window / frame type "S" and door A109C: State the amount to be ADDED to the base bid for removing and replacing the existing exterior east window and door in Meeting Room A109 with windows and frame type "S" and door A109C.	\$

Alternate No. 2	Amount
North Clerestory Window Replacement - To replace north clerestory window and frames with window / frame type "W2": State the amount to be ADDED to the base bid for removing and replacing the existing exterior north clerestory window with window / frame type "W2".	\$

Bids will be awarded to one Bidder for the entire Project or to any series of Bidders for an appropriate proportion of the Project.

The undersigned Bidder hereby acknowledges the receipt of the following addenda (if any) distributed by the Park District.

Addendum No. _____ Date: _____
 Addendum No. _____ Date: _____

All materials and supplies required to complete the Work must be delivered on site by April 31, 2020. Installation of the Work for the Contract shall commence on May 4, 2020, or on such earlier date as may be agreed upon by the parties. Contractor shall achieve Substantial Completion on or before June 4, 2020 and shall achieve Final Completion on or before June 11, 2020, unless otherwise extended by agreement of the parties pursuant to the General Conditions. Contractor shall only perform Work four (4) days a week and only on the designated days as specified on the Central Park West Monthly Calendar included in these Bid Documents.

The undersigned Bidder agrees that if this bid is accepted by the Park District, it will perform all Work in accordance with the requirements of the Contract.

DATED THIS _____ DAY OF _____, 2020.

Full Name of Bidder (Print) (a) Individual ()
(b) Partnership ()
(c) Corporation ()

Name and Title of Authorized Agent
if Corporation or Partnership (Print): _____

Full Name and Title of Bidder (Signature)

Street Address

City/State/Zip

Email

Phone _____

LIST OF SUBCONTRACTORS

Bidder submits a list of subcontractors for each trade relative to the Work to be performed under the Contract with the District, and agrees that if selected the successful Contractor, the Bidder will promptly confer with the District's agents on the question of which subcontractors the Bidder proposes to use, including submission of their qualifications. It is agreed that the District may substitute for any proposed subcontractor, another subcontractor for the trade against whose standing and ability the Bidder makes no objection in writing, and the Bidder will use all such finally selected subcontractors at the amount named in their respective subcontracts, and be in every way responsible for them and their work as if they had been originally named in the Bidder's bid, the unit, total and alternate Contract prices being adjusted to confirm thereto.

Subcontractor Name & Address Classification of Work Amount of Subcontract

1.		
2.		
3.		
4.		

BIDDER'S REFERENCE LIST

Each Bidder must list the name, address, phone number and project name for at least three (3) projects performed for governmental entities of similar scope and complexity as this Project in the past five (5) years. Bidder may include, as a separate attachment, additional information or references on projects completed.

1. _____
Name of Park District, School District, or Municipality

Contact Person

Phone Number _____ E-Mail _____

Description of Work performed _____ Project Value _____

2. _____
Name of Park District, School District, or Municipality

Contact Person

Phone Number _____ E-Mail _____

Description of Work performed _____ Project Value _____

3. _____
Name of Park District, School District, Municipality

Contact Person

Phone Number _____ E-Mail _____

Description of Work performed _____ Project Value _____

CONTRACTOR COMPLIANCE AND CERTIFICATIONS ATTACHMENT

Note: The following certifications form an integral part of the Agreement between the Owner and Contractor. Breach by Contractor of any of the certifications may result in immediate termination of the Contractor's services by Owner.

THE UNDERSIGNED CONTRACTOR HEREBY ACKNOWLEDGES, CERTIFIES, AFFIRMS AND AGREES AS FOLLOWS:

- A. Contractor has carefully read and understands the contents, purpose and legal effect of this document as stated above and hereafter in this document. The certifications contained herein are true, complete and correct in all respects.
- B. Contractor shall abide by and comply with, and in contracts which it has with all persons providing any of the services or Work on this Project on its behalf shall require compliance with, all applicable Federal, State and local laws and rules and regulations including without limitation those relating to 1) fair employment practices, affirmative action and prohibiting discrimination in employment; 2) workers' compensation; 3) workplace safety; 4) wages and claims of laborers, mechanics and other workers, agents, or servants in any manner employed in connection with contracts involving public funds or the development or construction of public works, buildings or facilities; and 5) steel products procurement.
- C. All contracts for this Project are subject to the provisions of the Illinois Prevailing Wage Act (820 ILCS 130/0.01 *et seq.*), providing for the payment of the prevailing rate of wage to all laborers, workmen and mechanics engaged in the Work. Contractor shall pay prevailing rates of wages in accordance with the Illinois Department of Labor's wage determination and any subsequent determinations issued by the Illinois Department of Labor, all in accordance with applicable law. These revisions may be accessed by computer at <http://labor.illinois.gov/>. Contractor is responsible for determining the applicable prevailing wage rates at the time of bid submission and at the time of performance of the Work. Failure of Contractor to make such determination shall not relieve it of its obligations in accordance with the Contract Documents. Contractor shall also comply with all other requirements of the Act including without limitation those pertaining to inclusion of required language in subcontracts, job site posting, maintenance and submission of certified payroll records and inspection of records. Contractor is not barred from entering into public contracts under Section 11a of the Illinois Prevailing Wage Act due to its having been found to have disregarded its obligations under the Act.
- D. To the best of Contractor's knowledge, no officer or employee of Contractor has been convicted of bribery or attempting to bribe an officer or employee of the State of Illinois, or any unit of local government, nor has any officer or employee made an admission of guilt of such conduct which is a matter of record.
- E. Contractor is not barred from bidding on or entering into public contracts due to having been convicted of bid-rigging or bid rotating under paragraphs 33E-3 or 33E-4 of the Illinois Criminal Code. Contractor also certifies that no officers or employees of the Contractor have been so convicted and that Contractor is not the successor company or a new company created by the officers or owners of one so convicted. Contractor further certifies that any such conviction occurring after the date of this certification will be reported to the Owner, immediately in writing, if it occurs during the bidding process, or otherwise prior to entering into the Contract therewith.

- F. Pursuant to the Illinois Human Rights Act (775 ILCS 5/2-105), Contractor has a written sexual harassment policy that includes, at a minimum, the following information: (i) a statement on the illegality of sexual harassment; (ii) the definition of sexual harassment under State law; (iii) a description of sexual harassment utilizing examples; (iv) the Contractor's internal complaint process including penalties; (v) the legal recourse, investigative and complaint process available through the Illinois Department of Human Rights and the Human Rights Commission and directions on how to contact both; and (vi) protection against retaliation as provided by Section 6-101 of the Illinois Human Rights Act. Contractor further certifies that such policy shall remain in full force and effect. A copy of the policy shall be provided to the Illinois Department of Human Rights upon request.
- G. (i) Contractor's bid proposal was made without any connection or common interest in the profits anticipated to be derived from the Contract by Contractor with any other persons submitting any bid or proposal for the Contract; (ii) the Contract terms are in all respects fair and the Contract will be entered into by Contractor without collusion or fraud; (iii) no official, officer or employee of the Owner has any direct or indirect financial interest in Contractor's bid proposal or in Contractor, (iv) the Contractor has not directly or indirectly provided, and shall not directly or indirectly provide, funds or other consideration to any person or entity (including, but not limited to, the Owner and the Owner's employees and agents), to procure improperly special or unusual treatment with respect to this Agreement or for the purpose of otherwise improperly influencing the relationship between the Owner and the Contractor. Additionally, the Contractor shall cause all of its officers, directors, employees, (as the case may be) to comply with the restrictions contained in the preceding sentence.
- H. Contractor knows and understands the Equal Employment Opportunity Clause administered by the Illinois Department of Human Rights, which is incorporated herein by this reference, and agrees to comply with the provisions thereof. Contractor further certifies that Contractor is an "equal opportunity employer" as defined by Section 2000 (e) of Chapter 21, Title 42 of the United States Code Annotated and Executive Orders #11246 and #11375 as amended, which are incorporated herein by this reference.
- I. Neither Contractor nor any substantially owned affiliated company is participating or shall participate in an international boycott in violation of the provisions of the U.S. Export Administration Act of 1979 or the regulations of the U.S. Department of Commerce promulgated under that Act.
- J. Contractor is not barred from contracting with the Owner because of any delinquency in the payment of any tax administered by the Illinois Department of Revenue, unless it is being contested. Contractor further certifies that it understands that making a false statement regarding delinquency in taxes is a Class A misdemeanor and, in addition, voids the Contract and allows the Owner, a municipal entity, to recover in a civil action all amounts paid to the Contractor.
- K. If Contractor has 25 or more employees at the time of letting of the Contract, Contractor knows, understands and acknowledges its obligations under the Illinois Drug Free Workplace Act (30 ILCS 580/1 *et seq.*) and certifies that it will provide a drug-free workplace by taking the actions required under, and otherwise implementing on a continuing basis, Section 3 of the Drug Free Workplace Act. Contractor further certifies that it has not been debarred and is not ineligible for award of this Contract as the result of a violation of the Illinois Drug Free Workplace Act.
- L. Contractor knows, understands and acknowledges its obligations under the Substance Abuse Prevention on Public Works Act, 820 ILCS 265/1 *et seq.* A true and complete copy of Contractor's

Substance Abuse Prevention Program Certification is attached to and made a part of this Contractor Compliance and Certification Attachment.

M. The Contractor shall comply with the requirements and provisions of the Freedom of Information Act (5 ILCS 140/1 *et. seq.*) and, upon request of the Oak Brook Park District’s designated Freedom of Information Act Officer (FOIA Officer), Contractor shall within two (2) business days of said request, turn over to the FOIA Officer any record in the possession of the Contractor that is deemed a public record under FOIA.

CONTRACTOR

By: _____

Its: _____

STATE OF _____)

)SS

COUNTY OF _____)

I, the undersigned, a notary public in and for the State and County, aforesaid, hereby certify that _____ appeared before me this day and, being first duly sworn on oath, acknowledged that he/she executed the foregoing instrument as his/her free act and deed and as the act and deed of the Contractor.

Dated:_____

(Notary Public)

(SEAL)

SUBSTANCE ABUSE PREVENTION PROGRAM CERTIFICATION

The Substance Abuse Prevention on Public Works Projects Act, 820 ILCS 265/1 et seq., (“Act”) prohibits any employee of the Contractor or any Subcontractor on a public works project to use, possess or be under the influence of a drug or alcohol, as those terms are defined in the Act, while performing work on the project. The Contractor/Subcontractor **[circle one]**, by its undersigned representative, hereby certifies and represents to the Oak Brook Park District that **[Contractor/Subcontractor must complete either Part A or Part B below]:**

A. The Contractor/Subcontractor **[circle one]** has in place for all of its employees not covered by a collective bargaining agreement that deals with the subject of the Act a written substance abuse prevention program, a true and correct copy of which is attached to this certification, which meets or exceeds the requirements of the Substance Abuse Prevention on Public Works Act, 820 ILCS 265/1 et seq. **[Contractor/Subcontractor must attach a copy of its substance abuse prevention program to this Certification.]**

Name of Contractor/Subcontractor (print or type)

Name and Title of Authorized Representative (print or type)

Signature of Authorized Representative

_____ Dated: _____

B. The Contractor/Subcontractor **[circle one]** has one or more collective bargaining agreements in effect for all of its employees that deal with the subject matter of the Substance Abuse Prevention on Public Works Projects Act, 820 ILCS 265/1 et seq.

Name of Contractor/Subcontractor (print or type)

Name and Title of Authorized Representative (print or type)

Signature of Authorized Representative

_____ Dated: _____

IMPORTANT NOTICE OF RESPONSIBILITY FOR PERIODIC REVISIONS TO PREVAILING WAGE RATES

Revisions of the Prevailing Wage Rates are made periodically by the Illinois Department of Labor (IDOL). As required by the Illinois Prevailing Wage Act, the contractor/subcontractor has an obligation to check IDOL's web site for revisions to prevailing wage rates. These revisions may be accessed by computer at <http://labor.illinois.gov/>. Bidders and contractors performing work on this Project are responsible for determining the applicable prevailing wage rates at the time of bid submission and performance of the Work. Failure of a bidder/contractor to make such determination shall not relieve it of its obligations in accordance with the Contract Documents. In consideration for the award to it of the contract for this Project, the contractor agrees that the foregoing notice satisfies any obligation of the public body in charge of this Project to notify the contractor of periodic changes in the prevailing wage rates and the contractor agrees to assume and be solely responsible for, as a material obligation of the contractor under the contract, the obligation to determine periodic revisions of the prevailing wage rates, to notify its subcontractors of such revisions, to post such revisions as required for the posting of wage rates under the Act, and to pay and require its subcontractors to pay wages in accordance with such revised rates.

Owner/Contractor Agreement

AIA[®] Document A104[™] – 2017

Standard Abbreviated Form of Agreement Between Owner and Contractor

AGREEMENT made as of the day of in the year Two Thousand Twenty
(In words, indicate day, month and year.)

BETWEEN the Owner:
(Name, legal status, address and other information)

Oak Brook Park District
1450 Forest Gate Road
Oak Brook, IL 60523

and the Contractor:
(Name, legal status, address and other information)

for the following Project:
(Name, location and detailed description)

Central Park West Door and Window Replacement Project
1500 Forest Gate Road
Oak Brook, IL 60523

This Project includes replacement of the sliding glass exterior doors in the main community room at Central Park West with swinging patio doors with side lights, and all other incidental and collateral work necessary to complete the Project in accordance with the Contract Documents.

The Architect:
(Name, legal status, address and other information)

Legat Architects, Inc.
2015 Spring Road, Suite 175
Oak Brook, IL 60523

The Owner and Contractor agree as follows.

ADDITIONS AND DELETIONS:
The author of this document has added information needed for its completion. The author may also have revised the text of the original AIA standard form. An *Additions and Deletions Report* that notes added information as well as revisions to the standard form text is available from the author and should be reviewed. A vertical line in the left margin of this document indicates where the author has added necessary information and where the author has added to or deleted from the original AIA text.

This document has important legal consequences. Consultation with an attorney is encouraged with respect to its completion or modification.

TABLE OF ARTICLES

1	THE WORK OF THIS CONTRACT
2	DATE OF COMMENCEMENT AND SUBSTANTIAL COMPLETION
3	CONTRACT SUM
4	PAYMENT
5	DISPUTE RESOLUTION
6	ENUMERATION OF CONTRACT DOCUMENTS
7	GENERAL PROVISIONS
8	OWNER
9	CONTRACTOR
10	ARCHITECT
11	SUBCONTRACTORS
12	CONSTRUCTION BY OWNER OR BY SEPARATE CONTRACTORS
13	CHANGES IN THE WORK
14	TIME
15	PAYMENTS AND COMPLETION
16	PROTECTION OF PERSONS AND PROPERTY
17	INSURANCE AND BONDS
18	CORRECTION OF WORK
19	MISCELLANEOUS PROVISIONS
20	TERMINATION OF THE CONTRACT
21	CLAIMS AND DISPUTES
22	OTHER CONDITIONS OR PROVISIONS
23	COMPLIANCE WITH LAWS

EXHIBIT A DETERMINATION OF THE COST OF THE WORK

ARTICLE 1 THE WORK OF THIS CONTRACT

The Contractor shall execute the Work described in the Contract Documents, except as specifically indicated in the Contract Documents to be the responsibility of others.

ARTICLE 2 DATE OF COMMENCEMENT AND SUBSTANTIAL COMPLETION

§ 2.1 The date of commencement of the Work shall be:

Init.

AIA Document A104™ – 2017 (formerly A107™ – 2007). Copyright © 1936, 1951, 1958, 1961, 1963, 1966, 1970, 1974, 1978, 1987, 1997, 2007 and 2017 by The American Institute of Architects. All rights reserved. **WARNING: This AIA® Document is protected by U.S. Copyright Law and International Treaties. Unauthorized reproduction or distribution of this AIA® Document, or any portion of it, may result in severe civil and criminal penalties, and will be prosecuted to the maximum extent possible under the law.** This document was produced by AIA software at 15:57:50 ET on 02/20/2020 under Order No.8830539077 which expires on 06/25/2020, and is not for resale.

User Notes:

(1899329843)

(Check one of the following boxes.)

- The date of this Agreement.
- A date set forth in a notice to proceed issued by the Owner.
- Established as follows:
(Insert a date or a means to determine the date of commencement of the Work.)

All materials and supplies required to complete the Work must be delivered on site by April 31, 2020. Installation of the Work for the Contract shall commence on May 4, 2020.

If a date of commencement of the Work is not selected, then the date of commencement shall be the date of this Agreement.

§ 2.2 The Contract Time shall be measured from the date of commencement.

§ 2.3 Substantial Completion

§ 2.3.1 Subject to adjustments of the Contract Time as provided in the Contract Documents, the Contractor shall achieve Substantial Completion of the entire Work:

(Check the appropriate box and complete the necessary information.)

- Not later than () calendar days from the date of commencement of the Work.
- By the following date: June 4, 2020

§ 2.3.2 Subject to adjustments of the Contract Time as provided in the Contract Documents, if portions of the Work are to be completed prior to Substantial Completion of the entire Work, the Contractor shall achieve Substantial Completion of such portions by the following dates:

Portion of Work	Substantial Completion Date
NA	

§ 2.3.3 If the Contractor fails to achieve Substantial Completion as provided in this Section 2.3, liquidated damages, if any, shall be assessed as set forth in Section 3.5.

§ 2.4 Final Completion

§ 2.4.1 Subject to adjustments of the Contract Time as provided in the Contract Documents, the Contractor shall achieve Final Completion of the entire Work:

(Check the appropriate box and complete the necessary information.)

- Not later than () calendar days from the date of commencement of the Work.
- By the following date: June 11, 2020

§ 2.4.2 If the Contractor fails to achieve Final Completion as provided in this Section 2.4, liquidated damages, if any, shall be assessed as set forth in Section 3.5.

ARTICLE 3 CONTRACT SUM

§ 3.1 The Owner shall pay the Contractor the Contract Sum in current funds for the Contractor's performance of the Contract. The Contract Sum shall be one of the following:

(Check the appropriate box.)

- Stipulated Sum, in accordance with Section 3.2 below

- Cost of the Work plus the Contractor's Fee, in accordance with Section 3.3 below
- Cost of the Work plus the Contractor's Fee with a Guaranteed Maximum Price, in accordance with Section 3.4 below

(Based on the selection above, complete Section 3.2, 3.3 or 3.4 below.)

§ 3.2 The Stipulated Sum shall be Dollars (\$), subject to additions and deductions as provided in the Contract Documents.

§ 3.2.1 The Stipulated Sum is based upon the following alternates, if any, which are described in the Contract Documents and are hereby accepted by the Owner:
(State the numbers or other identification of accepted alternates. If the bidding or proposal documents permit the Owner to accept other alternates subsequent to the execution of this Agreement, attach a schedule of such other alternates showing the amount for each and the date when that amount expires.)

§ 3.2.2 Unit prices, if any:
(Identify the item and state the unit price and the quantity limitations, if any, to which the unit price will be applicable.)

Item	Units and Limitations	Price per Unit (\$0.00)
------	-----------------------	-------------------------

§ 3.2.3 Allowances, if any, included in the stipulated sum:
(Identify each allowance.)

Item	Price
NA	

(Paragraphs deleted)

§ 3.2.4 Adjustments to the Contract Sum: Adjustments to the Contract Sum for changes in the Work other than changes in the Work involving items for which unit prices were requested by Owner and provided in Contractor's Submitted Bid Proposal, shall be made as follows:

1. In the manner agreed to by the Parties, or in the absence of agreement then the combined allowance for overhead and profit in connection with changes to the Work shall be the lesser of the amount, if any, included in the Contractor's bid proposal, or the following:
 - a. Five percent (5%) of the cost of the change in the Work involved if performed by the Contractor not involving Subcontractors, or
 - b. Five percent (5%) of the cost of the change in the Work involved performed by Subcontractors, plus two percent (2%) of the cost of the change in the Work for the Contractor's supervision of the work performed by the Subcontractors.

When both additions and credits covering related Work are involved in a change, the allowance for overhead and profit shall be figured on the basis of net increase, if any, with respect to that change.

§ 3.2.5 Overtime, if and when specifically authorized in advance in writing by the Owner shall be paid by the Owner on the basis of premium payment if any, plus the cost of insurance and taxes based on the premium payment period. No overhead or profit may be charged for overtime. The Contractor shall not be entitled to any payment for overtime necessitated by the failure of the Contractor to perform the Work in accordance with the Contract Documents including without limitation to the Contractor's failure to prosecute the Work diligently and on an uninterrupted basis

and with a sufficient work force so as to achieve completion of the Work within the time and in the manner contemplated by the Contract Documents or otherwise due to the fault of the Contractor. In such instances if the Owner requires the Contractor to perform Work on an overtime basis, all costs for and associates with such overtime shall be borne by the Contractor.

(Paragraphs deleted)

(Table deleted)

(Paragraphs deleted)

(Table deleted)

§ 3.5 Liquidated damages, if any:

(Insert terms and conditions for liquidated damages, if any.)

Time is of the essence to the Contract. Should the Contractor fail to complete the Work on or before the Substantial Completion date as stipulated in the Contract or within such extended time as may have been allowed, the Contractor shall be liable and shall pay to the Owner the sum of \$200.00 per calendar day, not as a penalty but as a liquidated damages for each day of overrun in the Contract Time or such extended time as may have been allowed. The liquidated damages for failure to complete the Contract on time are approximate, due to the impracticality of calculating and proving actual delay costs. The costs of delay represented by the liquidated damage amount are understood to be a fair and reasonable estimate of the costs that will be borne by the Owner during extended and delayed performance by the Contractor for the Work. The liquidated damage amount specified will accrue and be assessed until Final Completion of the total physical Work of the Contract even though the Work may be substantially complete. The Owner will deduct these liquidated damages from any monies due or to become due to the Contractor from the Owner.

ARTICLE 4 PAYMENT

§ 4.1 Progress Payments

§ 4.1.1 Based upon Applications for Payment properly completed and accompanied by all supporting documentation and other submittals required by the Contract Documents, submitted to the Architect by the Contractor and Certificates for Payment issued by the Architect, and agreed to by the Owner and not subsequently nullified by the Architect in accordance with the Contract Documents, the Owner shall make progress payments on account of the Contract Sum to the Contractor as provided below and elsewhere in the Contract Documents.

§ 4.1.2 The period covered by each Application for Payment shall be one calendar month ending on the last day of the month.

§ 4.1.3 Provided that an Application for Payment, which is in proper form and accompanied by the required supporting documents and submittals, in form and substance required by the Contract Documents, is received by the Architect not later than the 10th day of a month, certified by Architect and not subsequently nullified by Architect, the Owner shall make payment of the certified amount to the Contractor not later than the fifteenth day of the following month. If an Application for Payment is received by the Architect after the date fixed above, payment shall be made by the Owner not later than forty-five (45) days after the Architect receives the Application for Payment.

(Federal, state or local laws may require payment within a certain period of time.)

§ 4.1.4 For each progress payment made prior to Final Completion of the Work, the Owner may withhold retainage from the payment otherwise due as follows:

(Insert a percentage or amount to be withheld as retainage from each Application for Payment and any terms for reduction of retainage during the course of the Work. The amount of retainage may be limited by governing law.)

10% of the Contract Sum

§ 4.1.5 Payments due and unpaid under the Contract, and any penalties associated with the same, shall be paid in accordance with the provisions of, the Illinois Local Government Prompt Payment Act, 50 ILCS 505/1 *et seq.*

(Paragraph deleted)

§ 4.2 Final Payment

§ 4.2.1 Final payment, constituting the entire unpaid balance of the Contract Sum, shall be made by the Owner to the Contractor when

- .1 the Contractor has achieved Final Completion of the Work, including Final Completion for Contractor’s responsibility to correct Work as provided in Sections 9.4 and 18.2, and to satisfy other requirements, if any, which extend beyond final payment;
- .2 the Contractor has submitted a final accounting for the Cost of the Work, where payment is on the basis of the Cost of the Work with or without a Guaranteed Maximum Price; and
- .3 a final Certificate for Payment has been issued by the Architect in accordance with Section 15.7.1.

§ 4.2.2 Subject to § 4.2.1, the Owner’s final payment to the Contractor shall be made no later than 30 days after the issuance of the Architect’s final Certificate for Payment and approval by Owner.

ARTICLE 5 DISPUTE RESOLUTION

§ 5.1 Binding Dispute Resolution

The method of binding dispute resolution shall be as follows:
(Check the appropriate box.)

- Arbitration pursuant to Section 21.6 of this Agreement
- Litigation in a court of competent jurisdiction
- Other *(Specify)*

ARTICLE 6 ENUMERATION OF CONTRACT DOCUMENTS

§ 6.1 The Contract Documents are defined in Article 7 and, except for Modifications issued after execution of this Agreement, are enumerated in the sections below.

§ 6.1.1 The Agreement is this executed AIA Document A104™–2017, Standard Abbreviated Form of Agreement Between Owner and Contractor.

§ 6.1.2
(Paragraphs deleted)
Intentionally Omitted.

§ 6.1.3 The Supplementary and other Conditions of the Contract are those included in the Project Manual dated February 21, 2020.
(Table deleted)

§ 6.1.4 The
(Paragraphs deleted)
Specifications are those included in the Project Manual dated February 21, 2020.
(Table deleted)

§ 6.1.5 The Drawings are those included in the Project Manual dated February 21, 2020.
(Either list the Drawings here or refer to an exhibit attached to this Agreement.)
(Table deleted)

§ 6.1.6 The Addenda, if any:

Number	Date	Pages
--------	------	-------

Portions of Addenda relating to bidding or proposal requirements are not part of the Contract Documents unless the bidding or proposal requirements are enumerated in this Article 6.

§ 6.1.7 Additional documents, if any, forming part of the Contract Documents:

- .1 Other Exhibits:

Init.

(Check all boxes that apply.)

- Exhibit A, Determination of the Cost of the Work.
- AIA Document E204™–2017, Sustainable Projects Exhibit, dated as indicated below:
(Insert the date of the E204-2017 incorporated into this Agreement.)

The Sustainability Plan:

Title	Date	Pages
-------	------	-------

Supplementary and other Conditions of the Contract:

Document	Title	Date	Pages
----------	-------	------	-------

.2 Other documents, if any, listed below:
(List here any additional documents that are intended to form part of the Contract Documents.)

- a. Project Manual for Central Park West Door and Window Replacement Project, dated February 21, 2020, incorporated herein by reference.
- b. Contractor’s Proposal, dated _____, 2020, attached to and incorporated in this Agreement as **Exhibit A**.
- c. Contractor’s Compliance and Certification, a copy of which is attached to and incorporated in this Agreement as **Exhibit B**.
- d. Central Park West Work Calendar, a copy of which is attached to and incorporated in this Agreement as **Exhibit C**.
- e. Performance Bond and Labor Material Payment Bond, copies of which are attached to and incorporated as part of this Agreement by reference.

ARTICLE 7 GENERAL PROVISIONS

§ 7.1 The Contract Documents

The Contract Documents are enumerated in Article 6 and consist of this Agreement (including, if applicable, Supplementary and other Conditions of the Contract), Drawings, Specifications, Addenda issued prior to the execution of this Agreement, other documents listed in this Agreement, and Modifications issued after execution of this Agreement. A Modification is (1) a written amendment to the Contract signed by both parties, (2) a Change Order, (3) a Construction Change Directive, or (4) a written order for a minor change in the Work issued by the Architect. The intent of the Contract Documents is to include all items necessary for the proper execution and completion of the Work by the Contractor. The Contract Documents are complementary, and what is required by one shall be as binding as if required by all; performance by the Contractor shall be required to the extent consistent with the Contract Documents and reasonably inferable from them as being necessary to produce the indicated results.

§ 7.2 The Contract

The Contract Documents form the Contract for Construction. The Contract represents the entire and integrated agreement between the parties hereto and supersedes prior negotiations, representations, or agreements, either written or oral. The Contract may be amended or modified only by a Modification. The Contract Documents shall not be construed to create a contractual relationship of any kind between any persons or entities other than the Owner and the Contractor.

§ 7.3 The Work

The term "Work" means the construction and services required by the Contract Documents, whether completed or partially completed, and includes all other labor, materials, equipment, and services provided or to be provided by the Contractor to fulfill the Contractor’s obligations. The Work may constitute the whole or a part of the Project.

§ 7.4 Instruments of Service

Instruments of Service are representations, in any medium of expression now known or later developed, of the tangible and intangible creative work performed by the Architect and the Architect's consultants under their respective professional services agreements. Instruments of Service may include, without limitation, studies, surveys, models, sketches, drawings, specifications, and other similar materials.

§ 7.5 Ownership and use of Drawings, Specifications and Other Instruments of Service

§ 7.5.1 The Contractor, Subcontractors, Sub-subcontractors, and suppliers shall not own or claim a copyright in the Instruments of Service. Submittal or distribution to meet official regulatory requirements or for other purposes in connection with the Project is not to be construed as publication in derogation of the Architect's or Architect's consultants' reserved rights.

§ 7.5.2 The Contractor, Subcontractors, Sub-subcontractors and suppliers are authorized to use and reproduce the Instruments of Service provided to them, subject to the protocols established pursuant to Sections 7.6 and 7.7, if applicable, solely and exclusively for execution of the Work. All copies made under this authorization shall bear the copyright notice, if any, shown on the Instruments of Service. The Contractor, Subcontractors, Sub-subcontractors, and suppliers may not use the Instruments of Service on other projects or for additions to this Project outside the scope of the Work without the specific written consent of the Owner, Architect and the Architect's consultants.

7.5.3 The Owner is the owner of the Contract Documents. The Contractor may retain one record set for use with this Project only. All copies of the Contract Documents except the Contractor's record set, shall be returned or suitably accounted for to the Owner on request upon completion of the Work.

§ 7.6 Digital Data Use and Transmission

The parties shall agree upon protocols governing the transmission and use of Instruments of Service or any other information or documentation in digital form. If applicable, the parties may use AIA Document E203™–2013, Building Information Modeling and Digital Data Exhibit, to establish the protocols for the development, use, transmission, and exchange of digital data.

§ 7.7 Building Information Models Use and Reliance

Any use of, or reliance on, all or a portion of a building information model without agreement to protocols governing the use of, and reliance on, the information contained in the model and without having those protocols set forth in AIA Document E203™–2013, Building Information Modeling and Digital Data Exhibit, if completed, and the requisite AIA Document G202™–2013, Project Building Information Modeling Protocol Form, if completed, shall be at the using or relying party's sole risk and without liability to the other party and its contractors or consultants, the authors of, or contributors to, the building information model, and each of their agents and employees.

§ 7.8 Severability

The invalidity of any provision of the Contract Documents shall not invalidate the Contract or its remaining provisions. If it is determined that any provision of the Contract Documents violates any law, or is otherwise invalid or unenforceable, then that provision shall be revised to the extent necessary to make that provision legal and enforceable. In such case the Contract Documents shall be construed, to the fullest extent permitted by law, to give effect to the parties' intentions and purposes in executing the Contract.

§ 7.9 Notice

§ 7.9.1 Except as otherwise provided in Section 7.9.2, where the Contract Documents require one party to notify or give notice to the other party, such notice shall be provided in writing to the designated representative of the party to whom the notice is addressed and shall be deemed to have been duly served if delivered in person, by mail, by courier, or by electronic transmission in accordance with AIA Document E203™–2013, Building Information Modeling and Digital Data Exhibit, if completed, or as otherwise set forth below:

(If other than in accordance with AIA Document E203–2013, insert requirements for delivering Notice in electronic format such as name, title and email address of the recipient and whether and how the system will be required to generate a read receipt for the transmission.)

§ 7.9.2 Notice of Claims shall be provided in writing and shall be deemed to have been duly served only if delivered to the designated representative of the party to whom the notice is addressed by certified or registered mail, or by courier providing proof of delivery.

(Paragraphs deleted)

ARTICLE 8 OWNER

§ 8.1 Information and Services Required of the Owner

§ 8.1.1 Intentionally omitted.

§ 8.1.2 The Owner shall furnish all necessary surveys and a legal description of the site.

§ 8.1.3 Subject to the Contractor's duties and obligations under the Contract Document and § 9.1.1 of this Agreement, the Contractor shall be entitled to rely on the accuracy of information furnished by the Owner but shall exercise proper precautions relating to the safe performance of the Work.

§ 8.1.4 Except for permits and fees that are the responsibility of the Contractor under the Contract Documents, including those required under Section 9.6.1, the Owner shall secure and pay for other necessary approvals, easements, assessments, and charges required for the construction, use, or occupancy of permanent structures or for permanent changes in existing facilities.

§ 8.2 Owner's Right to Stop the Work

If the Contractor fails to correct Work which is not in accordance with the requirements of the Contract Documents, or fails or refuses to provide a sufficient amount of properly supervised and coordinated labor, material or equipment so as to be able to complete the Work within the Contract Time, or fails to pay subcontractors or material suppliers timely or to remove and discharge within ten days any lien filed upon the Owner's property or funds by anyone claiming by, through or under the Contractor, or disregards the instructions of the Architect or Owner when based on the requirements of the Contract Documents, or otherwise fails to carry out the Work in accordance with the Contract Documents, the Owner may issue a written order to the Contractor to stop the Work, or any portion thereof, until the cause for such order is eliminated; however, the right of the Owner to stop the Work shall not give rise to a duty on the part of the Owner to exercise this right for the benefit of the Contractor or any other person or entity.

§ 8.3 Owner's Right to Carry Out the Work

If the Contractor defaults or neglects to carry out the Work in accordance with the Contract Documents, or fails to perform a duty under or comply with a provision of the Contract Documents and fails within a seven-day period after receipt of written notice from the Owner to commence and continue correction of such default or neglect with diligence and promptness, or fails within such seven-day period to eliminate (or diligently commence to eliminate) the cause of any stop work order issued under Section 8.2 thereof, the Owner may, without prejudice to any other remedies the Owner may have, correct such deficiencies, default or neglect and may deduct the actual cost thereof, including Owner's expenses and compensation for the Architect's services made necessary thereby, from the payment then or thereafter due the Contractor. Architect may, pursuant to Section 15.4.3, withhold or nullify a Certificate for Payment in whole or in part, to the extent reasonably necessary to reimburse the Owner for the reasonable cost of correcting such deficiencies, including the Owner's expenses and compensation for the Architect's additional services made necessary by such default, neglect, or failure. If the Contractor disagrees with the actions of the Owner or the Architect, or the amounts claimed as costs to the Owner, the Contractor may file a Claim pursuant to Article 21.

ARTICLE 9 CONTRACTOR

§ 9.1 Review of Contract Documents and Field Conditions by Contractor

§ 9.1.1 By its execution of the Contract, the Contractor acknowledges, agrees, represents, and warrants that: (a) the Contractor has carefully and thoroughly examined the Contract Documents, and the Contract Documents are full and complete, include all items necessary for the proper execution and completion of the Work, are sufficient to have enabled the Contractor to determine the cost of the Work and the time required for performance of the Work and to enable Contractor to construct the Work indicated therein in accordance with laws, ordinances, codes, regulations and rules applicable to the Work, and otherwise to fulfill all its obligations thereunder, including, but not limited to, Contractor's obligation to construct the Work for an amount not in excess of the Contract Sum on or before the date(s) of Substantial and Final Completion established in the Contract; (b) the omission from the Contract Documents of minor details which ordinarily form a part of first class work and are necessary to the completion of the Work as indicated, shall not be cause for any extra cost but shall be included as if specifically mentioned or detailed; (c) the Contractor has visited and examined the Project site and surrounding areas, examined all physical, legal and other

conditions affecting the Work and correlated its personal observations with the requirements of the Contract Documents, and understands, is familiar with, and satisfied itself as to the same, including, without limitation: (i) the nature, location, and character of the Project and the site, including, without limitation surface conditions of the site and subsurface conditions observable or ascertainable upon the exercise of reasonable diligence including all structures and obstructions thereon and thereunder, both natural and manmade and all surface and subsurface water conditions of the site and the surrounding area; (ii) the nature, location, and character of the general area in which the Project is located, including without limitation, its generally prevailing climatic conditions, available labor supply and labor costs, and available equipment supply and equipment costs; (iii) the availability, quality, quantity and cost of all labor, materials, supplies, tools, equipment and professional services necessary to complete the Work in the manner and within the cost and time frame indicated by the Contract Documents.

By its execution of the Contract, the Contractor acknowledges, agrees, represents and warrants that it has carefully examined the Drawings, Specifications and other Contract Documents and having visited the Project site it has no actual knowledge of any discrepancies, omissions, ambiguities, or conflicts in or between the Contract Documents except those, if any, which have been clarified by Architect by Addenda to the Contractor's satisfaction, and that if it becomes aware of any such discrepancies, omissions, ambiguities, or conflicts, it has an obligation to and will immediately notify Owner and Architect of such fact, and will not proceed until it shall have received the written interpretation of Owner or Architect. If any such differences or conflicts which were ascertainable by careful review of the documents were not called to the Owner's and Architect's attention prior to submission by the Contractor of its bid proposal, the Architect shall decide which of the conflicting requirements will govern based upon the most stringent or highest quality of the requirements and, subject to the approval of the Owner, the Contractor shall perform the Work at no additional cost and/or time to the Owner in accordance with the Architect's decision.

§ 9.1.2 Because the Contract Documents are complementary, the Contractor shall, before starting each portion of the Work, carefully study and compare the various Contract Documents relative to that portion of the Work, as well as the information furnished by the Owner pursuant to Section 8.1.2, shall take field measurements of any existing conditions related to that portion of the Work and shall observe any conditions at the site affecting it. These obligations are for the purpose of facilitating coordination and construction by the Contractor and are not for the purpose of discovering errors, omissions, or inconsistencies in the Contract Documents; however, the Contractor shall promptly report to the Architect any errors, inconsistencies, or omissions discovered by or made known to the Contractor as a request for information in such form as the Architect may require. It is recognized that the Contractor's review is made in the Contractor's capacity as a contractor and not as a licensed design professional unless otherwise specifically provided in the Contract Documents.

§ 9.1.3 Except as otherwise required by the Contract Documents, the Contractor is not required to ascertain that the Contract Documents are in accordance with applicable laws, statutes, ordinances, codes, rules and regulations, or lawful orders of public authorities, but the Contractor shall promptly report to the Architect any nonconformity discovered by or made known to the Contractor as a request for information in such form as the Architect may require.

§ 9.2 Supervision and Construction Procedures

§ 9.2.1 The Contractor shall supervise and direct the Work, using the Contractor's best skill and attention under the full-time supervision of an approved site superintendent or foreman capable of communicating clearly with the Architect and the Owner in English. The Contractor shall be solely responsible for and have control over construction means, methods, techniques, sequences, and procedures, and for coordinating all portions of the Work under the Contract, unless the Contract Documents give other specific instructions concerning these matters.

§ 9.2.2 The Contractor shall be responsible to the Owner for acts and omissions of the Contractor's employees, Subcontractors and their agents and employees, and other persons or entities performing portions of the Work for or on behalf of the Contractor or any of its Subcontractors.

§ 9.2.3 The Contractor has the responsibility to ensure that all material suppliers and Subcontractors, their agents, and employees adhere to the Contract Documents, and that they order materials on time, taking into account the current market and delivery conditions and that they provide materials on time. The Contractor shall coordinate its Work with that of all others on the Project including deliveries, storage, installations, and construction utilities. The Contractor shall be responsible for the space requirements, locations, and routing of its equipment. In areas and locations where the proper and most effective space requirements, locations, and routing cannot be made as indicated, the Contractor

Int.

shall meet with all others involved, before installation, to plan the most effective and efficient method of overall installation.

§ 9.3 Labor and Materials

§ 9.3.1 Unless otherwise provided in the Contract Documents, the Contractor shall provide and pay for labor, materials, equipment, tools, construction equipment and machinery, water, heat, utilities, transportation, and other facilities and services necessary for proper execution and completion of the Work whether temporary or permanent and whether or not incorporated or to be incorporated in the Work.

§ 9.3.2 The Contractor shall enforce strict discipline and good order among the Contractor's employees and other persons carrying out the Work. The Contractor shall not permit employment of unfit persons or persons not skilled in tasks assigned to them.

§ 9.3.3 The Contractor may make a substitution equivalent to or superior to the specified materials only with the consent of the Owner, after evaluation by the Architect and approval by the Owner and in accordance with a Modification.

§ 9.3.4 The Contractor shall only employ labor on the Project or in connection with the Work capable of working harmoniously with all trades, crafts and any other individuals associated with the Project. The Contractor shall also use its reasonable best efforts to minimize the likelihood of any strike, work stoppage or other labor disturbance. The Contractor shall comply with all requirements of OSHA and shall indemnify and hold harmless the Owner against and from any claims, losses, damages or expenses it may incur as a result of the failure of the Contractor or any of its Subcontractors to comply with OSHA requirements.

§ 9.3.5 If the Work is to be performed by trade unions, the Contractor shall make all necessary arrangements to reconcile, without delay, damage, or cost to the Owner and without recourse to the Architect, Owner's representative or the Owner, any conflict between the Contract Documents and any agreements or regulations of any kind at any time in force among members of councils which regulate or distinguish what activities shall not be included in the Work of any particular trade. In case the progress of the Work is affected by any undue delay in furnishing or installing any items or materials or equipment required under the Contract Documents because of the conflict involving any such agreement or regulations, the Architect or Owner's representative with the Owner's approval may require that other materials or equipment of equal kind and quality be provided at no additional cost to the Owner.

§ 9.3.6 The Contractor shall carefully inspect all materials delivered on and to the Project site and reject defective materials without waiting for the Architect or Owner to observe the materials.

§ 9.3.7 The Contractor shall deliver, handle, store and install materials in accordance with manufacturers' or suppliers' instructions.

§ 9.3.8 Before ordering any material or doing any Work, the Contractor shall verify all measurements at the Project Site and Contractor shall be responsible for the correctness of same. No extra charge or compensation will be allowed to the Contractor on account of any difference between actual dimensions and the measurements shown by the Project Drawings.

§ 9.3.9 If any person employed by the Contractor on the Work shall appear to the Owner to be incompetent or conduct himself in a disorderly or improper manner, such person or persons shall be removed from the Work immediately on the request of the Owner. Said removal shall not create any additional cost to Owner and shall not extend the time for completion of the Work.

§ 9.4 Warranty

The Contractor warrants to the Owner and Architect that materials and equipment furnished under the Contract will be of good quality and new unless the Contract Documents require or permit otherwise. The Contractor further warrants that the Work will conform to the requirements of the Contract Documents and will be free from faults and defects. Work, materials, or equipment not conforming to these requirements may be considered defective. The Contractor's warranty excludes remedy for damage or defect caused by abuse, alterations to the Work of persons other than Contractor or subcontractor, improper or insufficient maintenance, improper operation or normal wear and tear under normal usage. All other warranties required by the Contract Documents shall be issued in the name of the Owner, or

shall be transferable to the Owner. Inability, failure or refusal of the Subcontractor or supplier responsible for the defective materials, equipment or Work to correct the same shall not excuse the Contractor from performing under the warranty. If required by the Architect or the Owner, the Contractor shall furnish satisfactory evidence as to the kind and quality of materials being furnished.

All warranties shall include labor and materials and shall be signed by the manufacturer or subcontractor as the case may be and countersigned by the Contractor. All warranties shall be addressed to the Owner and delivered to the Owner upon completion of the Work and before or with the submission of request for final payment. Except as otherwise provided in this Agreement or elsewhere in the Contract Documents, or in any Certificate of Substantial or Partial Completion approved by the Owner and Contractor and/or subcontractor, as applicable, all warranties shall become effective on the date of Substantial Completion of the entire Work unless otherwise provided in any Certificate of Partial or Substantial Completion approved by the Owner and the Contractor or Subcontractor, as applicable, but only with respect to warranties for that specific portion of the Work, and shall run for a twenty-four (24) month period, unless a longer period is provided for in the Contract Documents or by law. Where warranties overlap, the more stringent requirement shall govern. The Contractor shall consult with the Owner prior to the submission of any application to the appropriate permitting agency or authority in order to afford Owner the opportunity to obtain a waiver or reduction of any fees or costs associated therewith.

Defective materials, equipment or workmanship occurring within the Warranty period may be repaired where such produces results conforming to the Contract Documents relating to appearance, performance and reliability. Where the nature of the defective materials, equipment or workmanship is such that acceptable results cannot be obtained by repair, such defective items shall be removed and replaced with new materials, equipment or workmanship complying with the Contract Documents.

§ 9.5 Taxes

The Contractor shall pay sales, consumer, use, and other similar taxes that are legally enacted when bids are received or negotiations concluded, whether or not yet effective or merely scheduled to go into effect. Because the Owner is an Illinois unit of local government, the Illinois sales tax is not applicable to materials, equipment and supplies incorporated in the Work or wholly consumed in the performance of the Work. The Owner will provide its sales tax exemption number for use by Contractor in purchasing such materials, equipment and supplies for this Project.

§ 9.6 Permits, Fees, Notices, and Compliance with Laws

§ 9.6.1 Unless otherwise provided in the Contract Documents, the Contractor shall secure and pay for the building permit as well as other permits, fees, licenses, and inspections by government agencies necessary for proper execution and completion of the Work that are customarily secured after execution of the Contract and legally required at the time bids are received or negotiations concluded.

§ 9.6.2 The Contractor shall comply with and give notices and permit inspections required by applicable laws, statutes, ordinances, codes, rules and regulations, and lawful orders of public authorities applicable to performance of the Work or having jurisdiction over the Work. The Contractor shall promptly notify the Architect and Owner if any of the Contract Documents appear to be a variance therewith. If the Contractor performs Work knowing it to be contrary to applicable laws, statutes, ordinances, codes, rules and regulations, or lawful orders of public authorities, or had it carried out its obligations under the Contract Documents generally, and Section 9.1.1 of this Agreement in particular, should reasonably have known it to be contrary to applicable laws, statutes, ordinances, codes, rules and regulations, or lawful orders of public authorities, the Contractor shall assume appropriate responsibility for such Work and shall bear the costs attributable to correction.

§ 9.7 Allowances

The Contractor shall include in the Contract Sum all allowances stated in the Contract Documents. The Owner shall select materials and equipment under allowances with reasonable promptness. Allowance amounts shall include the costs to the Contractor of materials and equipment delivered at the site and all required taxes, less applicable trade discounts. Contractor's costs for unloading and handling at the site, labor, installation, overhead, profit, and other expenses contemplated for stated allowance amounts shall be included in the Contract Sum but not in the allowance.

§ 9.8 Contractor's Construction Schedules

§ 9.8.1 The Contractor, promptly after being awarded the Contract, shall submit for the Owner's and Architect's information a Contractor's construction schedule for the Work. The schedule shall not exceed time limits current

Init.

under the Contract Documents, shall be revised at appropriate intervals as required by the conditions of the Work and Project, shall be related to the entire Project to the extent required by the Contract Documents, and shall provide for expeditious and practicable execution of the Work.

§ 9.8.2 The Contractor shall perform the Work in general accordance with the most recent schedule submitted to the Owner and Architect.

§ 9.9 Submittals

§ 9.9.1 The Contractor shall review for compliance with the Contract Documents and submit to the Architect Shop Drawings, Product Data, Samples, and similar submittals required by the Contract Documents in coordination with the Contractor's construction schedule and in such sequence as to allow the Architect reasonable time for review. By submitting Shop Drawings, Product Data, Samples, and similar submittals, the Contractor represents to the Owner and Architect that the Contractor has (1) reviewed and approved them; (2) determined and verified materials, field measurements, and field construction criteria related thereto, or will do so; and (3) checked and coordinated the information contained within such submittals with the requirements of the Work and of the Contract Documents. The Work shall be in accordance with approved submittals.

§ 9.9.2 Shop Drawings, Product Data, Samples and similar submittals are not Contract Documents.

§ 9.9.3 The Contractor shall not be required to provide professional services that constitute the practice of architecture or engineering unless such services are specifically required by the Contract Documents or unless the Contractor needs to provide such services in order to carry out the Contractor's own responsibilities. If professional design services or certifications by a design professional are specifically required, the Owner and the Architect will specify the performance and design criteria that such services must satisfy. The Contractor shall cause such services or certifications to be provided by an appropriately licensed design professional. If no criteria are specified, the design shall comply with applicable codes and ordinances. Each Party shall be entitled to rely upon the information provided by the other Party. The Architect will review and approve or take other appropriate action on submittals for the limited purpose of checking for conformance with information provided and the design concept expressed in the Contract Documents. The Architect's review of Shop Drawings, Product Data, Samples, and similar submittals shall be for the limited purpose of checking for conformance with information given and the design concept expressed in the Contract Documents. In performing such review, the Architect will approve, or take other appropriate action upon, the Contractor's Shop Drawings, Product Data, Samples, and similar submittals.

§ 9.10 Use of Site

The Contractor shall confine operations at the site to areas permitted by applicable laws, statutes, ordinances, codes, rules and regulations, lawful orders of public authorities, the Contract Documents and as otherwise directed by Owner and shall not unreasonably encumber the site with materials or equipment.

§ 9.10.1 Parking & Traffic.

.1 Parking of construction vehicles on the site by the Contractor shall not inhibit construction nor prevent access for emergency or other official vehicles. Parking of private vehicles on the site by the Contractor is prohibited unless said vehicle is necessary in the execution of the Contract. No construction vehicles shall be parked near or under any existing vegetation on the site.

.2 Construction traffic and staging shall be permitted only within construction limits as indicated on plan. Contractor is responsible for repair of any areas disturbed outside of this area, including grading and sodding. No staging will be permitted on existing asphalt without Owner's prior written consent. The cost to repair any damage to existing asphalt will be back-charged to the Contractor.

§ 9.10.2 Fencing. Contractor will be responsible for erecting and maintaining construction fencing around the limits of the Project site at all times of construction in accordance with applicable law and the Contract Documents. Failure to erect or maintain this fencing will result in the correction of the problem by the Owner at the expense of the Contractor, and may include, but are not limited to, the cost of any materials and staff time. This fence must be installed and fully erected before construction operations beginning and tied-up at the end of each working day.

§ 9.10.3 Water Removal. If, during construction, standing water caused by heavy rains or poor drainage becomes a hazard in the proper execution of the Contract, it shall be the responsibility of the Contractor to provide and make payment for removal of said water to existing drainage swales, storm sewers or other natural or man-made drainage ways.

§ 9.11 Cutting and Patching

The Contractor shall be responsible for cutting, fitting, or patching required to complete the Work or to make its parts fit together properly.

§ 9.12 Cleaning Up

The Contractor shall keep the premises and surrounding area free from accumulation of waste materials and rubbish caused by operations under the Contract. At completion of the Work, the Contractor shall remove, and properly and lawfully dispose of as applicable, waste materials, rubbish, the Contractor's tools, construction equipment, machinery, and surplus material from and about the Project. The Contractor shall clean up and keep all streets, sidewalks and other public ways used for access to the Project site free from accumulation of spillage of fill or soils or other materials caused by operations under the Contract. The Contractor shall strictly comply with all laws and regulations pertaining to same be solely responsible for, and shall pay any fines or penalties assessed as the result of, any violation.

§ 9.13 Access to Work

The Contractor shall provide the Owner and Architect with access to the Work in preparation and progress wherever located.

§ 9.14 Royalties, Patents and Copyrights

The Contractor shall pay all royalties and license fees. The Contractor shall defend suits or claims for infringement of copyrights and patent rights and shall hold the Owner and Architect harmless from loss on account thereof, but shall not be responsible for defense or loss when a particular design, process, or product of a particular manufacturer or manufacturers is required by the Contract Documents or where the copyright violations are contained in Drawings, Specifications or other documents prepared by the Owner or Architect. However, if an infringement of a copyright or patent is discovered by, or made known to, the Contractor, the Contractor shall be responsible for the loss unless the information is promptly furnished to the Architect.

§ 9.15 Indemnification

§ 9.15.1 To the fullest extent permitted by law, the Contractor waives any rights of contribution against, and shall indemnify and hold harmless the Owner and its officers, officials, employees, volunteers and agents from and against all claims, damages, losses and expenses including but not limited to legal fees (attorney's and paralegals' fees and court costs), arising out of or resulting from the performance of the Contractor's work, provided that any such claim, damage, loss or expense (i) is attributable to bodily injury, sickness, disease or death, or injury to or destruction of tangible property, other than the work itself, including the loss of use resulting there from and (ii) is caused in whole or in part by any wrongful or negligent act or omission of the Contractor, any Subcontractor, anyone directly or indirectly employed by any of them or anyone for whose acts any of them may be liable, regardless of whether or not it is caused in part by a party indemnified hereunder. Such obligation shall not be construed to negate, abridge, or otherwise reduce any other right or obligation of indemnity which would otherwise exist as to any party or person described in this Paragraph. Contractor shall similarly protect, indemnify and hold and save harmless the Owner, its officers, officials, employees, volunteers and agents against and from any and all claims, costs, causes, actions and expenses including but not limited to legal fees, incurred by reason of Contractor's breach of any of its obligations under, or Contractor's default of, any provision of the Contract.

"Claims," "damages," "losses" and "expenses" as these words are used in this Agreement shall be construed to include, but not limited to (1) injury or damage consequent upon the failure of or use or misuse by Contractor, its subcontractors, agents, servants or employees, of any hoist, rigging, blocking, scaffolding, or any and all other kinds of items of equipment or other mechanical or structural contrivance erected or constructed by any person, or any or all other kinds of equipment whether or not the same be owned, furnished or loaned by Owner; (2) all attorneys' fees and costs incurred in bringing an action to enforce the provisions of this indemnity or any other indemnity contained herein; (3) all costs and expenses incurred by the indemnified party; and (4) error or omission or defect in any submission made to Architect / Architect for its approval or review.

Init.

§ 9.15.2 In claims against any person or entity indemnified under this Section 9.15 by an employee of the Contractor, a Subcontractor, anyone directly or indirectly employed by them, or anyone for whose acts they may be liable, the indemnification obligation under Section 9.15.1 shall not be limited by a limitation on amount or type of damages, compensation or benefits payable by or for the Contractor or Subcontractor under workers' compensation acts, disability benefit acts or other employee benefit acts.

ARTICLE 10 ARCHITECT

§ 10.1 The Architect will provide administration of the Contract as described in the Contract Documents and will be an Owner's representative during construction, until the date the Architect issues the final Certificate for Payment. The Architect will have authority to act on behalf of the Owner only to the extent provided in the Contract Documents, unless otherwise modified in writing in accordance with other provisions of the Contract.

§ 10.2 Duties, responsibilities, and limitations of authority of the Architect as set forth in the Contract Documents shall not be restricted, modified, or extended without written consent of the Owner and Architect. Consent shall not be unreasonably withheld.

§ 10.3 The Architect will visit the site at intervals appropriate to the stage of the construction to become generally familiar with the progress and quality of the portion of the Work completed, and to determine in general, if the Work observed is being performed in a manner indicating that the Work, when fully completed, will be in accordance with the Contract Documents. However, the Architect will not be required to make exhaustive or continuous on-site inspections to check the quality or quantity of the Work. The Architect will not have control over, charge of, or responsibility for the construction means, methods, techniques, sequences, or procedures, or for safety precautions and programs in connection with the Work, since these are solely the Contractor's rights and responsibilities under the Contract Documents.

§ 10.4 On the basis of the site visits, the Architect will keep the Owner reasonably informed about the progress and quality of the portion of the Work completed, and promptly report to the Owner (1) known deviations from the Contract Documents, (2) known deviations from the most recent construction schedule submitted by the Contractor, and (3) defects and deficiencies observed in the Work. The Architect will not be responsible for the Contractor's failure to perform the Work in accordance with the requirements of the Contract Documents. The Architect will not have control over or charge of and will not be responsible for acts or omissions of the Contractor, Subcontractors, or their agents or employees, or any other persons or entities performing portions of the Work.

§ 10.5 Based on the Architect's evaluations of the quality and progress of the Work and of the Contractor's Applications for Payment, the Architect will review and certify the amounts due the Contractor and will issue Certificates for Payment in such amounts.

§ 10.6 The Architect has authority to reject Work that does not conform to the Contract Documents and to require inspection or testing of the Work.

§ 10.7 The Architect will review and approve or take other appropriate action upon, the Contractor's submittals such as Shop Drawings, Product Data, and Samples, but only for the limited purpose of checking for conformance with information given and the design concept expressed in the Contract Documents.

§ 10.8 The Architect will interpret and decide matters concerning performance under, and requirements of, the Contract Documents on written request of either the Owner or Contractor. The Architect will make initial decisions on all claims, disputes, and other matters in question between the Owner and Contractor but will not be liable for results of any interpretations or decisions rendered in good faith.

§ 10.9 The Architect's decisions on matters relating to aesthetic effect will be final if consistent with the intent expressed in the Contract Documents.

ARTICLE 11 SUBCONTRACTORS

§ 11.1 A Subcontractor is a person or entity who has a direct contract with the Contractor to perform a portion of the Work at the site.

§ 11.2 Unless otherwise stated in the Contract Documents, the Contractor, as soon as practicable after award of the Contract, shall notify the Owner and Architect in writing of the name, trade and subcontract amount of each Subcontractor and supplier proposed for each of the principal portions of the Work. The Contractor shall not contract with any Subcontractor or supplier to whom the Owner or Architect has made reasonable written objection within ten days after receipt of the Contractor's written list of Subcontractors and suppliers. If the proposed but rejected Subcontractor was reasonably capable of performing the Work, the Contract Sum and Contract Time shall be increased or decreased by the difference, if any, occasioned by such change, and an appropriate Change Order shall be issued before commencement of the substitute Subcontractor's Work. The Contractor shall not be required to contract with anyone to whom the Contractor has made reasonable objection.

§ 11.3 Contracts between the Contractor and Subcontractors shall (1) require each Subcontractor, to the extent of the Work to be performed by the Subcontractor, to be bound to the Contractor by the terms of the Contract Documents, and to assume toward the Contractor all the obligations and responsibilities, including the responsibility for safety of the Subcontractor's Work, which the Contractor, by the Contract Documents, assumes toward the Owner and Architect, and (2) allow the Subcontractor the benefit of all rights, remedies and redress against the Contractor that the Contractor, by these Contract Documents, has against the Owner.

§ 11.4 All subcontracts shall be in writing and shall specifically provide that the Owner is an intended third-party beneficiary of such subcontract and that the Owner shall have the right to enforce the Subcontractor's obligations thereunder after the occurrence of a default under the Contract by the contractor. Each subcontract agreement shall preserve and protect the rights of the Owner and Architect under the Contract Documents with respect to the Work to be performed by the Subcontractor so that subcontracting thereof will not prejudice such rights, and shall allow to the Subcontractor, unless specifically provided otherwise in the subcontract agreement, the benefit of all rights, remedies and redress against the Contractor that the Contractor, by these Contract Documents, has against the Owner. Where appropriate, the Contractor shall require each Subcontractor to enter into similar written agreements with Sub-subcontractors. The Contractor shall make available to each proposed Subcontractor, prior to the execution of the subcontract agreement, copies of the Contract Documents to which the Subcontractor will be bound, and upon written request of the Subcontractor, identify to the Subcontractor terms and conditions of the proposed subcontract agreement which may be at variance with the Contract Documents. Subcontractors shall similarly make copies of applicable portions of such documents available to their representatives proposed Sub-subcontractors.

§ 11.5 All subcontract agreements shall conform to the requirements of the Contract Documents and the Contractor hereby irrevocably assigns to the Owner and Owner's permitted assigns all its interest in any subcontract agreements and purchase orders now existing or hereinafter entered into the contractor for performance of any part of the Work, which assignment will be effective in the event of the Contractor's failure to perform the Work in accordance with the Contract Documents and upon acceptance by the Owner in writing and only as to those subcontract agreements and purchase orders that Owner designates in said writing. It is agreed and understood that the Owner may accept said assignment at any time during the course of construction prior to Final Completion. The Contractor shall promptly submit to the Owner a true and complete copy of each subcontract upon execution of same. Each subcontract shall contain a contingent assignment of the subcontract to the Owner, consistent with this Subparagraph. Upon acceptance by the Owner of a subcontract; (1) the Contractor shall promptly furnish to the Owner true and complete copies of the designated subcontract agreements and purchase orders, both as may have been amended by approved change order together with copies of any and all such amendments, and (2) the Owner shall only be required to compensate the designated Subcontractor(s) or supplier(s) for compensation accruing to such party(ies) for Work done or materials delivered from and after the date on which the Owner accepts the subcontract agreement(s) or purchase order(s). All sums due and owing by the Contractor to the designated Subcontractor(s) or supplier(s) for work performed or material supplied prior to the Owner's acceptance of the subcontract agreement(s) or purchase order(s) shall constitute a debt between such parties and the Contractor. It is further agreed that no subcontract agreement or purchase order shall contain any restriction that would prohibit assignment under the terms and conditions stated hereinabove. It is further agreed and understood that such assignment is part of the consideration to Owner for entering into the Contract with the Contractor and may not be withdrawn prior to Final Completion.

ARTICLE 12 CONSTRUCTION BY OWNER OR BY SEPARATE CONTRACTORS

§ 12.1 The term "Separate Contractor(s)" shall mean other contractors retained by the Owner under separate agreements. The Owner reserves the right to perform construction or operations related to the Project with the Owner's own forces, and with Separate Contractors retained under Conditions of the Contract substantially similar to

Init.

those of this Contract, including those provisions of the Conditions of the Contract related to insurance and waiver of subrogation.

§ 12.2 The Contractor shall afford the Owner and Separate Contractors reasonable opportunity for introduction and storage of their materials and equipment and performance of their activities, and shall connect and coordinate the Contractor's activities with theirs as required by the Contract Documents.

§ 12.3 The Owner shall be reimbursed by the Contractor for costs incurred by the Owner which are payable to a Separate Contractor because of delays, improperly timed activities, or defective construction of the Contractor. The Owner shall be responsible to the Contractor for costs incurred by the Contractor because of delays, improperly timed activities, damage to the Work, or defective construction of a Separate Contractor.

ARTICLE 13 CHANGES IN THE WORK

§ 13.1 By appropriate Modification, changes in the Work may be accomplished after execution of the Contract. The Owner, without invalidating the Contract, may order changes in the Work within the general scope of the Contract consisting of additions, deletions, or other revisions, with the Contract Sum and Contract Time being adjusted accordingly. Such changes in the Work shall be authorized by written Change Order signed by the Owner, Contractor, and Architect, or by written Construction Change Directive signed by the Owner and Architect. Upon issuance of the Change Order or Construction Change Directive, the Contractor shall proceed promptly with such changes in the Work, unless otherwise provided in the Change Order or Construction Change Directive.

§ 13.2 Adjustments in the Contract Sum and Contract Time resulting from a change in the Work shall be determined by mutual agreement of the parties or, in the case of a Construction Change Directive signed only by the Owner and Architect, by the Contractor's cost of labor, material, equipment, and reasonable overhead and profit, unless the parties agree on another method for determining the cost or credit. Pending final determination of the total cost of a Construction Change Directive, the Contractor may request payment for Work completed pursuant to the Construction Change Directive. The Architect will make an interim determination of the amount of payment due for purposes of certifying the Contractor's monthly Application for Payment. When the Owner and Contractor agree on adjustments to the Contract Sum and Contract Time arising from a Construction Change Directive, the Architect will prepare a Change Order.

§ 13.3 The Architect will have authority to order minor changes in the Work not involving adjustment in the Contract Sum or extension of the Contract Time and not inconsistent with the intent of the Contract Documents. Such changes shall be effected by written order and shall be binding on the Owner and Contractor. The Contractor shall carry out such written orders promptly. If the Contractor believes that the proposed minor change in the Work will affect the Contract Sum or Contract Time, the Contractor shall notify the Architect and shall not proceed to implement the change in the Work.

§ 13.4 If concealed or unknown physical conditions are encountered at the site that differ materially from those indicated in the Contract Documents or from those conditions ordinarily found to exist, and the Contractor could not have discovered same in the exercise of reasonable diligence as required under Subsection 9.1.1 of this Agreement, the Contract Sum and Contract Time shall be equitably adjusted as mutually agreed between the Owner and Contractor; provided that the Contractor provides notice to the Owner and Architect promptly and before conditions are disturbed.

§ 13.5 Agreement on any Change Order shall constitute a final settlement, and accord and satisfaction between the Owner and Contractor, of all matters relating to the change in the Work which is the subject of the Change Order, including, but not limited to, all direct and indirect costs associated with such change and any and all adjustments to the Contract Sum, Contract Time and Construction Schedule. In the event a Change Order increases the Contract Sum, the Contractor shall include the Work covered by such Change Order in Applications for Payment as if such Work were originally part of the Contract Documents.

§ 13.6 No change in the Work, whether by way of alteration or addition to the Work, shall be the bases of an addition to the Contract Sum or change in the Contract Time unless and until such alteration or addition has been authorized by a Change Order executed and issued in accordance with and in strict compliance with the requirements of the Contract Documents and applicable law. Accordingly, no course of conduct or dealing between the parties, nor any express or implied acceptance of alterations or additions to the Work and no claim that the Owner has been unjustly enriched shall be the basis of any claim to an increase in the Contract Sum or change in the Contract Time.

ARTICLE 14 TIME

§ 14.1 Time limits stated in the Contract Documents are of the essence of the Contract. By executing this Agreement the Contractor confirms that the Contract Time is a reasonable period for performing the Work.

§ 14.2 Unless otherwise provided, Contract Time is the period of time, including authorized adjustments, allotted in the Contract Documents for Substantial Completion and for Final Completion of the Work.

§ 14.3 The term "day" as used in the Contract Documents shall mean calendar day unless otherwise specifically defined.

§ 14.4 The date of Substantial Completion and Final Completion are the dates certified by the Architect in accordance with Section 15.6.3.

§ 14.5 If the Contractor is delayed at any time in the commencement or progress of the Work by (1) changes ordered in the Work; (2) by labor disputes, fire, unusual delay in deliveries, abnormal adverse weather conditions not reasonably anticipatable, unavoidable casualties, or any causes beyond the Contractor's control; or (3) by other causes that the Contractor asserts, and the Architect determines and Owner agrees, justify delay, then, as the Contractor's sole remedy, the Contract Time shall be extended for such reasonable time as the Architect may determine. Notwithstanding the foregoing, delays of the Contractor to carry out its obligations under or in accordance with the provisions of the Contract, shall not extend the Contract Time.

§ 14.6 The Contractor shall carry the Work forward regularly, diligently, uninterruptedly and expeditiously and in a good workmanlike and professional manner at such a rate of progress and with an adequate work force as will insure the completion of the Work in accordance with the Contract Documents by the date established in the Contract. It is expressly understood and agreed by and between Contractor and Owner that the time for completion of the Work is a reasonable time, taking into consideration the average climatic range, usual industrial conditions, and all other conditions and actors prevailing in this locality.

ARTICLE 15 PAYMENTS AND COMPLETION

§ 15.1 Schedule of Values

§ 15.1.1 Where the Contract is based on a Stipulated Sum or the Cost of the Work with a Guaranteed Maximum Price pursuant to Section 3.2 or 3.4, the Contractor shall submit a schedule of values to the Architect before the first Application for Payment, allocating the entire Stipulated Sum or Guaranteed Maximum Price to the various portions of the Work. The schedule of values shall be prepared in the form, and supported by the data to substantiate its accuracy required by the Architect. This schedule of values shall be used as a basis for reviewing the Contractor's Applications for Payment.

§ 15.1.2 The allocation of the Stipulated Sum or Guaranteed Maximum Price under this Section 15.1 shall not constitute a separate stipulated sum or guaranteed maximum price for each individual line item in the schedule of values.

§ 15.2 Control Estimate

§ 15.2.1 Where the Contract Sum is the Cost of the Work, plus the Contractor's Fee without a Guaranteed Maximum Price pursuant to Section 3.3, the Contractor shall prepare and submit to the Owner a Control Estimate within 14 days of executing this Agreement. The Control Estimate shall include the estimated Cost of the Work plus the Contractor's Fee.

§ 15.2.2 The Control Estimate shall include:

- .1 the documents enumerated in Article 6, including all Modifications thereto;
- .2 a list of the assumptions made by the Contractor in the preparation of the Control Estimate to supplement the information provided by the Owner and contained in the Contract Documents;
- .3 a statement of the estimated Cost of the Work organized by trade categories or systems and the Contractor's Fee;
- .4 a project schedule upon which the Control Estimate is based, indicating proposed Subcontractors, activity sequences and durations, milestone dates for receipt and approval of pertinent information,

Init.

- schedule of shop drawings and samples, procurement and delivery of materials or equipment the Owner's occupancy requirements, and the date of Substantial Completion; and
- .5 a list of any contingency amounts included in the Control Estimate for further development of design and construction.

§ 15.2.3 When the Control Estimate is acceptable to the Owner and Architect, the Owner shall acknowledge it in writing. The Owner's acceptance of the Control Estimate does not imply that the Control Estimate constitutes a Guaranteed Maximum Price.

§ 15.2.4 The Contractor shall develop and implement a detailed system of cost control that will provide the Owner and Architect with timely information as to the anticipated total Cost of the Work. The cost control system shall compare the Control Estimate with the actual cost for activities in progress and estimates for uncompleted tasks and proposed changes. This information shall be reported to the Owner, in writing, no later than the Contractor's first Application for Payment and shall be revised and submitted with each Application for Payment.

§ 15.2.5 The Owner shall authorize preparation of revisions to the Contract Documents that incorporate the agreed-upon assumptions contained in the Control Estimate. The Owner shall promptly furnish such revised Contract Documents to the Contractor. The Contractor shall notify the Owner and Architect of any inconsistencies between the Control Estimate and the revised Contract Documents.

§ 15.3 Applications for Payment

§ 15.3.1 At least ten days before the date established for each progress payment, the Contractor shall submit to the Architect an itemized Application for Payment prepared in accordance with the schedule of values, if required under Section 15.1, for completed portions of the Work. The application shall be notarized, if required; be supported by all data substantiating the Contractor's right to payment that the Owner or Architect require; shall reflect retainage if provided for in the Contract Documents; and include any revised cost control information required by Section 15.2.4. Applications for Payment shall not include requests for payment for portions of the Work for which the Contractor does not intend to pay a Subcontractor or supplier, unless such Work has been performed by others whom the Contractor intends to pay.

§ 15.3.2 With each Application for Payment where the Contract Sum is based upon the Cost of the Work, or the Cost of the Work with a Guaranteed Maximum Price, the Contractor shall submit payrolls, petty cash accounts, receipted invoices or invoices with check vouchers attached, and any other evidence required by the Owner to demonstrate that cash disbursements already made by the Contractor on account of the Cost of the Work equal or exceed progress payments already received by the Contractor plus payrolls for the period covered by the present Application for Payment, less that portion of the progress payments attributable to the Contractor's Fee.

§ 15.3.3 Unless approved in advance by the Owner in writing, payments shall be made on account of materials and equipment incorporated in the Work. If approved in advance by the Owner payment shall be made on account of materials and equipment delivered and suitably stored and protected from damage and loss at the site for subsequent incorporation in the Work. If approved in advance by the Owner, payment may similarly be made for materials and equipment delivered and suitably stored, and protected from damage and loss, off the site at a location agreed upon in writing. The Owner may condition such approvals on such terms as the Owner in its discretion deems necessary for its protection.

§ 15.3.4 The Contractor warrants that title to all Work covered by an Application for Payment will pass to the Owner no later than the time of payment. The Contractor further warrants that upon submittal of an Application for Payment all Work for which Certificates for Payment have been previously issued and payments received from the Owner shall, to the best of the Contractor's knowledge, information and belief, be free and clear of liens, claims, security interests or other encumbrances adverse to the Owner's interests.

§ 15.3.5 Failure to supply waivers of lien or acceptable evidence of payment of all current accounts incurred by this Contract work will be considered grounds for withholding final payment.

§ 15.3.6 The first payment application shall be accompanied by the Contractor's Partial Waiver of Lien only, for the full amount of the payment. Each subsequent monthly payment application shall be accompanied by the Contractor Partial Waiver, and by the Partial lien Waivers of Subcontractor and Suppliers who were included in the immediately

Init.

preceding payment application to the extent of that payment. Application for Final Payment shall be accompanied by Final Waivers of Lien from the Contractor, Subcontractors and Suppliers who have not previously furnished such Final Waivers. Final Waivers shall be for the full amount of the Contract. All applications for payment shall be accompanied by affidavits, in triplicate, from the Contractor and Subcontractors containing such information and in such form as to comply with the Illinois Mechanics Lien Act (770 ILCS 60/0.01 *et seq.*) and showing in detail the sources of all labor and materials used and contracted to be used on the Project, including names and addresses of subcontractors and material suppliers; amounts paid and remaining to be paid to each; together with all documents as shall be necessary, in the sole judgment of the Architect and Owner, to waive all claims of liens to date and comply with all applicable state and local laws.

- (i) All waivers (partial and final) shall include language as applicable indicating either that:
 - a. all material were taken from fully paid stock and delivered to job site in our own vehicles and all labor has been fully paid in accordance with prevailing wage laws; or
 - b. materials were provided by the following suppliers for whom waivers of lien are attached and all labor has been fully paid in accordance with prevailing wage laws.

§ 15.4 Certificates for Payment

§ 15.4.1 The Architect will, within seven days after receipt of the Contractor's Application for Payment, either issue to the Owner a Certificate for Payment, with a copy to the Contractor, for such amount as the Architect determines is properly due, or notify the Contractor and Owner of the Architect's reasons for withholding certification in whole or in part as provided in Section 15.4.3.

§ 15.4.2 The issuance of a Certificate for Payment will constitute a representation by the Architect to the Owner, but not to Contractor, based on the Architect's evaluations of the Work and the data in the Application for Payment, that, to the best of the Architect's knowledge, information, and belief, the Work has progressed to the point indicated, the quality of the Work is in accordance with the Contract Documents, and the Contractor is entitled to payment in the amount certified. The foregoing representations are subject to an evaluation of the Work for conformance with the Contract Documents upon Substantial Completion, to results of subsequent tests and inspections, to correction of minor deviations from the Contract Documents prior to completion and to specific qualifications expressed by the Architect. The issuance of a Certificate for Payment will further constitute a representation to the Owner but not to the Contractor that the Contractor is entitled to payment in the amount certified. However, the issuance of a Certificate for Payment will not be a representation that the Architect has (1) made exhaustive or continuous on-site inspections to check the quality or quantity of the Work; (2) reviewed construction means, methods, techniques, sequences, or procedures; (3) reviewed copies of requisitions received from Subcontractors and suppliers and other data requested by the Owner to substantiate the Contractor's right to payment; or (4) made examination to ascertain how or for what purpose the Contractor has used money previously paid on account of the Contract Sum.

§ 15.4.3 The Architect may withhold a Certificate for Payment in whole or in part, to the extent reasonably necessary to protect the Owner, if in the Architect's opinion the representations to the Owner required by Section 15.4.2 cannot be made. If the Architect is unable to certify payment in the amount of the Application, the Architect will notify the Contractor and Owner as provided in Section 15.4.1. If the Contractor and the Architect cannot agree on a revised amount, the Architect will promptly issue a Certificate for Payment for the amount for which the Architect is able to make such representations to the Owner. The Architect may also withhold a Certificate for Payment or, because of subsequently discovered evidence, may nullify the whole or a part of a Certificate for Payment previously issued, to such extent as may be necessary in the Architect's opinion to protect the Owner from loss for which the Contractor is responsible, including loss resulting from acts and omissions described in Section 9.2.2, because of

- .1 defective Work not remedied;
- .2 third-party claims filed or reasonable evidence indicating probable filing of such claims unless security acceptable to the Owner is provided by the Contractor;
- .3 failure of the Contractor to make payments properly to Subcontractors or suppliers for labor, materials or equipment;
- .4 reasonable evidence that the Work cannot be completed for the unpaid balance of the Contract Sum;
- .5 damage to the Owner or a Separate Contractor;

Init.

- .6 reasonable evidence that the Work will not be completed within the Contract Time and that the unpaid balance would not be adequate to cover actual or liquidated damages for the anticipated delay; or
- .7 failure to carry out the Work in accordance with the Contract Documents.

§ 15.4.4 When the above reasons for withholding certification are removed, certification will be made for amounts previously withheld. No interest will be paid on amounts withheld.

§ 15.5 Progress Payments

§ 15.5.1 The Contractor shall pay each Subcontractor, no later than seven days after receipt of payment from the Owner, the amount to which the Subcontractor is entitled, reflecting percentages actually retained from payments to the Contractor on account of the Subcontractor's portion of the Work. The Contractor shall, by appropriate agreement with each Subcontractor, require each Subcontractor to make payments to sub-subcontractors in a similar manner. This provision is not to be construed as a "conditional payment" or "pay when paid" clause. In the event that payment to the Contractor is delayed without fault of the Subcontractor, payment to the Subcontractor shall be made within a reasonable time after work is properly performed by a Subcontractor irrespective of any delay in payment to the Contractor.

§ 15.5.2 Neither the Owner nor Architect shall have an obligation to pay or see to the payment of money to a Subcontractor or supplier except as may otherwise be required by law.

§ 15.5.3 A Certificate for Payment, a progress payment, or partial or entire use or occupancy of the Project by the Owner shall not constitute acceptance of Work not in accordance with the Contract Documents.

§ 15.5.4 Contractor shall defend and indemnify the Owner from all loss, liability, damage or expense, including reasonable attorney's fees and litigation expenses, arising out of any lien claim or other claim for payment by any Subcontractor or supplier of any tier. Upon receipt of notice of a lien claim or other claim for payment, the Owner shall notify the Contractor. If approved by the applicable court, when required, the Contractor may substitute a surety bond for the property against which the lien or other claim for payment has been asserted.

§ 15.5.5 Anything to the contrary contained or implied herein notwithstanding, no progress payment need be made by Owner until such time as Contractor, Subcontractors or any other persons performing the Work or furnishing materials or equipment for the Project furnishes such documents as Owner may reasonably require (including without limitation sworn notarized contractor's statement, affidavits and waivers of lien).

§ 15.6 Substantial Completion

§ 15.6.1 Substantial Completion is the stage in the progress of the Work when the Work or designated portion thereof is completed in accordance with the Contract Documents so that the Owner can occupy or utilize the Work for its intended use and has been accepted by Owner to receive all required occupancy permits.

"Punch List" mean and shall be limited to uncompleted items of Work (a) that do not interfere with the use and occupancy of any area of the Site for its intended purpose and (b) that, as a group, are capable of being completed by the Contractor within thirty (30) days of issuance of any Punch List. The "Punch List" is the list containing the Punch List Items.

§ 15.6.2 When the Contractor considers that the Work, or a portion thereof which the Owner agrees to accept separately, is substantially complete, the Contractor shall prepare and submit to the Architect a comprehensive list of items to be completed or corrected prior to final payment. Failure to include an item on such list does not alter the responsibility of the Contractor to complete all Work in accordance with the Contract Documents.

§ 15.6.3 Upon receipt of the Contractor's list, the Architect and Owner will make an inspection to determine whether the Work or designated portion thereof is substantially complete. If the Architect's or Owner's inspection discloses an item, whether or not included in the Contractor's list, which is not in accordance with the Contract Documents and is necessary for Owner's occupancy or utilization of the Work, the Contractor shall before issuance of a Certificate of Substantial Completion, complete such items upon notification from the Architect and Owner. The cost of this and any additional inspections required to establish Substantial Completion due to the failure of the Contractor to properly complete all items of the Work necessary for the Owner's use or occupancy of the Work shall be charged to the Contractor. When the Architect determines that the Work or designated portion thereof is substantially complete, the

Architect will issue a Certificate of Substantial Completion to the Owner for review and concurrence by the Owner which shall establish the date of Substantial Completion; establish responsibilities of the Owner and Contractor for security, maintenance, heat, utilities, damage to the Work and insurance; and fix the time within which the Contractor shall finish all items on the Punch List accompanying the Certificate. Warranties required by the Contract Documents shall commence on the date of Final Completion of the Work or designated portion thereof with the exception of the items of Work contained in the Punch List accompanying the Certificate of Substantial Completion. With respect to Work enumerated on the Punch List, the guarantee or warranty period shall commence upon Contractor's completion and Owner's approval of the Punch List items.

§ 15.6.4 The Certificate of Substantial Completion shall be submitted to the Owner and Contractor for their written acceptance of responsibilities assigned to them in the Certificate.

§ 15.7 Final Completion and Final Payment

§ 15.7.1 Upon receipt of the Contractor's notice that the Work is ready for final inspection and acceptance and upon receipt of a final Application for Payment, the Architect will promptly make such inspection and, when the Architect finds the Work acceptable under the Contract Documents and the Contract fully performed, and the Architect has advised Owner of that finding and Owner has not advised Architect of any objection to such finding, the Architect will promptly issue a final Certificate for Payment to the Owner but not the Contractor stating that to the best of the Architect's knowledge, information and belief, and on the basis of the Architect's on-site visits and inspections, the Work has been completed in accordance with the Contract Documents and that the entire balance found to be due the Contractor and noted in the final Certificate is due and payable. The Architect's final Certificate for Payment will constitute a further representation that conditions stated in Section 15.7.2 as precedent to the Contractor's being entitled to final payment have been fulfilled. The Owner's failure to object to, and the Owner's acceptance of, the Architect's findings and/or certifications hereunder shall not constitute Owner's acceptance of Work not complying with the Contract Documents, or Owner's waiver of any claims or remedies it may have with respect to any such defective or delayed Work.

§ 15.7.2 Final payment shall not become due until the Contractor has fully performed the contract, including but not limited to, delivery of all manufacturer's and supplier's warranties, operating manuals, as-built drawings, and consent of the surety to final payment, pursuant to the Contract Documents, and has delivered to the Owner a complete release of all liens arising out of this Contract or receipts in full covering all labor, materials and equipment for which a lien could be filed, or a bond satisfactory to the Owner to indemnify the Owner against such lien. If such lien remains unsatisfied after payments are made, the Contractor shall refund to the Owner all money that the Owner may be compelled to pay in discharging such lien, including costs and reasonable attorneys' fees.

§ 15.7.3 The making of final payment shall constitute a waiver of claims by the Owner except those arising from

- .1 liens, claims, security interests or encumbrances arising out of the Contract and unsettled;
- .2 failure of the Work to comply with the requirements of the Contract Documents;
- .3 terms of special warranties required by the Contract Documents; or
- .4 audits performed by the Owner, if permitted by the Contract Documents, after final payment.

The final payment by Owner shall not relieve the Contractor of the responsibility for the correction of any and all defects in the work performed. Contractor shall correct all defects as notified for the applicable warranty period after final payment.

§ 15.7.4 Acceptance of final payment by the Contractor, a Subcontractor or supplier shall constitute a waiver of claims by that payee except those previously made in writing and identified by that payee as unsettled at the time of the final Application for Payment.

ARTICLE 16 PROTECTION OF PERSONS AND PROPERTY

§ 16.1 Safety Precautions and Programs

The Contractor shall be responsible for initiating, maintaining, and supervising all safety precautions and programs in connection with the performance of the Contract. The Contractor shall take reasonable precautions for safety of, and shall provide reasonable protection to prevent damage, injury, or loss to

- .1 employees on the Work and other persons who may be affected thereby;
- .2 the Work and materials and equipment to be incorporated therein, whether in storage on or off the site, under care, custody, or control of the Contractor, a Subcontractor, or a Sub-subcontractor; and

Init.

AIA Document A104™ – 2017 (formerly A107™ – 2007). Copyright © 1936, 1951, 1958, 1961, 1963, 1966, 1970, 1974, 1978, 1987, 1997, 2007 and 2017 by The American Institute of Architects. All rights reserved. **WARNING: This AIA® Document is protected by U.S. Copyright Law and International Treaties. Unauthorized reproduction or distribution of this AIA® Document, or any portion of it, may result in severe civil and criminal penalties, and will be prosecuted to the maximum extent possible under the law.** This document was produced by AIA software at 15:57:50 ET on 02/20/2020 under Order No.8830539077 which expires on 06/25/2020, and is not for resale.

User Notes:

(1899329843)

- 3 other property at the site or adjacent thereto, such as trees, shrubs, lawns, walks, pavements, roadways, structures and utilities not designated for removal, relocation, or replacement in the course of construction.

The Contractor shall comply with, and give notices required by, applicable laws, statutes, ordinances, codes, rules and regulations, and lawful orders of public authorities bearing on safety of persons and property and their protection from damage, injury, or loss. The Contractor shall promptly remedy damage and loss to property caused in whole or in part by the Contractor, a Subcontractor, a sub-subcontractor, or anyone directly or indirectly employed by any of them, or by anyone for whose acts they may be liable and for which the Contractor is responsible under Sections 16.1.2 and 16.1.3. The Contractor may make a claim for the cost to remedy the damage or loss to the extent such damage or loss is attributable to acts or omissions of the Owner or Architect or by anyone for whose acts either of them may be liable, and not attributable to the fault or negligence of the Contractor. The foregoing obligations of the Contractor are in addition to the Contractor's obligations under Section 9.15.

§ 16.2 Hazardous Materials and Substances

§ 16.2.1 The Contractor is responsible for compliance with the requirements of the Contract Documents regarding hazardous materials or substances. If the Contractor encounters a hazardous material or substance not addressed in the Contract Documents, and if reasonable precautions will be inadequate to prevent foreseeable bodily injury or death to persons resulting from a material or substance, including but not limited to asbestos or polychlorinated biphenyl (PCB), encountered on the site by the Contractor, the Contractor shall, upon recognizing the condition, immediately stop Work in the affected area and notify the Owner and Architect of the condition. When the material or substance has been rendered harmless, Work in the affected area shall resume upon written agreement of the Owner and Contractor. By Change Order, the Contract Time shall be extended appropriately and the Contract Sum shall be increased in the amount of the Contractor's reasonable additional costs of shutdown, delay, and start-up.

§ 16.2.2 To the fullest extent permitted by law, the Owner shall indemnify and hold harmless the Contractor, Subcontractors, Architect, Architect's consultants, and agents and employees of any of them from and against claims, damages, losses, and expenses, including but not limited to attorneys' fees, arising out of or resulting from performance of the Work in the affected area, if in fact, the material or substance presents the risk of bodily injury or death as described in Section 16.2.1 and has not been rendered harmless, provided that such claim, damage, loss, or expense is attributable to bodily injury, sickness, disease or death, or to injury to or destruction of tangible property (other than the Work itself), except to the extent that such damage, loss, or expense is due to the fault or negligence of the party seeking indemnity.

§ 16.2.3 If, without negligence on the part of the Contractor, the Contractor is held liable by a government agency for the cost of remediation of a hazardous material or substance solely by reason of performing Work as required by the Contract Documents, the Owner shall indemnify the Contractor for all cost and expense thereby incurred.

ARTICLE 17 INSURANCE AND BONDS

§ 17.1 Contractor's Insurance

§ 17.1.1 The Contractor shall purchase and maintain insurance of the types and limits of liability, containing the endorsements, and subject to the terms and conditions, as described in this Section 17.1 and in the Contract Documents. The Contractor shall purchase and maintain the insurance required by this Agreement from an insurance company or insurance companies lawfully authorized to issue insurance in the jurisdiction where the Project is located. Contractor shall procure insurance from insurance companies that have obtained A.M. Best ratings no less than A VII using the most recent edition of the A.M. Best's Key Rating Guide. If the Best's rating is less than A VII or a Best's rating is not obtained, the Owner has the right to reject insurance written by an insurer it deems unacceptable. Failure to maintain the required insurance may result in termination of the Contract at Owner's option. Owner shall have the right, but not the obligation, of prohibiting Contractor or any Subcontractor from entering the Project site until such certificates or other evidence that insurance has been placed in complete compliance with these requirements is received and approved by Owner.

The Contractor shall maintain the required insurance until the expiration of the period for correction of Work as set forth in Section 18.4, unless a different duration is stated below:

Contractor shall maintain commercial general liability (CGL) and, if necessary, commercial umbrella liability insurance with a limit of not less than \$2,000,000 each occurrence for at least three years following Substantial

Completion of the Work.

§ 17.1.2 Commercial General Liability insurance for the Project written on an occurrence form with policy limits of not less than Two Million Dollars (\$ 2,000,000) each occurrence, Two Million Dollars (\$ 2,000,000) general aggregate, which shall apply separately to this project, and Two Million Dollars (\$ 2,000,000) each occurrence for products-completed operations hazard for at least three years following Completion of the Work, providing coverage for claims including

- .1 damages because of bodily injury, sickness or disease, including occupational sickness or disease, and death of any person;
- .2 personal and advertising injury;
- .3 damages because of physical damage to or destruction of tangible property, including the loss of use of such property;
- .4 bodily injury or property damage arising out of completed operations; and
- .5 the Contractor's indemnity obligations under Section 9.15.

CGL insurance shall be written on Insurance Services Office (ISO) occurrence form CG 00 01 04 13, or a substitute form providing equivalent coverage, and shall also cover liability arising from premises, operations, independent contractors, and liability assumed under an insured contract (including the tort liability of another assumed in a business contract)

This insurance shall apply as primary insurance with respect to any other insurance or self-insurance afforded to Owner.

There shall be no endorsement or modification of the CGL limiting the scope of coverage for liability arising from pollution, explosion, collapse, or underground property damage.

For Contractor's Continuing Completed Operations Liability Insurance:

Continuing CGL insurance shall be written on ISO occurrence form CG 00 01 4 13, or substitute form providing equivalent coverage, and shall, at minimum, cover liability arising from products-completed operations and liability assumed under an insured contract.

Continuing CGL insurance shall have a products-completed operations aggregate of at least two times its each occurrence limit.

Continuing commercial umbrella coverage, if any, shall include liability coverage for damage to the insured's completed work equivalent to that provided under ISO form CG 00 01.

§ 17.1.3 Automobile Liability covering vehicles owned by the Contractor, hired, and non-owned vehicles used by the Contractor, with policy limits of not less than One Million Dollars (\$ 1,000,000) per accident, for bodily injury, death of any person, and property damage arising out of the ownership, maintenance, and use of those motor vehicles along with any other statutorily required automobile coverage. Business auto insurance shall be written Insurance Services Office (ISO) form CA 00 01, CA 00 05, CA 00 12, CA 00 20, or a substitute form providing equivalent liability coverage. If necessary, the policy shall be endorsed to provide contractual liability coverage equivalent to that provided in the 1990 and later editions of CA 00 01.

§ 17.1.4 The Contractor may achieve the required limits and coverage for Commercial General Liability and Automobile Liability through a combination of primary and excess or umbrella liability insurance, provided such primary and excess or umbrella insurance policies result in the same or greater coverage as those required under Section 17.1.2 and 17.1.3, and in no event shall any excess or umbrella liability insurance provide narrower coverage than the primary policy. The excess policy shall not require the exhaustion of the underlying limits only through the actual payment by the underlying insurers.

§ 17.1.5 Workers' Compensation

Contractor shall maintain workers compensation as required by statute and employers liability insurance. The commercial umbrella and/or employers liability limits shall not be less than \$1,000,000 each accident for bodily injury by accident of \$1,000,000 each employee for bodily injury by disease.

Init.

If Owner has not been included as an insured under the CGL using ISO additional insured endorsement CG 20 10 under the Commercial General and Umbrella Liability Insurance required in this Contract, the Contractor waives all rights against Owner and its officers, officials, employees, volunteers and agents for recovery of damages arising out of or incident to the Contractor's Work.

§ 17.1.6 Employers' Liability with policy limits not less than One Million Dollars (\$ 1,000,000) each accident, One Million Dollars (\$ 1,000,000) each employee, and One Million Dollars (\$ 1,000,000) policy limit.

§ 17.1.7 Intentionally deleted.

§ 17.1.8 Intentionally deleted.

§ 17.1.9 Intentionally deleted.

§ 17.1.10 The Contractor shall provide certificates of insurance acceptable to the Owner evidencing compliance with the requirements in this Section 17.1 at the following times: (1) prior to commencement of the Work; (2) upon renewal or replacement of each required policy of insurance; and (3) within 10 days' upon the Owner's written request. An additional certificate evidencing continuation of liability coverage, including coverage for completed operations, shall be submitted with the final Application for Payment and thereafter upon renewal or replacement of such coverage until the expiration of the period required by Section 17.1.1 or upon Owner's written request for the same. The certificates will show the Owner, its elected and appointed officials, employees, volunteers and agents as an additional insured on the Contractor's Commercial General Liability and excess or umbrella liability policy. Failure of Owner to demand such certificate, endorsement or other evidence of full compliance with these insurance requirements or failure of Owner to identify a deficiency from evidence that is provided shall not be construed as a waiver of Contractor's obligation to maintain such insurance.

§ 17.1.11 The Contractor shall disclose to the Owner any deductible or self-insured retentions applicable to any insurance required to be provided by the Contractor. At the option of the Owner, the Contractor may be asked to eliminate such deductibles or self-insured retentions as respects the Owner, its officers, officials, employees, volunteers and agents or required to procure a bond guaranteeing payment of losses and other related costs including but not limited to investigations, claim administration and defense expenses.

§ 17.1.12 To the fullest extent permitted by law, the Contractor shall cause the commercial liability coverage required by this Section 17.1 to include (1) the Owner, its elected and appointed officials, employees, volunteers and agents for claims caused in whole or in part by the Contractor's negligent acts or omissions during the Contractor's operations; and (2) the Owner as an additional insured for claims caused in whole or in part by the Contractor's negligent acts or omissions for which loss occurs during completed operations. The additional insured coverage shall be primary and non-contributory to any of the Owner's general liability insurance policies and shall apply to both ongoing and completed operations. The additional insured coverage shall be no less than that provided by Insurance Services Office, Inc. (ISO) forms CG 20 10 07 04, CG 20 37 07 04, or a substitute providing equivalent coverage, and under the commercial umbrella, if any. ..

If Contractor's liability policies do not contain the standard ISO separation of insured's' provision, or a substantially similar clause, they shall be endorsed to provide cross-liability coverage.

§ 17.1.13 All certificates shall provide for 30 days' written notice to Owner prior to the cancellation or material change of any insurance referred to therein. Written notice to Owner shall be by certified mail, return receipt requested. Upon receipt of notice from the Contractor, the Owner shall have the right to either stop the Work until the lapse in coverage has been cured by the procurement of replacement coverage by the Contractor or terminate the contract, at Owner's option. In the event Owner does not terminate, the furnishing of notice by the Contractor shall not relieve the Contractor of any contractual obligation to provide any required coverage.

§ 17.1.14 Other Insurance Provided by the Contractor

(List below any other insurance coverage to be provided by the Contractor and any applicable limits.)

Coverage

Limits

Contractor shall cause each Subcontractor employed by Contractor to purchase and maintain insurance of the type specified above. When requested by the Owner, Contractor shall furnish copies of certificates of insurance evidencing

coverage for each Subcontractor.

§ 17.2 Owner's Insurance

§ 17.2.1

(Paragraphs deleted)

Unless otherwise provided, the Owner shall purchase and maintain, in a company or companies lawfully authorized to do business in the jurisdiction in which the Project is located, property insurance in the amount of the initial Contract Sum as well as subsequent modifications thereto for the entire Work at the site on a replacement cost basis without voluntary deductibles. Such property insurance shall be maintained, unless otherwise provided in the Contract Documents or otherwise agreed in writing by all persons and entities who are beneficiaries of such insurance, until final payment has been made as provided in Article 15.7 or until no person or entity other than the Owner has an insurable interest in the property required by this Paragraph 17.2.1 to be covered, whichever is earlier. This insurance shall include the respective interests of the Owner, the Contractor, Subcontractors and Sub-subcontractors in the Work.

§ 17.2.2 Property insurance shall be on a course of construction policy form and shall insure against the perils of fire and extended coverage and physical loss or damage including, without duplication of coverage, theft, vandalism, malicious mischief, collapse, false work, windstorm, testing and start-up, temporary buildings and debris removal, including demolition, and shall cover reasonable compensation for the Architect's, any of the Owner's Consultant's services and expenses required as a result of such insured loss. Coverage for other perils shall not be required unless otherwise provided in the Contract Documents. Property insurance provided by the Owner shall not cover Contractor's, Subcontractor's or Sub-subcontractor's liability or any tools, apparatus, machinery, scaffolding, hoists, forms, staging, shoring or other similar items commonly referred to as construction equipment, which may be on the site and the capital value of which is not included in the Work. The Contractor shall make his own arrangements for any insurance he may require on such construction equipment.

(Paragraphs deleted)

§ 17.2.3 The Contractor shall effect insurance which will protect the interests of the Contractor, Subcontractors and Sub-subcontractors in the Work.

§ 17.2.4 If the property insurance requires minimum deductibles and such deductibles are identified in the Contract Documents, the Contractor shall pay costs not covered because of deductibles. If the Owner or insurer increases the required minimum deductibles above the amounts so identified or if the Owner elects to purchase this insurance with voluntary deductible amounts, the Owner shall be responsible for payment of the additional costs not covered because of such increased or voluntary deductibles. If deductibles are not identified in the Contract Documents, the Owner shall pay costs not covered because of deductibles.

§ 17.2.5 Unless otherwise provided in the Contract Documents, this property insurance shall cover portions of the Work stored off the site and paid for by Owner after written approval of the Owner at the value established in the approval, and also portions of the Work in transit and paid for by Owner.

§ 17.2.6 Partial occupancy or use shall not commence until the insurance company or companies providing property insurance have consented to such partial occupancy or use by endorsement or otherwise. The Owner and the Contractor shall take reasonable steps to obtain consent of the insurance company or companies and shall, without mutual written consent, take no action with respect to partial occupancy or use that would cause cancellation, lapse or reduction of insurance.

§ 17.2.7 The Owner shall purchase and maintain boiler and machinery insurance required by the Contract Documents or by law, which shall specifically cover such insured objects during installation and until final acceptance by the Owner; this insurance shall include interests of the Owner, Contractor Subcontractors and Sub-subcontractors in the Work, and the Owner and the Contractor shall be named insureds.

§ 17.2.8 If the Contractor requests in writing that insurance for risks other than those described herein or other special causes of loss be included in the property insurance policy, the Owner shall, if possible, include such insurance, and the cost thereof shall be charged to the Contractor by appropriate Change Order.

Init.

§ 17.2.9 Notwithstanding any provision contained in Article 17, the Owner's obligation to purchase insurance shall herein be deemed satisfied by the Owner's membership in a self-insured risk management agency or pool. The Contractor agrees that any obligation the Owner has to purchase property insurance shall be satisfied by the Owner's membership in a self-insured risk management agency or pool. The Contractor further agrees that it will only have rights allowable to it under any coverage provided through the Owner's membership in a self-insured risk management agency or pool.

Omitted.

(Table deleted)

§ 17.3 Performance Bond and Payment Bond

§ 17.3.1 The Owner shall have the right to require the Contractor to furnish bonds covering faithful performance of the Contract and payment of obligations arising thereunder as stipulated in the Contract Documents on the date of execution of the Contract.

§ 17.3.2 Upon the request of any person or entity appearing to be a potential beneficiary of bonds covering payment of obligations arising under the Contract, the Contractor shall promptly furnish a copy of the bonds or shall authorize a copy to be furnished.

§ 17.3.3 If required by the Owner the Contractor, before commencing the Work, shall furnish a Performance Bond and a Labor and Material Payment Bond. The Performance Bond shall be in an amount equal to 110% of the full amount of the Contract Sum as security for the faithful performance of the obligations of the Contract Documents, including the payment of prevailing wages in accordance with Article 23 of this Agreement, and the Labor and Material Payment Bond shall be in an amount equal to 110% of the full amount of the Contract Sum as security for required payments to all persons performing labor and furnishing materials in connection with the Work. Such bonds shall be on AIA Document A-312, or the most current edition, issued by the American Institute of Architects, shall be issued by a surety satisfactory to the Owner, and shall name the Owner as primary co-obligee. Such bonds shall be from an Illinois Admitted Bonding Company acceptable to the Owner and having a minimum policy holder rating of "B+" in the latest edition of Best's Insurance Guide in effect as of the date of the Contract. Bonds shall remain in full force and effect for at least one year following the date of Final Completion of the Work or for the entire duration of the longest warranty period provided for the Work, whichever is longer. The cost of the bonds is to be included in the Contract Sum stated by the Contractor in its Bid Proposal.

§17.3.4 The Contractor shall (i) furnish with all bonds a certified copy of the power of attorney from the Surety Company stating that the person executing said bond is duly authorized by the Surety Company to execute said bond; (ii) furnish a certified copy of the certificate from said Surety Company's state showing said Surety Company licensed and authorized to transact business and execute said bond in Illinois; and (iii) if requested by Owner, furnish a copy of current financial statements of said Surety Company.

ARTICLE 18 CORRECTION OF WORK

§ 18.1 The Contractor shall promptly correct Work rejected by the Architect or failing to conform to the requirements of the Contract Documents, whether discovered before or after Substantial Completion and whether or not fabricated, installed, or completed. Costs of correcting such rejected Work, including additional testing and inspections, the cost of uncovering and replacement, and compensation for the Architect's services and expenses made necessary thereby, shall be at the Contractor's expense. If prior to the date of Final Completion the Contractor, a Subcontractor, or anyone for who either of them is responsible, uses or damages any portion of the Work, including but not limited to mechanical, electrical, plumbing or other building system, machinery, equipment or other mechanical device, the Contractor shall cause such item to be replaced or if permitted by the Owner restored to "like new" condition, at no expense to the Owner.

§ 18.2 In addition to the Contractor's obligations under Section 9.4, if, within one year after the date of Final Completion of the Work or designated portion thereof or after the date for commencement of warranties established under Section 15.6.3, or by terms of an applicable special warranty required by the Contract Documents, any of the Work is found to be not in accordance with the requirements of the Contract Documents, the Contractor shall correct it promptly after receipt of notice from the Owner to do so unless the Owner has previously given the Contractor a written acceptance of such condition. The Owner shall give such notice promptly after discovery of the condition. The obligation under this Section 18.2 shall survive acceptance of the Work under the Contract and termination of the Contract. Corrective Work shall be warranted to be free from defects for a period equal to the longer of twelve (12) months after the completion of the corrective Work or one (1) year from the date of Final Completion of the Work, or

such longer period of time as may be prescribed by law or in equity or by the terms of any applicable special warranty. Notwithstanding the foregoing, Contractor shall correct Work deficiently or defectively performed and replace defective or non-conforming materials and equipment, even though such deficiency, defect or non-conformity may be discovered more than one (1) year after Final Completion, if the correction is of a latent defect and arises from poor workmanship or improper materials or equipment, or is required to be made to Work, materials or equipment covered by the Contractor or a Subcontractor contrary to the Architect's or Owner's request or to the request of a governmental officer, or to the requirements of the Contract Documents or Governmental Requirements, and was therefore not visible for inspection by the Architect, Owner or governmental officer, as applicable, at the time of inspection. Contractor shall, within a reasonable time under the circumstances, after receipt of written notice thereof, correct, repair, replace and otherwise make good any defects or non-conformity in the Work.

§ 18.3 If the Contractor fails to correct nonconforming Work within a reasonable time, the Owner may correct it in accordance with Section 8.3.

§ 18.4 The one-year period for correction of Work shall be extended with respect to portions of Work first performed after Substantial Completion by the period of time between Substantial Completion and the actual completion of that portion of the Work.

§ 18.5 The Contractor shall remove from the site portions of the Work that are not in accordance with the requirements of the Contract Documents and are neither corrected by the Contractor nor accepted by the Owner.

§ 18.6 The Contractor shall bear the cost of correcting destroyed or damaged construction, whether completed or partially completed, of the Owner or separate contractors caused by the Contractor's correction or removal of the Work that is not in accordance with the requirements of the Contract Documents

ARTICLE 19 MISCELLANEOUS PROVISIONS

§ 19.1 Assignment of Contract

Neither party to the Contract shall assign the Contract without written consent of the other, except that the Owner may, without consent of the Contractor, assign the Contract to a lender providing construction financing for the Project if the lender assumes the Owner's rights and obligations under the Contract Documents. The Contractor shall execute all consents reasonably required to facilitate such assignment.

§ 19.2 Governing Law

The Contract shall be governed by the law of the place where the Project is located.

§ 19.3 Tests and Inspections

Tests, inspections, and approvals of portions of the Work required by the Contract Documents or by applicable laws, statutes, ordinances, codes, rules and regulations, or lawful orders of public authorities shall be made at an appropriate time. Unless otherwise provided, the Contractor shall make arrangements for such tests, inspections, and approvals with an independent testing laboratory or entity acceptable to the Owner, or with the appropriate public authority, and shall bear all related costs of tests, inspections, and approvals. The Contractor shall give the Architect timely notice of when and where tests and inspections are to be made so that the Architect may be present for such procedures. The Owner shall bear costs of (1) tests, inspections, or approvals that do not become requirements until after bids are received or negotiations concluded and (2) tests, inspections or approvals where building codes or applicable laws or regulations prohibit the Owner from delegating the costs to the Contractor, unless such tests, inspection or approvals were necessitated by the Contractor's failure to perform the Work in accordance with the Contract Documents in which event the Contractor shall bear the costs. The Owner shall directly arrange and pay for tests, inspections, or approvals where building codes or applicable laws or regulations so require.

The Owner shall bear costs of (1) tests, inspections or approvals that do not become requirements until after bids are received or negotiations concluded, and (2) tests, inspections or approvals where building codes or applicable laws or regulations prohibit the Owner from delegating the costs to the Contractor, unless such tests, inspection or approvals were necessitated by the Contractor's failure to perform the Work in accordance with the Contract Documents in which event the Contractor shall bear the costs.

§ 19.4 The Owner's representative:

AIA Document A104™ – 2017 (formerly A107™ – 2007). Copyright © 1936, 1951, 1958, 1961, 1963, 1966, 1970, 1974, 1978, 1987, 1997, 2007 and 2017 by The American Institute of Architects. All rights reserved. **WARNING: This AIA® Document is protected by U.S. Copyright Law and International Treaties. Unauthorized reproduction or distribution of this AIA® Document, or any portion of it, may result in severe civil and criminal penalties, and will be prosecuted to the maximum extent possible under the law.** This document was produced by AIA software at 15:57:50 ET on 02/20/2020 under Order No.8830539077 which expires on 06/25/2020, and is not for resale.

User Notes:

(1899329843)

(Name, address, email address and other information)

Dave Thommes
Oak Brook Park District
1450 Forest Gate Road
Oak Brook, IL 60523
T: 630-645-9534
Email: dthommes@obparks.org

§ 19.5 The Contractor's representative:
(Name, address, email address and other information)

§ 19.6 Neither the Owner's nor the Contractor's representative shall be changed without ten days' prior notice to the other party.

ARTICLE 20 TERMINATION OF THE CONTRACT

§ 20.1 Termination by the Contractor

If the Architect fails to certify payment as provided in Section 15.4.1 for a period of 30 days through no fault of the Contractor or for any undisputed payment and has not notified Contractor for the reason for withholding payment, or if the Owner fails to make payment as provided in Section 4.1.3 for a period of 30 days through no fault of the Contractor or for any undisputed payment and has not notified Contractor for the reason for withholding payment, and such failure continues for a period of 90 days after notice from the Contractor, the Contractor may, as its sole remedy, upon seven additional days' notice to the Owner and the Architect, unless this reason is cured prior to the expiration of the notice period, and recover from Owner payment of Work properly executed in accordance with the Contract Documents (the basis for such payment shall be as provided in the Contract) provided said Work was authorized in advance by Owner. The Owner shall have the right to cure any defect or default prior to the date of termination stated in any written notice from Contractor as provided herein, in which event Contractor shall continue with the Work. If the Contractor terminates the Work and receives payment in connection with his equipment, tools or materials such items shall be left and remain on the Site if the Owner so elects. Owner shall not be responsible for damages for loss of anticipated profits on Work not performed.

§ 20.2 Termination by the Owner for Cause

§ 20.2.1 The Owner may terminate the Contract if the Contractor

(Paragraph deleted)

If the Contractor shall institute proceedings or consent to proceeding requesting relief or arrangement under the Federal Bankruptcy Act or any applicable Federal or State Law, or if a petition under any federal or state insolvency law is filed against the Contractor and such petition is not dismissed within sixty (60) days from the date of the filing, or if the Contractor admits in writing his inability to pay his debts generally as they become due, or if he makes a general assignment for the benefit of his creditors, or if a receiver, liquidator, trustee, or assignee is appointed on account of his bankruptcy or insolvency; or if a receiver of all or any substantial portion of the Contractor's properties is appointed; or if the Contractor abandons the Work; or if he fails, except in cases for which extension of time is provided, to prosecute promptly and diligently the Work or to supply enough properly skilled workmen or proper materials for the Work; or if the Contractor submits an application for payment, sworn statement, waiver of lien, affidavit or document of any nature whatsoever which is intentionally falsified; or if the Contractor fails to make prompt payment to Subcontractors for materials or labor

(Paragraphs deleted)

or otherwise breaches obligations under any subcontract with a Subcontractor; or if a lien or a notices of lien is filed against any part of the Project or Project funds or if the Contractor disregards any laws, statues, ordinances, rules, regulations or orders of any governmental body or public or quasi-public authority having jurisdiction of the Work or the Project premises; or if the Contractor otherwise violates any material provision of the Contract Documents, then, without prejudice to any right or remedy available Owner may, after giving the Contractor seven (7) days' written

notice, terminate the Contractor, and take possession of the Project and all materials, equipment, tools, construction equipment and machinery thereon owned by the Contractor and accept assignment of Subcontracts and may complete the Work by whatever reasonable method the Owner may deem expedient. If requested by the Owner, the Contractor shall remove any part or all of this equipment, machinery and supplies from the Project within seven (7) days from the date of such request, and in such event at the Contractor's expense. Upon request of the Contractor, the Owner shall furnish to the Contractor a reasonably detailed accounting of the costs incurred by the Owner in completing the Work.

§ 20.2.2 Intentionally omitted.

§ 20.2.3 When the Owner terminates the Contract for one of the reasons stated in Section 20.2.1, the Contractor shall not be entitled to receive further payment until the Work is finished.

§ 20.2.4 If the unpaid balance of the Contract Sum exceeds costs of finishing the Work, including compensation for the Architect's services and expenses made necessary thereby, and other damages incurred by the Owner and not expressly waived, such excess shall be paid to the Contractor. If such costs and damages exceed the unpaid balance, the Contractor shall pay the difference to the Owner. The amount to be paid to the Contractor or Owner, as the case may be, shall be certified by the Architect, upon application, and this obligation for payment shall survive termination of the Contract.

§ 20.2.5 The Owner's right to terminate the contract pursuant to Section 20.2 shall be in addition to and not in limitation of its right to stop the Work without terminating the Contract as provided elsewhere in this Agreement.

§ 20.3 Termination by the Owner for Convenience

The Owner may, at any time, terminate the Contract for the Owner's convenience and without cause.

(Paragraphs deleted)

Termination by the Owner under this Section 20.3 shall be by a written notice of termination specifying the extent of termination and the effective date.

§ 20.3.1 Upon receipt of a notice of termination for convenience, the Contractor shall immediately, in accordance with instructions from the Owner, proceed with performance of the following duties:

1. cease operation as specified in the notice;
2. place no further orders and enter into no further Subcontracts for materials, labor, services, equipment, or facilities except as necessary to complete continued portions of the Contract;
3. terminate all subcontracts and orders to the extent they relate to the Work terminated;
4. proceed to complete the performance of Work not terminated; and
5. take actions that may be necessary, or that the Owner may direct, for the protection and preservation of the terminated work.

§ 20.3.2 In the event of termination by Owner for convenience, the sum payable to the Contractor for the Work shall be prorated based upon the amount of properly performed Work completed. Owner shall receive proper credit for sums already paid. Upon any such termination, all obligations of Owner (other than payment of sums due Contractor for services properly performed but not previously paid prior to the date of termination) shall cease as of the effective date of termination.

§20.3.4 The Owner shall be credited for (1) payments previously made to the Contractor for the terminated portion of the Work, and (2) claims which the Owner has against the Contractor under the Contract.

§20.4 SUSPENSION BY THE OWNER FOR CONVENIENCE

§20.4.1 The Owner may without cause order the Contractor in writing to suspend, delay or interrupt the Work in whole or in part for such period of time as the Owner may determine.

§20.4.2 If suspension, delay or interruption ordered by the Owner constitutes in the aggregate more than twenty percent (20%) of the total number of days scheduled for completion, an adjustment shall be made for increases in the cost of the performance of this Contract, excluding profit caused by such suspension, delay or interruption. No

Init.

adjustment shall be made to the extent:

- .1 That the performance is, was, or would have been so suspended, delayed or interrupted by another cause, including without limitation the fault or negligence of the Contractor or any Subcontractor; or
- .2 That an equitable adjustment is made or denied under another provision of this Contract.

§20.4.3 Adjustments made in the cost of performance may have a mutually agreed fixed or percentage fee.

ARTICLE 21 CLAIMS AND DISPUTES

§ 21.1 Intentionally omitted.

§ 21.2 Notice of Claims

§ 21.2.1 Intentionally omitted.

§ 21.2.2 Claims by either the Owner or Contractor, where the condition giving rise to the Claim is first discovered after expiration of the period for correction of the Work set forth in Section 18.2, shall be initiated by notice to the other party.

§ 21.3 Time Limits on Claims

The Owner and Contractor shall commence all claims and causes of action against the other and arising out of or related to the Contract in accordance with the requirements of the final dispute resolution method selected in this Agreement whether in contract, tort, breach of warranty, or otherwise, within the period specified by applicable law.

§ 21.4 If a claim, dispute or other matter in question relates to or is the subject of a mechanic's lien, the party asserting such matter may proceed in accordance with applicable law to comply with the lien notice or filing deadlines.

§ 21.5 Intentionally omitted.

§ 21.6 Intentionally omitted.

(Paragraphs deleted)

§ 21.7- § 21.9 Intentionally omitted.

§ 21.10 Continuing Contract Performance

Pending final resolution of a Claim, except as otherwise agreed in writing, the Contractor shall proceed diligently with performance of the Contract and the Owner shall continue to make payments in accordance with the Contract Documents.

§ 21.11 Waiver of Claims for Consequential Damages

The Contractor waives Claims against the Owner for consequential damages arising out of or relating to this Contract. This

(Paragraphs deleted)

waiver includes, but is not limited to damages incurred by the Contractor for principal office expenses including the compensation of personnel stationed there, for losses of financing, business and reputation, and for loss of profit arising from the Work.

This waiver is applicable, without limitation, to all consequential damages due to Owner's termination in accordance with Article 20.

In any suit or action arising under this Contract the Owner shall be entitled to an award of reasonable attorney's fees and costs of litigation.

Any suit or action arising under this Contract shall be commenced in DuPage County, Illinois.

ARTICLE 22 OTHER CONDITIONS OR PROVISIONS

§ 22.1 The Contractor shall be responsible for the supply and maintenance of any and all temporary equipment, utilities, and facilities necessary to properly and safely complete and protect the Work, including without limitation those required by winter conditions. Contractor shall provide and erect barricades and other safeguards adequate to warn of danger at the site and to protect persons and property from injury resulting from the Work.

§ 22.2 The Contractor shall limit material and equipment storage to the immediate area of Work and such other areas as Owner may designate. The Contractor shall promptly remove and properly dispose off-site all construction material, trash, garbage and other debris.

§ 22.3 The Contractor shall notify Architect and Owner in advance (to the extent practicable, notice shall be made at least 48 hours in advance) of any and all deliveries of major materials to the Project Site and shall give notice of receipt of materials and equipment that Architect or Owner has indicated or customarily would want to inspect prior to commencement of the Work. Prior to resumption of the Work in the event of a temporary suspension lasting longer than 72 hours, and at such other time intervals during the process of the Work as requested by Owner, in order to permit Owner to properly coordinate its normal operations and facilities requirements with the Work.

§22.4 The following definitions are added to the Contract:

"**Final completion**" means the date the Contract has been fully performed, all the Work has been completed in accordance with the Contract Documents and the Owner has approved Final Payment to the Contractor.

"**Indicated**" and "**shown**" mean as described, detailed, discussed, scheduled, referenced, or called for in. or reasonably inferable from the Contract Documents in order to produce a first class Work product.

"**Provide**" or derivatives thereof means the Contractor shall properly fabricate, supply, furnish or procure all labor, materials, equipment, apparatus, and accessory appurtenances necessary to transport, deliver, install, erect and construct the specified item, complete, in place and ready for operation and use, including any final connections, in strict accordance with the Drawings, Specifications and other Contract Documents. The words "Contractor shall" are implied and shall be so understood whenever the direction or term "provide" is used.

"**Unit Price**" is an amount stated in the Contractor's bid proposal or in the Contract Documents as a price per unit of measurement for materials, equipment or services for a portion of the Work as described in the Bidding Documents or the Contract Documents. A Unit Price includes all costs associated with the performance of the portion of the Work for which the Unit Price is provided, including but not limited to labor, materials, equipment, loading, transportation, handling, unloading, overhead and profit.

§22.5 Except as otherwise specifically provided in the Contract Documents, if and to the extent of any inconsistency, ambiguity, conflict, discrepancy or error in the Contract Document, and otherwise in interpreting the Contract Documents, the Parties shall give precedence to the Contract Documents in the following order of priority:

- (i) Modifications.
- (ii) This Agreement except that the Supplementary Conditions shall take precedence over the General Conditions of the Contract.
- (iii) Specifications.

ARTICLE 23 • COMPLIANCE WITH LAWS

§ 23.1 The Contractor shall comply with all federal, state, county and local laws, codes, rules and regulations applicable to the Work including without limitation all building codes, permit conditions, the American with Disabilities Act and the equal employment opportunity clause of the Illinois Human Rights Act and the rules and regulations of the Illinois Department of Human Rights, the Illinois Prevailing Wage Act, and all laws and regulations pertaining to occupational and work safety, hours of operation and disposal of construction debris. A copy of the Contractor's certification of compliance with applicable laws is attached to and made a part of this Agreement.

§23.2 The Contractor shall maintain and shall require its Subcontractors to maintain policies of employment as follows:

§23.3.1 In the event of the Contractor's non-compliance with the provisions of this equal opportunity clause, the Illinois Human Rights Act or the Rules and Regulations of the Illinois Department of Human Rights ("Department"). Contractor may be declared ineligible for future contracts or subcontracts with the State of Illinois or any of its political subdivisions or municipal corporations, and the Contract may be cancelled or voided in whole or in part, and such other sanctions or penalties may be imposed or remedies invoked as provided by statute or regulation. During the performance of this Contract, Contractor agrees as follows:

- 1) That it will not discriminate against any employee or applicant for employment because of race, color, religion, sex, sexual orientation or preference, marital status, national origin or ancestry, citizenship status, age, physical or mental disability unrelated to a person's ability to perform the essential functions of the job, association with a person with a disability, military status or an unfavorable discharge from military service, or record of arrest; and further that it will examine all job classifications to determine if minority persons or women are underutilized and will take appropriate affirmative action to rectify any such underutilization.
- 2) That, if it hires additional employees in order to perform this Contract or any portions thereof, it will determine the availability (in accordance with the Department's Rules and Regulations) of minorities and women in the area(s) from which it may reasonably recruit and it will hire for each job classification for which employees are hired in such a way that minorities and women are not underutilized.
- 3) That, in all solicitations or advertisements for employees placed by it or on its behalf, it will state that all applicants will be afforded equal opportunity without discrimination because of race, color, religion, sex, sexual orientation, marital status, national origin or ancestry, citizenship status, age, physical or mental handicap or disability unrelated to a person's ability to perform the essential function of the job, or association with a person with a disability, military status or an unfavorable discharge from military service, or record of arrest.
- 4) That it will send to each labor organization or representative of workers with which it has or is bound by a collective bargaining or other agreement or understanding, a notice advising such labor organization or representative of the Contractor's obligations under the Illinois Human Rights Act and the Department's rules and regulations. If any such labor organization or representative fails or refuses to cooperate with the Contractor in its efforts to comply with such Act and rules and regulations, the Contractor will promptly notify the Department and the Owner and will recruit employees from other sources when necessary to fulfill its obligations thereunder.
- 5) That it will submit reports as required by the Department's rules and regulations, furnish all relevant information as may from time to time be requested by the Department or the Owner, and in all respects comply with the Illinois Human Rights Act and the Department's rules and regulations.
- 6) That it will permit access to all relevant books, records, accounts and work sites by personnel of the Owner and the Department for purposes of investigation to ascertain Department's rules and regulations.
- 7) That it will include verbatim or by reference the provisions of this clause in every subcontract it awards under which any portion of the Contract obligations are undertaken or assumed, so that such provisions will be binding upon such subcontractor. In the same manner as with other provisions of this Contract. The Contractor will be liable for compliance with applicable provisions of this clause by such subcontractors; and further it will promptly notify the Owner and the Department in the event any subcontractor fails or refuses to comply therewith. In addition, the Contractor will not utilize any subcontractor declared by the Illinois Human Rights Commission to be ineligible (or contracts or subcontracts with the State of Illinois or any of its political subdivisions or municipal corporations).

§23.4 The Contractor is encouraged to utilize qualified minority businesses as subcontractors for supplies, services and construction.

§23.5 The Contractor shall comply with the requirements of the Illinois Prevailing Wage Act (820 ILCS 130/0.01 *et seq.*) requiring payment of prevailing wages. The Contractor shall pay or cause to be paid not less than the prevailing rate of hourly wage in the county the Work is performed as determined by the Illinois Department of Labor for the month in which the Work is performed including but not limited to all laborers, workers and mechanics. All contractors and subcontractors rendering services under this contract must comply with all requirements under the Act, including but not limited to, all wage, notice and record keeping duties.

The Contractor is required to verify current prevailing wage prior to the first day of each month and to pay the then-current prevailing wage rate as determined by the Illinois Department of Labor. Any increases in costs to the Contractor due to the changes in the prevailing wage during the term of this Contract shall be at the expense of Contractor and not at the expense of Owner. Current prevailing wage rates are published at the following: <https://www2.illinois.gov/idnl/Laws-Rules/CONMED/Pages/2018-Rates.aspx>. The Contractor agrees to indemnify and hold harmless the Park District for any violations of the Prevailing Wage Act.

The Contractor shall also: (1) insert into each subcontract and the project specifications for each subcontract, a written stipulation that the subcontractor shall not pay less than the prevailing rate of hourly wage to all laborers, workers, and mechanics performing work under the contract; and (2) require each subcontractor to insert into each lower-tiered contract and the project specifications for each lower-tiered subcontract, a stipulation that the subcontractor shall not pay less than prevailing rate of hourly wage to all laborers, workers, and mechanics performing work under the contract.

The Contractor shall include on all bonds and shall cause all subcontractors' bonds required under the Contract Documents to guarantee compliance with the Prevailing Wage Act.

Additionally, the Contractor and each subcontractor shall make and keep, for a period of not less than 5 years from the date of the last payment on a contract or subcontract, records of all laborers, mechanics, and other workers employed by them on the Project; the records shall include each worker's name, address, telephone number when available, social security number, classification or classifications, the hourly wages paid in each pay period, the number of hours worked each day, and the starting and ending times of work each day. The Contractor shall submit monthly, no later than the 10th day of each calendar month, in person, by mail, or electronically a certified payroll to the Park District with each monthly pay request in the form required by the Illinois Prevailing Wage Act. The certified payroll shall be accompanied by a statement signed by the Contractor or subcontractor which states that: (i) he or she has examined the certified payroll and such records are true and accurate; (ii) the hourly rate paid to each worker is not less than the general prevailing rate of hourly wages required by this Act; and (iii) the Contractor or subcontractor is aware that filing a certified payroll that he or she knows to be false is a Class A misdemeanor. The Contractor may rely on the certification of a lower tier subcontractor, provided the Contractor does not knowingly rely upon a subcontractor's false certification. The records submitted in accordance with this payroll submittal provision shall be considered public records pursuant to Section 5 of the Prevailing Wage Act, 820 ILCS 130/5 (2004, as amended by P.A. 94-515). The Park District may, at its option, immediately terminate the Contract in the event that Contractor violates any provision of this paragraph or the Prevailing Wage Act.

Contractor shall also post the prevailing wage rates for each craft or type of worker or mechanic needed to complete the project at either: (1) a location on the project site easily accessible to the workers engaged on the project; or (2) in lieu of posting on the project site, if the Contractor has a business location where laborers, workers, and mechanics may regularly visit, the Contractor may either post the prevailing rate of wages in each county the Contractor works in a conspicuous location or provide the laborers, workers or mechanics engaged on the project a written notice indicating the prevailing rate of wages for the project.

Upon seven business days' notice, the Contractor and each subcontractor shall make available for inspection and copying at a location within this State during reasonable hours, the records identified in 820 ILCS 130/5(a)(1) to the Owner, and its officers and agents.

§23.6 Central Park West shall remain open to the public during weekends for the duration of the Project. As such, Contractor shall maintain the Project site in a manner that ensures safe access to Central Park West amenities by the public, Park District staff and others requiring access to Central Park West. Additionally, the Contractor shall ensure that the Project site is clean, all tools are either removed from the Project site or safely secured on-site in a manner that will not restrict access to Central Park West by the public and Park District staff, and Central Park West is otherwise able to be occupied and operated as a rental space during the weekends by the public. Contractor shall comply with and give notices required by applicable laws, statutes, ordinances, codes, rules and regulations, and lawful orders of public authorities bearing on safety of persons or property or their protection from damage, injury or loss.

Init.

§23.7 Contractor shall only perform work four (4) days a week and only on the designated days as specified on the Central Park West Monthly Calendar included in these Bid Documents.

This Agreement entered into as of the day and year first written above.

OAK BROOK PARK DISTRICT

OWNER (Signature)

CONTRACTOR (Signature)

(Printed name and title)

(Printed name and title)

Additions and Deletions Report for AIA® Document A104™ – 2017

This Additions and Deletions Report, as defined on page 1 of the associated document, reproduces below all text the author has added to the standard form AIA document in order to complete it, as well as any text the author may have added to or deleted from the original AIA text. Added text is shown underlined. Deleted text is indicated with a horizontal line through the original AIA text.

Note: This Additions and Deletions Report is provided for information purposes only and is not incorporated into or constitute any part of the associated AIA document. This Additions and Deletions Report and its associated document were generated simultaneously by AIA software at 15:57:50 ET on 02/20/2020.

PAGE 1

AGREEMENT made as of the day of in the year Two Thousand Twenty

...

(Name, legal status, address and other information)

Oak Brook Park District
1450 Forest Gate Road
Oak Brook, IL 60523

...

Central Park West Door and Window Replacement Project
1500 Forest Gate Road
Oak Brook, IL 60523

This Project includes replacement of the sliding glass exterior doors in the main community room at Central Park West with swinging patio doors with side lights, and all other incidental and collateral work necessary to complete the Project in accordance with the Contract Documents.

...

Legat Architects, Inc.
2015 Spring Road, Suite 175
Oak Brook, IL 60523

PAGE 2

21 CLAIMS AND DISPUTES

22 OTHER CONDITIONS OR PROVISIONS

23 COMPLIANCE WITH LAWS

PAGE 3

Established as follows:

...

All materials and supplies required to complete the Work must be delivered on site by April 31, 2020.

Additions and Deletions Report for AIA Document A104™ – 2017 (formerly A107™ – 2007). Copyright © 1936, 1951, 1958, 1961, 1963, 1966, 1970, 1974, 1978, 1987, 1997, 2007 and 2017 by The American Institute of Architects. All rights reserved. **WARNING: This AIA® Document is protected by U.S. Copyright Law and International Treaties. Unauthorized reproduction or distribution of this AIA® Document, or any portion of it, may result in severe civil and criminal penalties, and will be prosecuted to the maximum extent possible under the law.** This document was produced by AIA software at 15:57:50 ET on 02/20/2020 under Order No.8830539077 which expires on 06/25/2020, and is not for resale.

User Notes:

(1899329843)

Installation of the Work for the Contract shall commence on May 4, 2020.

...

By the following date: June 4, 2020

...

NA

...

§ 2.4 Final Completion

§ 2.4.1 Subject to adjustments of the Contract Time as provided in the Contract Documents, the Contractor shall achieve Final Completion of the entire Work:

(Check the appropriate box and complete the necessary information.)

Not later than () calendar days from the date of commencement of the Work.

By the following date: June 11, 2020

§ 2.4.2 If the Contractor fails to achieve Final Completion as provided in this Section 2.4, liquidated damages, if any, shall be assessed as set forth in Section 3.5.

...

Stipulated Sum, in accordance with Section 3.2 below
PAGE 4

§ 3.2 The Stipulated Sum shall be Dollars (\$), subject to additions and deductions as provided in the Contract Documents.

...

NA

§ 3.3 Cost of the Work Plus Contractor's Fee

§ 3.3.1 The Cost of the Work is as defined in Exhibit A, Determination of the Cost of the Work.

§ 3.3.2 The Contractor's Fee:

(State a lump sum, percentage of Cost of the Work or other provision for determining the Contractor's Fee and the method of adjustment to the Fee for changes in the Work.)

§ 3.4 Cost of the Work Plus Contractor's Fee With a Guaranteed Maximum Price

§ 3.4.1 The Cost of the Work is as defined in Exhibit A, Determination of the Cost of the Work.

§ 3.4.2 The Contractor's Fee:

(State a lump sum, percentage of Cost of the Work or other provision for determining the Contractor's Fee and the method of adjustment to the Fee for changes in the Work.)

§ 3.4.3 Guaranteed Maximum Price

§ 3.4.3.1 The sum of the Cost of the Work and the Contractor's Fee is guaranteed by the Contractor not to exceed (\$), subject to additions and deductions by changes in the Work as provided in the Contract Documents. This maximum sum is referred to in the Contract Documents as the Guaranteed Maximum Price. Costs which would cause the Guaranteed Maximum Price to be exceeded shall be paid by the Contractor without reimbursement by the Owner. *(Insert specific provisions if the Contractor is to participate in any savings.)*

§ 3.4.3.2 The Guaranteed Maximum Price is based on the following alternates, if any, which are described in the Contract Documents and are hereby accepted by the Owner: *(State the numbers or other identification of accepted alternates. If the bidding or proposal documents permit the Owner to accept other alternates subsequent to the execution of this Agreement, attach a schedule of such other alternates showing the amount for each and the date when that amount expires.)*

§ 3.4.3.3 Unit Prices, if any: *(Identify the item and state the unit price and the quantity limitations, if any, to which the unit price will be applicable.)*

§ 3.2.4 Adjustments to the Contract Sum: Adjustments to the Contract Sum for changes in the Work other than changes in the Work involving items for which unit prices were requested by Owner and provided in Contractor's Submitted Bid Proposal, shall be made as follows:

1. In the manner agreed to by the Parties, or in the absence of agreement then the combined allowance for overhead and profit in connection with changes to the Work shall be the lesser of the amount, if any, included in the Contractor's bid proposal, or the following:
 - a. Five percent (5%) of the cost of the change in the Work involved if performed by the Contractor not involving Subcontractors, or
 - b. Five percent (5%) of the cost of the change in the Work involved performed by Subcontractors, plus two percent (2%) of the cost of the change in the Work for the Contractor's supervision of the work performed by the Subcontractors.

When both additions and credits covering related Work are involved in a change, the allowance for overhead and profit shall be figured on the basis of net increase, if any, with respect to that change.

§ 3.2.5 Overtime, if and when specifically authorized in advance in writing by the Owner shall be paid by the Owner on the basis of premium payment if any, plus the cost of insurance and taxes based on the premium payment period. No overhead or profit may be charged for overtime. The Contractor shall not be entitled to any payment for overtime necessitated by the failure of the Contractor to perform the Work in accordance with the Contract Documents including without limitation to the Contractor's failure to prosecute the Work diligently and on an uninterrupted basis and with a sufficient work force so as to achieve completion of the Work within the time and in the manner contemplated by the Contract Documents or otherwise due to the fault of the Contractor. In such instances if the Owner requires the Contractor to perform Work on an overtime basis, all costs for and associates with such overtime shall be borne by the Contractor.

Item	Units and Limitations	Price per Unit (\$0.00)
------	-----------------------	-------------------------

§ 3.4.3.4 Allowances, if any, included in the Guaranteed Maximum Price: *(Identify each allowance.)*

Item	Price
------	-------

~~§ 3.4.3.5 Assumptions, if any, on which the Guaranteed Maximum Price is based:~~

~~§ 3.4.3.6 To the extent that the Contract Documents are anticipated to require further development, the Guaranteed Maximum Price includes the costs attributable to such further development consistent with the Contract Documents and reasonably inferable therefrom. Such further development does not include changes in scope, systems, kinds and quality of materials, finishes or equipment, all of which, if required, shall be incorporated by Change Order.~~

~~§ 3.4.3.7 The Owner shall authorize preparation of revisions to the Contract Documents that incorporate the agreed upon assumptions contained in Section 3.4.3.5. The Owner shall promptly furnish such revised Contract Documents to the Contractor. The Contractor shall notify the Owner and Architect of any inconsistencies between the agreed upon assumptions contained in Section 3.4.3.5 and the revised Contract Documents.~~

PAGE 5

Time is of the essence to the Contract. Should the Contractor fail to complete the Work on or before the Substantial Completion date as stipulated in the Contract or within such extended time as may be have been allowed, the Contractor shall be liable and shall pay to the Owner the sum of \$200.00 per calendar day, not as a penalty but as a liquidated damages for each day of overrun in the Contract Time or such extended time as may have been allowed. The liquidated damages for failure to complete the Contract on time are approximate, due to the impracticality of calculating and proving actual delay costs. The costs of delay represented by the liquidated damage amount are understood to be a fair and reasonable estimate of the costs that will be borne by the Owner during extended and delayed performance by the Contractor for the Work. The liquidated damage amount specified will accrue and be assessed until Final Completion of the total physical Work of the Contract even though the Work may be substantially complete. The Owner will deduct these liquidated damages from any monies due or to become due to the Contractor from the Owner.

...

§ 4.1.1 Based upon Applications for Payment properly completed and accompanied by all supporting documentation and other submittals required by the Contract Documents, submitted to the Architect by the Contractor and Certificates for Payment issued by the Architect, and agreed to by the Owner and not subsequently nullified by the Architect in accordance with the Contract Documents, the Owner shall make progress payments on account of the Contract Sum to the Contractor as provided below and elsewhere in the Contract Documents.

§ 4.1.2 The period covered by each Application for Payment shall be one calendar month ending on the last day of the month, or as follows: month.

...

§ 4.1.3 Provided that an Application for Payment Payment, which is in proper form and accompanied by the required supporting documents and submittals, in form and substance required by the Contract Documents, is received by the Architect not later than the 10th day of a month, certified by Architect and not subsequently nullified by Architect, the Owner shall make payment of the certified amount to the Contractor not later than the fifteenth day of the following month. If an Application for Payment is received by the Architect after the date fixed above, payment shall be made by the Owner not later than forty-five (45) days after the Architect receives the Application for Payment.

...

§ 4.1.4 For each progress payment made prior to Substantial-Final Completion of the Work, the Owner may withhold retainage from the payment otherwise due as follows:

...

10% of the Contract Sum

§ 4.1.5 Payments due and unpaid under the Contract shall bear interest from the date payment is due at the rate stated below, or in the absence thereof, at the legal rate prevailing from time to time at the place where the Project is located. Contract, and any penalties associated with the same, shall be paid in accordance with the provisions of the Illinois Local Government Prompt Payment Act, 50 ILCS 505/1 et seq.
(Insert rate of interest agreed upon, if any.)

—%
PAGE 6

- .1 the Contractor has fully performed the Contract except for the achieved Final Completion of the Work, including Final Completion for Contractor's responsibility to correct Work as provided in Section Sections 9.4 and 18.2, and to satisfy other requirements, if any, which extend beyond final payment;

...

§ 4.2.2 The Subject to § 4.2.1, the Owner's final payment to the Contractor shall be made no later than 30 days after the issuance of the Architect's final Certificate for Payment, or as follows:
Payment and approval by Owner.

...

For any claim subject to, but not resolved by, mediation pursuant to Section 21.5, the The method of binding dispute resolution shall be as follows:

...

- Litigation in a court of competent jurisdiction

...

If the Owner and Contractor do not select a method of binding dispute resolution, or do not subsequently agree in writing to a binding dispute resolution method other than litigation, claims will be resolved in a court of competent jurisdiction.

...

§ 6.1.2 AIA Document E203™ 2013, Building Information Modeling and Digital Data Exhibit, dated as indicated below:
(Insert the date of the E203 2013 incorporated into this Agreement.)

Intentionally Omitted.

§ 6.1.3 The Supplementary and other Conditions of the Contract:
Contract are those included in the Project Manual dated February 21, 2020.

Document	Title	Date	Pages
----------	-------	------	-------

§ 6.1.4 The Specifications:
(Either list the Specifications here or refer to an exhibit attached to this Agreement.)

Specifications are those included in the Project Manual dated February 21, 2020.

Section	Title	Date	Pages
---------	-------	------	-------

§ 6.1.5 ~~The Drawings~~ Drawings are those included in the Project Manual dated February 21, 2020.

...

Number	Title	Date
--------	-------	------

PAGE 7

- a. Project Manual for Central Park West Door and Window Replacement Project, dated February 21, 2020, incorporated herein by reference.
- b. Contractor's Proposal, dated _____, 2020, attached to and incorporated in this Agreement as Exhibit A.
- c. Contractor's Compliance and Certification, a copy of which is attached to and incorporated in this Agreement as Exhibit B.
- d. Central Park West Work Calendar, a copy of which is attached to and incorporated in this Agreement as Exhibit C.
- e. Performance Bond and Labor Material Payment Bond, copies of which are attached to and incorporated as part of this Agreement by reference.

PAGE 8

~~§ 7.5.1 The Architect and the Architect's consultants shall be deemed the authors and owners of their respective Instruments of Service, including the Drawings and Specifications, and will retain all common law, statutory and other reserved rights in their Instruments of Service, including copyrights. The Contractor, Subcontractors, Sub-subcontractors, and suppliers shall not own or claim a copyright in the Instruments of Service. Submittal or distribution to meet official regulatory requirements or for other purposes in connection with the Project is not to be construed as publication in derogation of the Architect's or Architect's consultants' reserved rights.~~

§ 7.5.2 The Contractor, Subcontractors, Sub-subcontractors and suppliers are authorized to use and reproduce the Instruments of Service provided to them, subject to the protocols established pursuant to Sections 7.6 and 7.7, if applicable, solely and exclusively for execution of the Work. All copies made under this authorization shall bear the copyright notice, if any, shown on the Instruments of Service. The Contractor, Subcontractors, Sub-subcontractors, and suppliers may not use the Instruments of Service on other projects or for additions to this Project outside the scope of the Work without the specific written consent of the Owner, Architect and the Architect's consultants.

7.5.3 The Owner is the owner of the Contract Documents. The Contractor may retain one record set for use with this Project only. All copies of the Contract Documents except the Contractor's record set, shall be returned or suitably accounted for to the Owner on request upon completion of the Work.

...

The parties shall agree upon protocols governing the transmission and use of Instruments of Service or any other information or documentation in digital form. ~~The parties will~~ if applicable, the parties may use AIA Document E203™-2013, Building Information Modeling and Digital Data Exhibit, to establish the protocols for the development, use, transmission, and exchange of digital data.

...

Any use of, or reliance on, all or a portion of a building information model without agreement to protocols governing the use of, and reliance on, the information contained in the model and without having those protocols set forth in AIA Document E203™-2013, Building Information Modeling and Digital Data Exhibit, if completed, and the requisite AIA Document G202™-2013, Project Building Information Modeling Protocol Form, if completed, shall be at the using or relying party's sole risk and without liability to the other party and its contractors or consultants, the authors of, or contributors to, the building information model, and each of their agents and employees.

PAGE 9

§ 7.10 Relationship of the Parties

~~Where the Contract is based on the Cost of the Work plus the Contractor's Fee, with or without a Guaranteed Maximum Price, the Contractor accepts the relationship of trust and confidence established by this Agreement and covenants with the Owner to cooperate with the Architect and exercise the Contractor's skill and judgment in furthering the interests of the Owner; to furnish efficient business administration and supervision; to furnish at all times an adequate supply of workers and materials; and to perform the Work in an expeditious and economical manner consistent with the Owner's interests. The Owner agrees to furnish and approve, in a timely manner, information required by the Contractor and to make payments to the Contractor in accordance with the requirements of the Contract Documents.~~

...

~~§ 8.1.1 Prior to commencement of the Work, at the written request by the Contractor, the Owner shall furnish to the Contractor reasonable evidence that the Owner has made financial arrangements to fulfill the Owner's obligations under the Contract. The Contractor shall have no obligation to commence the Work until the Owner provides such evidence. If commencement of the Work is delayed under this Section 8.1.1, the Contract Time shall be extended appropriately.~~

Intentionally omitted.

...

~~§ 8.1.3 The Subject to the Contractor's duties and obligations under the Contract Document and § 9.1.1 of this Agreement, the Contractor shall be entitled to rely on the accuracy of information furnished by the Owner but shall exercise proper precautions relating to the safe performance of the Work.~~

...

~~If the Contractor fails to correct Work which is not in accordance with the requirements of the Contract Documents, or repeatedly fails or refuses to provide a sufficient amount of properly supervised and coordinated labor, material or equipment so as to be able to complete the Work within the Contract Time, or fails to pay subcontractors or material suppliers timely or to remove and discharge within ten days any lien filed upon the Owner's property or funds by anyone claiming by, through or under the Contractor, or disregards the instructions of the Architect or Owner when based on the requirements of the Contract Documents, or otherwise fails to carry out the Work in accordance with the Contract Documents, the Owner may issue a written order to the Contractor to stop the Work, or any portion thereof, until the cause for such order is eliminated; however, the right of the Owner to stop the Work shall not give rise to a duty on the part of the Owner to exercise this right for the benefit of the Contractor or any other person or entity.~~

...

~~If the Contractor defaults or neglects to carry out the Work in accordance with the Contract Documents, and fails within a ten-day period after receipt of or fails to perform a duty under or comply with a provision of the Contract Documents and fails within a seven-day period after receipt of written notice from the Owner to commence and continue correction of such default or neglect with diligence and promptness, or fails within such seven-day period to eliminate (or diligently commence to eliminate) the cause of any stop work order issued under Section 8.2 thereof, the Owner may, without prejudice to any other remedies the Owner may have, correct such default or neglect. Such action by the Owner and amounts charged to the Contractor are both subject to prior approval of the Architect and the deficiencies, default or neglect and may deduct the actual cost thereof, including Owner's expenses and compensation for the Architect's services made necessary thereby, from the payment then or thereafter due the Contractor. Architect may, pursuant to Section 15.4.3, withhold or nullify a Certificate for Payment in whole or in part, to the extent reasonably necessary to reimburse the Owner for the reasonable cost of correcting such deficiencies, including the Owner's expenses and compensation for the Architect's additional services made necessary by such default, neglect, or failure. If the Contractor disagrees with the actions of the Owner or the Architect, or the amounts claimed as costs to the Owner, the Contractor may file a Claim pursuant to Article 21.~~

...

§ 9.1.1 Execution of the Contract by the Contractor is a representation that the Contractor has visited the site, become generally familiar with local conditions under which the Work is to be performed and correlated personal observations with requirements of the Contract Documents. By its execution of the Contract, the Contractor acknowledges, agrees, represents, and warrants that: (a) the Contractor has carefully and thoroughly examined the Contract Documents, and the Contract Documents are full and complete, include all items necessary for the proper execution and completion of the Work, are sufficient to have enabled the Contractor to determine the cost of the Work and the time required for performance of the Work and to enable Contractor to construct the Work indicated therein in accordance with laws, ordinances, codes, regulations and rules applicable to the Work, and otherwise to fulfill all its obligations thereunder, including, but not limited to, Contractor's obligation to construct the Work for an amount not in excess of the Contract Sum on or before the date(s) of Substantial and Final Completion established in the Contract; (b) the omission from the Contract Documents of minor details which ordinarily form a part of first class work and are necessary to the completion of the Work as indicated, shall not be cause for any extra cost but shall be included as if specifically mentioned or detailed; (c) the Contractor has visited and examined the Project site and surrounding areas, examined all physical, legal and other conditions affecting the Work and correlated its personal observations with the requirements of the Contract Documents, and understands, is familiar with, and satisfied itself as to the same, including, without limitation: (i) the nature, location, and character of the Project and the site, including, without limitation surface conditions of the site and subsurface conditions observable or ascertainable upon the exercise of reasonable diligence including all structures and obstructions thereon and thereunder, both natural and manmade and all surface and subsurface water conditions of the site and the surrounding area; (ii) the nature, location, and character of the general area in which the Project is located, including without limitation, its generally prevailing climatic conditions, available labor supply and labor costs, and available equipment supply and equipment costs; (iii) the availability, quality, quantity and cost of all labor, materials, supplies, tools, equipment and professional services necessary to complete the Work in the manner and within the cost and time frame indicated by the Contract Documents.

By its execution of the Contract, the Contractor acknowledges, agrees, represents and warrants that it has carefully examined the Drawings, Specifications and other Contract Documents and having visited the Project site it has no actual knowledge of any discrepancies, omissions, ambiguities, or conflicts in or between the Contract Documents except those, if any, which have been clarified by Architect by Addenda to the Contractor's satisfaction, and that if it becomes aware of any such discrepancies, omissions, ambiguities, or conflicts, it has an obligation to and will immediately notify Owner and Architect of such fact, and will not proceed until it shall have received the written interpretation of Owner or Architect. If any such differences or conflicts which were ascertainable by careful review of the documents were not called to the Owner's and Architect's attention prior to submission by the Contractor of its bid proposal, the Architect shall decide which of the conflicting requirements will govern based upon the most stringent or highest quality of the requirements and, subject to the approval of the Owner, the Contractor shall perform the Work at no additional cost and/or time to the Owner in accordance with the Architect's decision.

PAGE 10

§ 9.1.3 The-Except as otherwise required by the Contract Documents, the Contractor is not required to ascertain that the Contract Documents are in accordance with applicable laws, statutes, ordinances, codes, rules and regulations, or lawful orders of public authorities, but the Contractor shall promptly report to the Architect any nonconformity discovered by or made known to the Contractor as a request for information in such form as the Architect may require.

...

§ 9.2.1 The Contractor shall supervise and direct the Work, using the Contractor's best skill and ~~attention~~-attention under the full-time supervision of an approved site superintendent or foreman capable of communicating clearly with the Architect and the Owner in English. The Contractor shall be solely responsible for and have control over construction means, methods, techniques, sequences, and procedures, and for coordinating all portions of the Work under the Contract, unless the Contract Documents give other specific instructions concerning these matters.

...

§ 9.2.3 The Contractor has the responsibility to ensure that all material suppliers and Subcontractors, their agents, and employees adhere to the Contract Documents, and that they order materials on time, taking into account the current market and delivery conditions and that they provide materials on time. The Contractor shall coordinate its Work with that of all others on the Project including deliveries, storage, installations, and construction utilities. The Contractor

shall be responsible for the space requirements, locations, and routing of its equipment. In areas and locations where the proper and most effective space requirements, locations, and routing cannot be made as indicated, the Contractor shall meet with all others involved, before installation, to plan the most effective and efficient method of overall installation.

PAGE 11

§ 9.3.3 The Contractor may make a substitution equivalent to or superior to the specified materials only with the consent of the Owner, after evaluation by the Architect and approval by the Owner and in accordance with a Modification.

§9.3.4 The Contractor shall only employ labor on the Project or in connection with the Work capable of working harmoniously with all trades, crafts and any other individuals associated with the Project. The Contractor shall also use its reasonable best efforts to minimize the likelihood of any strike, work stoppage or other labor disturbance. The Contractor shall comply with all requirements of OSHA and shall indemnify and hold harmless the Owner against and from any claims, losses, damages or expenses it may incur as a result of the failure of the Contractor or any of its Subcontractors to comply with OSHA requirements.

§9.3.5 If the Work is to be performed by trade unions, the Contractor shall make all necessary arrangements to reconcile, without delay, damage, or cost to the Owner and without recourse to the Architect, Owner's representative or the Owner, any conflict between the Contract Documents and any agreements or regulations of any kind at any time in force among members of councils which regulate or distinguish what activities shall not be included in the Work of any particular trade. In case the progress of the Work is affected by any undue delay in furnishing or installing any items or materials or equipment required under the Contract Documents because of the conflict involving any such agreement or regulations, the Architect or Owner's representative with the Owner's approval may require that other materials or equipment of equal kind and quality be provided at no additional cost to the Owner.

§ 9.3.6 The Contractor shall carefully inspect all materials delivered on and to the Project site and reject defective materials without waiting for the Architect or Owner to observe the materials.

§9.3.7 The Contractor shall deliver, handle, store and install materials in accordance with manufacturers' or suppliers' instructions.

§9.3.8 Before ordering any material or doing any Work, the Contractor shall verify all measurements at the Project Site and Contractor shall be responsible for the correctness of same. No extra charge or compensation will be allowed to the Contractor on account of any difference between actual dimensions and the measurements shown by the Project Drawings.

§9.3.9 If any person employed by the Contractor on the Work shall appear to the Owner to be incompetent or conduct himself in a disorderly or improper manner, such person or persons shall be removed from the Work immediately on the request of the Owner. Said removal shall not create any additional cost to Owner and shall not extend the time for completion of the Work.

...

The Contractor warrants to the Owner and Architect that materials and equipment furnished under the Contract will be of good quality and new unless the Contract Documents require or permit otherwise. The Contractor further warrants that the Work will conform to the requirements of the Contract Documents and will be free from defects, ~~except for those inherent in the quality of the Work the Contract Documents require or permit.~~ faults and defects. Work, materials, or equipment not conforming to these requirements may be considered defective. The Contractor's warranty excludes remedy for damage or defect caused by abuse, alterations to the Work ~~not executed by the Contractor,~~ of persons other than Contractor or subcontractor, improper or insufficient maintenance, improper operation or normal wear and tear under normal usage. All other warranties required by the Contract Documents shall be issued in the name of the Owner, or shall be transferable ~~to the Owner, and shall commence in accordance with Section 15.6.3 to the Owner.~~ Inability, failure or refusal of the Subcontractor or supplier responsible for the defective materials, equipment or Work to correct the same shall not excuse the Contractor from performing under the warranty.

If required by the Architect or the Owner, the Contractor shall furnish satisfactory evidence as to the kind and quality of materials being furnished.

All warranties shall include labor and materials and shall be signed by the manufacturer or subcontractor as the case may be and countersigned by the Contractor. All warranties shall be addressed to the Owner and delivered to the Owner upon completion of the Work and before or with the submission of request for final payment. Except as otherwise provided in this Agreement or elsewhere in the Contract Documents, or in any Certificate of Substantial or Partial Completion approved by the Owner and Contractor and/or subcontractor, as applicable, all warranties shall become effective on the date of Substantial Completion of the entire Work unless otherwise provided in any Certificate of Partial or Substantial Completion approved by the Owner and the Contractor or Subcontractor, as applicable, but only with respect to warranties for that specific portion of the Work, and shall run for a twenty-four (24) month period, unless a longer period is provided for in the Contract Documents or by law. Where warranties overlap, the more stringent requirement shall govern. The Contractor shall consult with the Owner prior to the submission of any application to the appropriate permitting agency or authority in order to afford Owner the opportunity to obtain a waiver or reduction of any fees or costs associated therewith.

Defective materials, equipment or workmanship occurring within the Warranty period may be repaired where such produces results conforming to the Contract Documents relating to appearance, performance and reliability. Where the nature of the defective materials, equipment or workmanship is such that acceptable results cannot be obtained by repair, such defective items shall be removed and replaced with new materials, equipment or workmanship complying with the Contract Documents.

PAGE 12

The Contractor shall pay sales, consumer, use, and other similar taxes that are legally enacted when bids are received or negotiations concluded, whether or not yet effective or merely scheduled to go into effect. Because the Owner is an Illinois unit of local government, the Illinois sales tax is not applicable to materials, equipment and supplies incorporated in the Work or wholly consumed in the performance of the Work. The Owner will provide its sales tax exemption number for use by Contractor in purchasing such materials, equipment and supplies for this Project.

...

§ 9.6.2 The Contractor shall comply with and give notices and permit inspections required by applicable laws, statutes, ordinances, codes, rules and regulations, and lawful orders of public authorities applicable to performance of the Work or having jurisdiction over the Work. The Contractor shall promptly notify the Architect and Owner if any of the Contract Documents appear to be a variance therewith. If the Contractor performs Work knowing it to be contrary to applicable laws, statutes, ordinances, codes, rules and regulations, or lawful orders of public authorities, or had it carried out its obligations under the Contract Documents generally, and Section 9.1.1 of this Agreement in particular, should reasonably have known it to be contrary to applicable laws, statutes, ordinances, codes, rules and regulations, or lawful orders of public authorities, the Contractor shall assume appropriate responsibility for such Work and shall bear the costs attributable to correction.

PAGE 13

The Contractor shall confine operations at the site to areas permitted by applicable laws, statutes, ordinances, codes, rules and regulations, lawful orders of public authorities, ~~and~~ the Contract Documents and as otherwise directed by Owner and shall not unreasonably encumber the site with materials or equipment.

§ 9.10.1 Parking & Traffic.

.1 Parking of construction vehicles on the site by the Contractor shall not inhibit construction nor prevent access for emergency or other official vehicles. Parking of private vehicles on the site by the Contractor is prohibited unless said vehicle is necessary in the execution of the Contract. No construction vehicles shall be parked near or under any existing vegetation on the site.

.2 Construction traffic and staging shall be permitted only within construction limits as indicated on plan. Contractor is responsible for repair of any areas disturbed outside of this area, including grading and sodding. No staging will be permitted on existing asphalt without Owner's prior written consent. The cost to repair any damage to existing asphalt will be back-charged to the Contractor.

§ 9.10.2 Fencing. Contractor will be responsible for erecting and maintaining construction fencing around the limits of the Project site at all times of construction in accordance with applicable law and the Contract Documents. Failure to erect or maintain this fencing will result in the correction of the problem by the Owner at the expense of the Contractor, and may include, but are not limited to, the cost of any materials and staff time. This fence must be installed and fully erected before construction operations beginning and tied-up at the end of each working day.

§ 9.10.3 Water Removal. If, during construction, standing water caused by heavy rains or poor drainage becomes a hazard in the proper execution of the Contract, it shall be the responsibility of the Contractor to provide and make payment for removal of said water to existing drainage swales, storm sewers or other natural or man-made drainage ways.

PAGE 14

The Contractor shall keep the premises and surrounding area free from accumulation of waste materials and rubbish caused by operations under the Contract. At completion of the Work, the Contractor shall ~~remove~~ remove, and properly and lawfully dispose of as applicable, waste materials, rubbish, the Contractor's tools, construction equipment, machinery, and surplus material from and about the Project. The Contractor shall clean up and keep all streets, sidewalks and other public ways used for access to the Project site free from accumulation of spillage of fill or soils or other materials caused by operations under the Contract. The Contractor shall strictly comply with all laws and regulations pertaining to same be solely responsible for, and shall pay any fines or penalties assessed as the result of, any violation.

...

§ 9.15.1 To the fullest extent permitted by law, the Contractor ~~waives any rights of contribution against, and shall indemnify and hold harmless the Owner, Architect, Architect's consultants, and agents and employees of any of them from and against claims, damages, losses and expenses, including but not limited to attorneys' fees, Owner and its officers, officials, employees, volunteers and agents from and against all claims, damages, losses and expenses including but not limited to legal fees (attorney's and paralegals' fees and court costs), arising out of or resulting from the performance of the Work, Contractor's work, provided that any such claim, damage, loss, loss or expense (i) is attributable to bodily injury, sickness, disease or death, or to injury to or destruction of tangible property (other than the Work itself), but only to the extent caused by the negligent acts or omissions of the Contractor, a property, other than the work itself, including the loss of use resulting there from and (ii) is caused in whole or in part by any wrongful or negligent act or omission of the Contractor, any Subcontractor, anyone directly or indirectly employed by them, any of them or anyone for whose acts they any of them may be liable, regardless of whether or not such claim, damage, loss, or expense it is caused in part by a party indemnified hereunder. Such obligation shall not be construed to negate, abridge, or reduce other rights or obligations otherwise reduce any other right or obligation of indemnity which would otherwise exist as to a party or person described in this Section 9.15.1, any party or person described in this Paragraph. Contractor shall similarly protect, indemnify and hold and save harmless the Owner, its officers, officials, employees, volunteers and agents against and from any and all claims, costs, causes, actions and expenses including but not limited to legal fees, incurred by reason of Contractor's breach of any of its obligations under, or Contractor's default of, any provision of the Contract.~~

"Claims," "damages," "losses" and "expenses" as these words are used in this Agreement shall be construed to include, but not limited to (1) injury or damage consequent upon the failure of or use or misuse by Contractor, its subcontractors, agents, servants or employees, of any hoist, rigging, blocking, scaffolding, or any and all other kinds of items of equipment or other mechanical or structural contrivance erected or constructed by any person, or any or all other kinds of equipment whether or not the same be owned, furnished or loaned by Owner; (2) all attorneys' fees and costs incurred in bringing an action to enforce the provisions of this indemnity or any other indemnity contained herein; (3) all costs and expenses incurred by the indemnified party; and (4) error or omission or defect in any submission made to Architect / Architect for its approval or review.

PAGE 15

§ 10.2 Duties, responsibilities, and limitations of authority of the Architect as set forth in the Contract Documents shall not be restricted, modified, or extended without written consent of the ~~Owner, Contractor, Owner~~ and Architect. Consent shall not be unreasonably withheld.

...

§ 10.5 Based on the Architect's evaluations of the quality and progress of the Work and of the Contractor's Applications for Payment, the Architect will review and certify the amounts due the Contractor and will issue Certificates for Payment in such amounts.

PAGE 16

§ 11.2 Unless otherwise stated in the Contract Documents, the Contractor, as soon as practicable after award of the Contract, shall notify the Owner and Architect of the Subcontractors or suppliers in writing of the name, trade and subcontract amount of each Subcontractor and supplier proposed for each of the principal portions of the Work. The Contractor shall not contract with any Subcontractor or supplier to whom the Owner or Architect has made reasonable written objection within ten days after receipt of the Contractor's written list of Subcontractors and suppliers. If the proposed but rejected Subcontractor was reasonably capable of performing the Work, the Contract Sum and Contract Time shall be increased or decreased by the difference, if any, occasioned by such change, and an appropriate Change Order shall be issued before commencement of the substitute Subcontractor's Work. The Contractor shall not be required to contract with anyone to whom the Contractor has made reasonable objection.

...

§ 11.4 All subcontracts shall be in writing and shall specifically provide that the Owner is an intended third-party beneficiary of such subcontract and that the Owner shall have the right to enforce the Subcontractor's obligations thereunder after the occurrence of a default under the Contract by the contractor. Each subcontract agreement shall preserve and protect the rights of the Owner and Architect under the Contract Documents with respect to the Work to be performed by the Subcontractor so that subcontracting thereof will not prejudice such rights, and shall allow to the Subcontractor, unless specifically provided otherwise in the subcontract agreement, the benefit of all rights, remedies and redress against the Contractor that the Contractor, by these Contract Documents, has against the Owner. Where appropriate, the Contractor shall require each Subcontractor to enter into similar written agreements with Sub-subcontractors. The Contractor shall make available to each proposed Subcontractor, prior to the execution of the subcontract agreement, copies of the Contract Documents to which the Subcontractor will be bound, and upon written request of the Subcontractor, identify to the Subcontractor terms and conditions of the proposed subcontract agreement which may be at variance with the Contract Documents. Subcontractors shall similarly make copies of applicable portions of such documents available to their representatives proposed Sub-subcontractors.

§ 11.5 All subcontract agreements shall conform to the requirements of the Contract Documents and the Contractor hereby irrevocably assigns to the Owner and Owner's permitted assigns all its interest in any subcontract agreements and purchase orders now existing or hereinafter entered into the contractor for performance of any part of the Work, which assignment will be effective in the event of the Contractor's failure to perform the Work in accordance with the Contract Documents and upon acceptance by the Owner in writing and only as to those subcontract agreements and purchase orders that Owner designates in said writing. It is agreed and understood that the Owner may accept said assignment at any time during the course of construction prior to Final Completion. The Contractor shall promptly submit to the Owner a true and complete copy of each subcontract upon execution of same. Each subcontract shall contain a contingent assignment of the subcontract to the Owner, consistent with this Subparagraph. Upon acceptance by the Owner of a subcontract: (1) the Contractor shall promptly furnish to the Owner true and complete copies of the designated subcontract agreements and purchase orders, both as may have been amended by approved change order together with copies of any and all such amendments, and (2) the Owner shall only be required to compensate the designated Subcontractor(s) or supplier(s) for compensation accruing to such party(ies) for Work done or materials delivered from and after the date on which the Owner accepts the subcontract agreement(s) or purchase order(s). All sums due and owing by the Contractor to the designated Subcontractor(s) or supplier(s) for work performed or material supplied prior to the Owner's acceptance of the subcontract agreement(s) or purchase order(s) shall constitute a debt between such parties and the Contractor. It is further agreed that no subcontract agreement or purchase order shall contain any restriction that would prohibit assignment under the terms and conditions stated hereinabove. It is further agreed and understood that such assignment is part of the consideration to Owner for entering into the Contract with the Contractor and may not be withdrawn prior to Final Completion.

PAGE 17

§ 13.4 If concealed or unknown physical conditions are encountered at the site that differ materially from those indicated in the Contract Documents or from those conditions ordinarily found to exist, and the Contractor could not

have discovered same in the exercise of reasonable diligence as required under Subsection 9.1.1 of this Agreement, the Contract Sum and Contract Time shall be equitably adjusted as mutually agreed between the Owner and Contractor; provided that the Contractor provides notice to the Owner and Architect promptly and before conditions are disturbed.

§ 13.5 Agreement on any Change Order shall constitute a final settlement, and accord and satisfaction between the Owner and Contractor, of all matters relating to the change in the Work which is the subject of the Change Order, including, but not limited to, all direct and indirect costs associated with such change and any and all adjustments to the Contract Sum, Contract Time and Construction Schedule. In the event a Change Order increases the Contract Sum, the Contractor shall include the Work covered by such Change Order in Applications for Payment as if such Work were originally part of the Contract Documents.

§ 13.6 No change in the Work, whether by way of alteration or addition to the Work, shall be the bases of an addition to the Contract Sum or change in the Contract Time unless and until such alteration or addition has been authorized by a Change Order executed and issued in accordance with and in strict compliance with the requirements of the Contract Documents and applicable law. Accordingly, no course of conduct or dealing between the parties, nor any express or implied acceptance of alterations or additions to the Work and no claim that the Owner has been unjustly enriched shall be the basis of any claim to an increase in the Contract Sum or change in the Contract Time.

PAGE 18

§ 14.2 Unless otherwise provided, Contract Time is the period of time, including authorized adjustments, allotted in the Contract Documents for Substantial Completion and for Final Completion of the Work.

...

§ 14.4 The date of Substantial Completion is the date and Final Completion are the dates certified by the Architect in accordance with Section 15.6.3.

§ 14.5 If the Contractor is delayed at any time in the commencement or progress of the Work by (1) changes ordered in the Work; (2) by labor disputes, fire, unusual delay in deliveries, abnormal adverse weather conditions not reasonably anticipatable, unavoidable casualties, or any causes beyond the Contractor's control; or (3) by other causes that the Contractor asserts, and the Architect determines, justify delay, then determines and Owner agrees, justify delay, then, as the Contractor's sole remedy, the Contract Time shall be extended for such reasonable time as the Architect may determine, subject to the provisions of Article 21 determine. Notwithstanding the foregoing, delays of the Contractor to carry out its obligations under or in accordance with the provisions of the Contract, shall not extend the Contract Time.

§ 14.6 The Contractor shall carry the Work forward regularly, diligently, uninterruptedly and expeditiously and in a good workmanlike and professional manner at such a rate of progress and with an adequate work force as will insure the completion of the Work in accordance with the Contract Documents by the date established in the Contract. It is expressly understood and agreed by and between Contractor and Owner that the time for completion of the Work is a reasonable time, taking into consideration the average climatic range, usual industrial conditions, and all other conditions and actors prevailing in this locality.

PAGE 19

§ 15.3.3 ~~Payments~~ Unless approved in advance by the Owner in writing, payments shall be made on account of materials and equipment incorporated in the Work. If approved in advance by the Owner payment shall be made on account of materials and equipment delivered and suitably stored and protected from damage and loss at the site for subsequent incorporation in the Work. If approved in advance by the Owner, payment may similarly be made for materials and equipment delivered and suitably stored, and protected from damage, damage and loss, off the site at a location agreed upon in writing. The Owner may condition such approvals on such terms as the Owner in its discretion deems necessary for its protection.

...

§ 15.3.5 Failure to supply waivers of lien or acceptable evidence of payment of all current accounts incurred by this Contract work will be considered grounds for withholding final payment.

§ 15.3.6 The first payment application shall be accompanied by the Contractor's Partial Waiver of Lien only, for the full amount of the payment. Each subsequent monthly payment application shall be accompanied by the Contractor Partial Waiver, and by the Partial Lien Waivers of Subcontractor and Suppliers who were included in the immediately preceding payment application to the extent of that payment. Application for Final Payment shall be accompanied by Final Waivers of Lien from the Contractor, Subcontractors and Suppliers who have not previously furnished such Final Waivers. Final Waivers shall be for the full amount of the Contract. All applications for payment shall be accompanied by affidavits, in triplicate, from the Contractor and Subcontractors containing such information and in such form as to comply with the Illinois Mechanics Lien Act (770 ILCS 60/0.01 et seq.) and showing in detail the sources of all labor and materials used and contracted to be used on the Project, including names and addresses of subcontractors and material suppliers; amounts paid and remaining to be paid to each; together with all documents as shall be necessary, in the sole judgment of the Architect and Owner, to waive all claims of liens to date and comply with all applicable state and local laws.

- (i) All waivers (partial and final) shall include language as applicable indicating either that:
- a. all material were taken from fully paid stock and delivered to job site in our own vehicles and all labor has been fully paid in accordance with prevailing wage laws; or
 - b. materials were provided by the following suppliers for whom waivers of lien are attached and all labor has been fully paid in accordance with prevailing wage laws.

PAGE 20

§ 15.4.2 The issuance of a Certificate for Payment will constitute a representation by the Architect to the Owner, but not to Contractor, based on the Architect's evaluations of the Work and the data in the Application for Payment, that, to the best of the Architect's knowledge, information, and belief, the Work has progressed to the point indicated, the quality of the Work is in accordance with the Contract Documents, and the Contractor is entitled to payment in the amount certified. The foregoing representations are subject to an evaluation of the Work for conformance with the Contract Documents upon Substantial Completion, to results of subsequent tests and inspections, to correction of minor deviations from the Contract Documents prior to completion and to specific qualifications expressed by the Architect. The issuance of a Certificate for Payment will further constitute a representation to the Owner but not to the Contractor that the Contractor is entitled to payment in the amount certified. However, the issuance of a Certificate for Payment will not be a representation that the Architect has (1) made exhaustive or continuous on-site inspections to check the quality or quantity of the Work; (2) reviewed construction means, methods, techniques, sequences, or procedures; (3) reviewed copies of requisitions received from Subcontractors and suppliers and other data requested by the Owner to substantiate the Contractor's right to payment; or (4) made examination to ascertain how or for what purpose the Contractor has used money previously paid on account of the Contract Sum.

PAGE 21

- .7 ~~repeated~~ failure to carry out the Work in accordance with the Contract Documents.

§ 15.4.4 When either party disputes the Architect's decision regarding a Certificate for Payment under Section 15.4.3, in whole or in part, that party may submit a Claim in accordance with Article 21 the above reasons for withholding certification are removed. certification will be made for amounts previously withheld. No interest will be paid on amounts withheld.

...

§ 15.5.1 The Contractor shall pay each Subcontractor, no later than seven days after receipt of payment from the Owner, the amount to which the Subcontractor is entitled, reflecting percentages actually retained from payments to the Contractor on account of the Subcontractor's portion of the Work. The Contractor shall, by appropriate agreement with each Subcontractor, require each Subcontractor to make payments to sub-subcontractors in a similar manner. This provision is not to be construed as a "conditional payment" or "pay when paid" clause. In the event that payment to the Contractor is delayed without fault of the Subcontractor, payment to the Subcontractor shall be made within a reasonable time after work is properly performed by a Subcontractor irrespective of any delay in payment to the Contractor.

...

~~§ 15.5.4 Provided the Owner has fulfilled its payment obligations under the Contract Documents, the Contractor shall defend and indemnify the Owner from all loss, liability, damage or expense, including reasonable attorney's fees and litigation expenses, arising out of any lien claim or other claim for payment by any Subcontractor or supplier of any tier. Upon receipt of notice of a lien claim or other claim for payment, the Owner shall notify the Contractor. If approved by the applicable court, when required, the Contractor may substitute a surety bond for the property against which the lien or other claim for payment has been asserted.~~

~~§ 15.5.5 Anything to the contrary contained or implied herein notwithstanding, no progress payment need be made by Owner until such time as Contractor, Subcontractors or any other persons performing the Work or furnishing materials or equipment for the Project furnishes such documents as Owner may reasonably require (including without limitation sworn notarized contractor's statement, affidavits and waivers of lien).~~

...

~~§ 15.6.1 Substantial Completion is the stage in the progress of the Work when the Work or designated portion thereof is sufficiently complete completed in accordance with the Contract Documents so that the Owner can occupy or utilize the Work for its intended use. for its intended use and has been accepted by Owner to receive all required occupancy permits.~~

~~"Punch List" mean and shall be limited to uncompleted items of Work (a) that do not interfere with the use and occupancy of any area of the Site for its intended purpose and (b) that, as a group, are capable of being completed by the Contractor within thirty (30) days of issuance of any Punch List. The "Punch List" is the list containing the Punch List Items.~~

...

~~§ 15.6.3 Upon receipt of the Contractor's list, the Architect and Owner will make an inspection to determine whether the Work or designated portion thereof is substantially complete. If the Architect's or Owner's inspection discloses an item, whether or not included in the Contractor's list, which is not in accordance with the Contract Documents and is necessary for Owner's occupancy or utilization of the Work, the Contractor shall before issuance of a Certificate of Substantial Completion, complete such items upon notification from the Architect and Owner. The cost of this and any additional inspections required to establish Substantial Completion due to the failure of the Contractor to properly complete all items of the Work necessary for the Owner's use or occupancy of the Work shall be charged to the Contractor. When the Architect determines that the Work or designated portion thereof is substantially complete, the Architect will issue a Certificate of Substantial Completion to the Owner for review and concurrence by the Owner which shall establish the date of Substantial Completion; establish responsibilities of the Owner and Contractor for security, maintenance, heat, utilities, damage to the Work and insurance; and fix the time within which the Contractor shall finish all items on the ~~list~~ Punch List accompanying the Certificate. Warranties required by the Contract Documents shall commence on the date of Substantial Final Completion of the Work or designated portion thereof unless otherwise provided in the Certificate of Substantial Completion with the exception of the items of Work contained in the Punch List accompanying the Certificate of Substantial Completion. With respect to Work enumerated on the Punch List, the guarantee or warranty period shall commence upon Contractor's completion and Owner's approval of the Punch List items.~~

~~§ 15.6.4 The Certificate of Substantial Completion shall be submitted to the Owner and Contractor for their written acceptance of responsibilities assigned to them in the Certificate. Upon such acceptance and consent of surety, if any, the Owner shall make payment of retainage applying to the Work or designated portion thereof. Such payment shall be adjusted for Work that is incomplete or not in accordance with the requirements of the Contract Documents.~~

PAGE 22

~~§ 15.7.1 Upon receipt of the Contractor's notice that the Work is ready for final inspection and acceptance and upon receipt of a final Application for Payment, the Architect will promptly make such inspection and, when the Architect finds the Work acceptable under the Contract Documents and the Contract fully performed, and the Architect has advised Owner of that finding and Owner has not advised Architect of any objection to such finding, the Architect will~~

promptly issue a final Certificate for Payment to the Owner but not the Contractor stating that to the best of the Architect's knowledge, information and belief, and on the basis of the Architect's on-site visits and inspections, the Work has been completed in accordance with the Contract Documents and that the entire balance found to be due the Contractor and noted in the final Certificate is due and payable. The Architect's final Certificate for Payment will constitute a further representation that conditions stated in Section 15.7.2 as precedent to the Contractor's being entitled to final payment have been fulfilled. The Owner's failure to object to, and the Owner's acceptance of, the Architect's findings and/or certifications hereunder shall not constitute Owner's acceptance of Work not complying with the Contract Documents, or Owner's waiver of any claims or remedies it may have with respect to any such defective or delayed Work.

§ 15.7.2 Final payment shall not become due until the Contractor has fully performed the contract, including but not limited to, delivery of all manufacturer's and supplier's warranties, operating manuals, as-built drawings, and consent of the surety to final payment, pursuant to the Contract Documents, and has delivered to the Owner a complete release of all liens arising out of this Contract or receipts in full covering all labor, materials and equipment for which a lien could be filed, or a bond satisfactory to the Owner to indemnify the Owner against such lien. If such lien remains unsatisfied after payments are made, the Contractor shall refund to the Owner all money that the Owner may be compelled to pay in discharging such lien, including costs and reasonable attorneys' fees.

...

The final payment by Owner shall not relieve the Contractor of the responsibility for the correction of any and all defects in the work performed. Contractor shall correct all defects as notified for the applicable warranty period after final payment.

PAGE 23

§ 17.1.1 The Contractor shall purchase and maintain insurance of the types and limits of liability, containing the endorsements, and subject to the terms and conditions, as described in this Section 17.1 ~~or elsewhere and~~ in the Contract Documents. The Contractor shall purchase and maintain the insurance required by this Agreement from an insurance company or insurance companies lawfully authorized to issue insurance in the jurisdiction where the Project is located. Contractor shall procure insurance from insurance companies that have obtained A.M. Best ratings no less than A VII using the most recent edition of the A.M. Best's Key Rating Guide. If the Best's rating is less than A VII or a Best's rating is not obtained, the Owner has the right to reject insurance written by an insurer it deems unacceptable. Failure to maintain the required insurance may result in termination of the Contract at Owner's option. Owner shall have the right, but not the obligation, of prohibiting Contractor or any Subcontractor from entering the Project site until such certificates or other evidence that insurance has been placed in complete compliance with these requirements is received and approved by Owner.

...

Contractor shall maintain commercial general liability (CGL) and, if necessary, commercial umbrella liability insurance with a limit of not less than \$2,000,000 each occurrence for at least three years following Substantial Completion of the Work.

§ 17.1.2 Commercial General Liability insurance for the Project written on an occurrence form with policy limits of not less than ~~(\$) each occurrence, (\$) general aggregate, and (\$) aggregate for products-completed operations hazard,~~ Two Million Dollars (\$ 2,000,000) each occurrence. Two Million Dollars (\$ 2,000,000) general aggregate, which shall apply separately to this project, and Two Million Dollars (\$ 2,000,000) each occurrence for products-completed operations hazard for at least three years following Completion of the Work, providing coverage for claims including

PAGE 24

.5 the Contractor's indemnity obligations under Section 9.15.

CGL insurance shall be written on Insurance Services Office (ISO) occurrence form CG 00 01 04 13, or a substitute form providing equivalent coverage, and shall also cover liability arising from premises, operations, independent contractors,

and liability assumed under an insured contract (including the tort liability of another assumed in a business contract)

This insurance shall apply as primary insurance with respect to any other insurance or self-insurance afforded to Owner.

There shall be no endorsement or modification of the CGL limiting the scope of coverage for liability arising from pollution, explosion, collapse, or underground property damage.

For Contractor's Continuing Completed Operations Liability Insurance:

Continuing CGL insurance shall be written on ISO occurrence form CG 00 01 4 13, or substitute form providing equivalent coverage, and shall, at minimum, cover liability arising from products-completed operations and liability assumed under an insured contract.

Continuing CGL insurance shall have a products-completed operations aggregate of at least two times its each occurrence limit.

Continuing commercial umbrella coverage, if any, shall include liability coverage for damage to the insured's completed work equivalent to that provided under ISO form CG 00 01.

§ 17.1.3 Automobile Liability covering vehicles owned by the ~~Contractor~~ Contractor, hired, and non-owned vehicles used by the Contractor, with policy limits of not less than One Million Dollars (\$ 1,000,000) per accident, for bodily injury, death of any person, and property damage arising out of the ownership, maintenance, and use of those motor vehicles along with any other statutorily required automobile coverage. Business auto insurance shall be written Insurance Services Office (ISO) form CA 00 01, CA 00 05, CA 00 12, CA 00 20, or a substitute form providing equivalent liability coverage. If necessary, the policy shall be endorsed to provide contractual liability coverage equivalent to that provided in the 1990 and later editions of CA 00 01.

...

§ 17.1.5 Workers' Compensation ~~at statutory limits.~~

Contractor shall maintain workers compensation as required by statute and employers liability insurance. The commercial umbrella and/or employers liability limits shall not be less than \$1,000,000 each accident for bodily injury by accident of \$1,000,000 each employee for bodily injury by disease.

If Owner has not been included as an insured under the CGL using ISO additional insured endorsement CG 20 10 under the Commercial General and Umbrella Liability Insurance required in this Contract, the Contractor waives all rights against Owner and its officers, officials, employees, volunteers and agents for recovery of damages arising out of or incident to the Contractor's Work.

§ 17.1.6 Employers' Liability with policy limits not less than One Million Dollars (\$ 1,000,000) each accident, One Million Dollars (\$ 1,000,000) each employee, and One Million Dollars (\$ 1,000,000) policy limit.

§ 17.1.7 ~~If the Contractor is required to furnish professional services as part of the Work, the Contractor shall procure Professional Liability insurance covering performance of the professional services, with policy limits of not less than (\$) per claim and (\$) in the aggregate.~~

Intentionally deleted.

§ 17.1.8 ~~If the Work involves the transport, dissemination, use, or release of pollutants, the Contractor shall procure Pollution Liability insurance, with policy limits of not less than (\$) per claim and (\$) in the aggregate.~~

Intentionally deleted.

§ 17.1.9 ~~Coverage under Sections 17.1.7 and 17.1.8 may be procured through a Combined Professional Liability and Pollution Liability insurance policy, with combined policy limits of not less than (\$) per claim and (\$) in the aggregate.~~

Intentionally deleted.

§ 17.1.10 The Contractor shall provide certificates of insurance acceptable to the Owner evidencing compliance with the requirements in this Section 17.1 at the following times: (1) prior to commencement of the Work; (2) upon renewal or replacement of each required policy of insurance; and ~~(3) upon~~ (3) within 10 days' upon the Owner's written request. An additional certificate evidencing continuation of liability coverage, including coverage for completed

operations, shall be submitted with the final Application for Payment and thereafter upon renewal or replacement of such coverage until the expiration of the period required by ~~Section 17.1.1. The certificates will show the Owner~~ Section 17.1.1 or upon Owner's written request for the same. The certificates will show the Owner, its elected and appointed officials, employees, volunteers and agents as an additional insured on the Contractor's Commercial General Liability and excess or umbrella liability policy. Failure of Owner to demand such certificate, endorsement or other evidence of full compliance with these insurance requirements or failure of Owner to identify a deficiency from evidence that is provided shall not be construed as a waiver of Contractor's obligation to maintain such insurance.

§ 17.1.11 The Contractor shall disclose to the Owner any deductible or self-insured retentions applicable to any insurance required to be provided by the Contractor. At the option of the Owner, the Contractor may be asked to eliminate such deductibles or self-insured retentions as respects the Owner, its officers, officials, employees, volunteers and agents or required to procure a bond guaranteeing payment of losses and other related costs including but not limited to investigations, claim administration and defense expenses.

§ 17.1.12 To the fullest extent permitted by law, the Contractor shall cause the commercial liability coverage required by this Section 17.1 to include (1) the Owner, the Architect, and the Architect's Consultants as additional insureds Owner, its elected and appointed officials, employees, volunteers and agents for claims caused in whole or in part by the Contractor's negligent acts or omissions during the Contractor's operations; and (2) the Owner as an additional insured for claims caused in whole or in part by the Contractor's negligent acts or omissions for which loss occurs during completed operations. The additional insured coverage shall be primary and non-contributory to any of the Owner's general liability insurance policies and shall apply to both ongoing and completed operations. ~~To the extent commercially available, the~~ The additional insured coverage shall be no less than that provided by Insurance Services Office, Inc. (ISO) forms CG 20 10 07 04, CG 20 37 07 04, and, with respect to the Architect and the Architect's Consultants, CG 20 32 07 04 or a substitute providing equivalent coverage, and under the commercial umbrella, if any. . .

If Contractor's liability policies do not contain the standard ISO separation of insured's' provision, or a substantially similar clause, they shall be endorsed to provide cross-liability coverage.

§ 17.1.13 ~~Within three (3) business days of the date the Contractor becomes aware of an impending or actual cancellation or expiration of any insurance required by this Section 17.1, the Contractor shall provide notice to the Owner of such impending or actual cancellation or expiration. All certificates shall provide for 30 days' written notice to Owner prior to the cancellation or material change of any insurance referred to therein. Written notice to Owner shall be by certified mail, return receipt requested. Upon receipt of notice from the Contractor, the Owner shall, unless the lapse in coverage arises from an act or omission of the Owner, have the right to either stop the Work until the lapse in coverage has been cured by the procurement of replacement coverage by the Contractor. The Contractor or terminate the contract, at Owner's option. In the event Owner does not terminate, the furnishing of notice by the Contractor shall not relieve the Contractor of any contractual obligation to provide any required coverage.~~

PAGE 25

Contractor shall cause each Subcontractor employed by Contractor to purchase and maintain insurance of the type specified above. When requested by the Owner, Contractor shall furnish copies of certificates of insurance evidencing coverage for each Subcontractor.

PAGE 26

§ 17.2.1 Owner's Liability Insurance

~~The Owner shall be responsible for purchasing and maintaining the Owner's usual liability insurance.~~

Unless otherwise provided, the Owner shall purchase and maintain, in a company or companies lawfully authorized to do business in the jurisdiction in which the Project is located, property insurance in the amount of the initial Contract Sum as well as subsequent modifications thereto for the entire Work at the site on a replacement cost basis without voluntary deductibles. Such property insurance shall be maintained, unless otherwise provided in the Contract Documents or otherwise agreed in writing by all persons and entities who are beneficiaries of such insurance, until final payment has been made as provided in Article 15.7 or until no person or entity other than the Owner has an insurable interest in the property required by this Paragraph 17.2.1 to be covered, whichever is earlier. This insurance shall include the respective interests of the Owner, the Contractor, Subcontractors and Sub-subcontractors in the Work.

Additions and Deletions Report for AIA Document A104™ – 2017 (formerly A107™ – 2007). Copyright © 1936, 1951, 1958, 1961, 1963, 1966, 1970, 1974, 1978, 1987, 1997, 2007 and 2017 by The American Institute of Architects. All rights reserved. **WARNING: This AIA® Document is protected by U.S. Copyright Law and International Treaties. Unauthorized reproduction or distribution of this AIA® Document, or any portion of it, may result in severe civil and criminal penalties, and will be prosecuted to the maximum extent possible under the law.** This document was produced by AIA software at 15:57:50 ET on 02/20/2020 under Order No.8830539077 which expires on 06/25/2020, and is not for resale.

User Notes:

(1899329843)

§ 17.2.2 Property Insurance Property insurance shall be on a course of construction policy form and shall insure against the perils of fire and extended coverage and physical loss or damage including, without duplication of coverage, theft, vandalism, malicious mischief, collapse, false work, windstorm, testing and start-up, temporary buildings and debris removal, including demolition, and shall cover reasonable compensation for the Architect's, any of the Owner's Consultant's services and expenses required as a result of such insured loss. Coverage for other perils shall not be required unless otherwise provided in the Contract Documents. Property insurance provided by the Owner shall not cover Contractor's, Subcontractor's or Sub-subcontractor's liability or any tools, apparatus, machinery, scaffolding, hoists, forms, staging, shoring or other similar items commonly referred to as construction equipment which may be on the site and the capital value of which is not included in the Work. The Contractor shall make his own arrangements for any insurance he may require on such construction equipment.

§ 17.2.2.1 The Owner shall purchase and maintain, from an insurance company or insurance companies lawfully authorized to issue insurance in the jurisdiction where the Project is located, property insurance written on a builder's risk "all risks" completed value or equivalent policy form and sufficient to cover the total value of the entire Project on a replacement cost basis. The Owner's property insurance coverage shall be no less than the amount of the initial Contract Sum, plus the value of subsequent Modifications and labor performed or materials or equipment supplied by others. The property insurance shall be maintained until Substantial Completion and thereafter as provided in Section 17.2.2.2, unless otherwise provided in the Contract Documents or otherwise agreed in writing by the parties to this Agreement. This insurance shall include the interests of the Owner, Contractor, Subcontractors, and Sub-subcontractors in the Project as insureds. This insurance shall include the interests of mortgagees as loss payees.

§ 17.2.2.2 Unless the parties agree otherwise, upon Substantial Completion, the Owner shall continue the insurance required by Section 17.2.2.1 or, if necessary, replace the insurance policy required under Section 17.2.2.1 with property insurance written for the total value of the Project that shall remain in effect until expiration of the period for correction of the Work set forth in Section 18.4.

§ 17.2.2.3 If the insurance required by this Section 17.2.2 is subject to deductibles or self-insured retentions, the Owner shall be responsible for all loss not covered because of such deductibles or retentions.

§ 17.2.2.4 If the Work involves remodeling an existing structure or constructing an addition to an existing structure, the Owner shall purchase and maintain, until the expiration of the period for correction of Work as set forth in Section 18.4, "all risks" property insurance, on a replacement cost basis, protecting the existing structure against direct physical loss or damage, notwithstanding the undertaking of the Work. The Owner shall be responsible for all co-insurance penalties.

§ 17.2.2.5 Prior to commencement of the Work, the Owner shall secure the insurance, and provide evidence of the coverage, required under this Section 17.2.2 and, upon the Contractor's request, provide a copy of the property insurance policy or policies required by this Section 17.2.2. The copy of the policy or policies provided shall contain all applicable conditions, definitions, exclusions, and endorsements.

§ 17.2.2.6 Within three (3) business days of the date the Owner becomes aware of an impending or actual cancellation or expiration of any insurance required by this Section 17.2.2, the Owner shall provide notice to the Contractor of such impending or actual cancellation or expiration. Unless the lapse in coverage arises from an act or omission of the Contractor: (1) the Contractor, upon receipt of notice from the Owner, shall have the right to stop the Work until the lapse in coverage has been cured by the procurement of replacement coverage by either the Owner or the Contractor; (2) the Contract Time and Contract Sum shall be equitably adjusted; and (3) the Owner waives all rights against the Contractor, Subcontractors, and Sub-subcontractors to the extent any loss to the Owner would have been covered by the insurance had it not expired or been cancelled. If the Contractor purchases replacement coverage, the cost of the insurance shall be charged to the Owner by an appropriate Change Order. The furnishing of notice by the Owner shall not relieve the Owner of any contractual obligation to provide required insurance.

§ 17.2.2.7 Waiver of Subrogation

§ 17.2.2.7.1 The Owner and Contractor waive all rights against (1) each other and any of their subcontractors, sub-subcontractors, agents, and employees, each of the other; (2) the Architect and Architect's consultants; and (3) Separate Contractors, if any, and any of their subcontractors, sub-subcontractors, agents, and employees, for damages caused by fire, or other causes of loss, to the extent those losses are covered by property insurance required by this Agreement or other property insurance applicable to the Project, except such rights as they have to proceeds of such

insurance. The Owner or Contractor, as appropriate, shall require similar written waivers in favor of the individuals and entities identified above from the Architect, Architect's consultants, Separate Contractors, subcontractors, and sub-subcontractors. The policies of insurance purchased and maintained by each person or entity agreeing to waive claims pursuant to this Section 17.2.2.7 shall not prohibit this waiver of subrogation. This waiver of subrogation shall be effective as to a person or entity (1) even though that person or entity would otherwise have a duty of indemnification, contractual or otherwise, (2) even though that person or entity did not pay the insurance premium directly or indirectly, or (3) whether or not the person or entity had an insurable interest in the damaged property.

~~§ 17.2.2.7.2 If during the Project construction period the Owner insures properties, real or personal or both, at or adjacent to the site by property insurance under policies separate from those insuring the Project, or if after final payment property insurance is to be provided on the completed Project through a policy or policies other than those insuring the Project during the construction period, to the extent permissible by such policies, the Owner waives all rights in accordance with the terms of Section 17.2.2.7.1 for damages caused by fire or other causes of loss covered by this separate property insurance.~~

~~§ 17.2.2.8 A loss insured under the Owner's property insurance shall be adjusted by the Owner as fiduciary and made payable to the Owner as fiduciary for the insureds, as their interests may appear, subject to requirements of any applicable mortgagee clause. The Owner shall pay the Architect and Contractor their just shares of insurance proceeds received by the Owner, and by appropriate agreements, written where legally required for validity, the Architect and Contractor shall make payments to their consultants and Subcontractors in similar manner.~~

§ 17.2.3 Other Insurance Provided by the Owner

~~(List below any other insurance coverage to be provided by the Owner and any applicable limits.) The Contractor shall effect insurance which will protect the interests of the Contractor, Subcontractors and Sub-subcontractors in the Work.~~

~~§ 17.2.4 If the property insurance requires minimum deductibles and such deductibles are identified in the Contract Documents, the Contractor shall pay costs not covered because of deductibles. If the Owner or insurer increases the required minimum deductibles above the amounts so identified or if the Owner elects to purchase this insurance with voluntary deductible amounts, the Owner shall be responsible for payment of the additional costs not covered because of such increased or voluntary deductibles. If deductibles are not identified in the Contract Documents, the Owner shall pay costs not covered because of deductibles.~~

~~§ 17.2.5 Unless otherwise provided in the Contract Documents, this property insurance shall cover portions of the Work stored off the site and paid for by Owner after written approval of the Owner at the value established in the approval, and also portions of the Work in transit and paid for by Owner.~~

~~§ 17.2.6 Partial occupancy or use shall not commence until the insurance company or companies providing property insurance have consented to such partial occupancy or use by endorsement or otherwise. The Owner and the Contractor shall take reasonable steps to obtain consent of the insurance company or companies and shall, without mutual written consent, take no action with respect to partial occupancy or use that would cause cancellation, lapse or reduction of insurance.~~

~~§ 17.2.7 The Owner shall purchase and maintain boiler and machinery insurance required by the Contract Documents or by law, which shall specifically cover such insured objects during installation and until final acceptance by the Owner; this insurance shall include interests of the Owner, Contractor Subcontractors and Sub-subcontractors in the Work, and the Owner and the Contractor shall be named insureds.~~

~~§ 17.2.8 If the Contractor requests in writing that insurance for risks other than those described herein or other special causes of loss be included in the property insurance policy, the Owner shall, if possible, include such insurance, and the cost thereof shall be charged to the Contractor by appropriate Change Order.~~

~~§ 17.2.9 Notwithstanding any provision contained in Article 17, the Owner's obligation to purchase insurance shall herein be deemed satisfied by the Owner's membership in a self-insured risk management agency or pool. The Contractor agrees that any obligation the Owner has to purchase property insurance shall be satisfied by the Owner's membership in a self-insured risk management agency or pool. The Contractor further agrees that it will only have rights allowable to it under any coverage provided through the Owner's membership in a self-insured risk management agency or pool.~~

Omitted.

Coverage

Limite

PAGE 27

§ 17.3.3 If required by the Owner the Contractor, before commencing the Work, shall furnish a Performance Bond and a Labor and Material Payment Bond. The Performance Bond shall be in an amount equal to 110% of the full amount of the Contract Sum as security for the faithful performance of the obligations of the Contract Documents, including the payment of prevailing wages in accordance with Article 23 of this Agreement, and the Labor and Material Payment Bond shall be in an amount equal to 110% of the full amount of the Contract Sum as security for required payments to all persons performing labor and furnishing materials in connection with the Work. Such bonds shall be on AIA Document A-312, or the most current edition, issued by the American Institute of Architects, shall be issued by a surety satisfactory to the Owner, and shall name the Owner as primary co-obligee. Such bonds shall be from an Illinois Admitted Bonding Company acceptable to the Owner and having a minimum policy holder rating of "B+" in the latest edition of Best's Insurance Guide in effect as of the date of the Contract. Bonds shall remain in full force and effect for at least one year following the date of Final Completion of the Work or for the entire duration of the longest warranty period provided for the Work, whichever is longer. The cost of the bonds is to be included in the Contract Sum stated by the Contractor in its Bid Proposal.

§17.3.4 The Contractor shall (i) furnish with all bonds a certified copy of the power of attorney from the Surety Company stating that the person executing said bond is duly authorized by the Surety Company to execute said bond; (ii) furnish a certified copy of the certificate from said Surety Company's state showing said Surety Company licensed and authorized to transact business and execute said bond in Illinois; and (iii) if requested by Owner, furnish a copy of current financial statements of said Surety Company.

§ 18.1 The Contractor shall promptly correct Work rejected by the Architect or failing to conform to the requirements of the Contract Documents, whether discovered before or after Substantial Completion and whether or not fabricated, installed, or completed. Costs of correcting such rejected Work, including additional testing and inspections, the cost of uncovering and replacement, and compensation for the Architect's services and expenses made necessary thereby, shall be at the Contractor's expense, unless compensable under Section A.1.7.3 in Exhibit A, Determination of the Cost of the Work expense. If prior to the date of Final Completion the Contractor, a Subcontractor, or anyone for who either of them is responsible, uses or damages any portion of the Work, including but not limited to mechanical, electrical, plumbing or other building system, machinery, equipment or other mechanical device, the Contractor shall cause such item to be replaced or if permitted by the Owner restored to "like new" condition, at no expense to the Owner.

§ 18.2 In addition to the Contractor's obligations under Section 9.4, if, within one year after the date of Substantial Final Completion of the Work or designated portion thereof or after the date for commencement of warranties established under Section 15.6.3, or by terms of an applicable special warranty required by the Contract Documents, any of the Work is found to be not in accordance with the requirements of the Contract Documents, the Contractor shall correct it promptly after receipt of notice from the Owner to do so unless the Owner has previously given the Contractor a written acceptance of such condition. The Owner shall give such notice promptly after discovery of the condition. During the one-year period for correction of Work, if the Owner fails to notify the Contractor and give the Contractor an opportunity to make the correction, the Owner waives the rights to require correction by the Contractor and to make a claim for breach of warranty. The obligation under this Section 18.2 shall survive acceptance of the Work under the Contract and termination of the Contract. Corrective Work shall be warranted to be free from defects for a period equal to the longer of twelve (12) months after the completion of the corrective Work or one (1) year from the date of Final Completion of the Work, or such longer period of time as may be prescribed by law or in equity or by the terms of any applicable special warranty. Notwithstanding the foregoing, Contractor shall correct Work deficiently or defectively performed and replace defective or non-conforming materials and equipment, even though such deficiency, defect or non-conformity may be discovered more than one (1) year after Final Completion, if the correction is of a latent defect and arises from poor workmanship or improper materials or equipment, or is required to be made to Work, materials or equipment covered by the Contractor or a Subcontractor contrary to the Architect's or Owner's request or to the request of a governmental officer, or to the requirements of the Contract Documents or Governmental Requirements, and was therefore not visible for inspection by the Architect, Owner or governmental officer, as applicable, at the time of inspection. Contractor shall, within a reasonable time under the circumstances,

after receipt of written notice thereof, correct, repair, replace and otherwise make good any defects or non-conformity in the Work.

PAGE 28

§ 18.5 The one-year period for correction of Work shall not be extended by corrective Work performed by the Contractor pursuant to this Article 18. Contractor shall remove from the site portions of the Work that are not in accordance with the requirements of the Contract Documents and are neither corrected by the Contractor nor accepted by the Owner.

§ 18.6 The Contractor shall bear the cost of correcting destroyed or damaged construction, whether completed or partially completed, of the Owner or separate contractors caused by the Contractor's correction or removal of the Work that is not in accordance with the requirements of the Contract Documents

...

The Contract shall be governed by the law of the place where the Project is located, excluding that jurisdiction's choice of law rules. If the parties have selected arbitration as the method of binding dispute resolution, the Federal Arbitration Act shall govern Section 21.6. located.

...

Tests, inspections, and approvals of portions of the Work required by the Contract Documents or by applicable laws, statutes, ordinances, codes, rules and regulations, or lawful orders of public authorities shall be made at an appropriate time. Unless otherwise provided, the Contractor shall make arrangements for such tests, inspections, and approvals with an independent testing laboratory or entity acceptable to the Owner, or with the appropriate public authority, and shall bear all related costs of tests, inspections, and approvals. The Contractor shall give the Architect timely notice of when and where tests and inspections are to be made so that the Architect may be present for such procedures. The Owner shall bear costs of (1) tests, inspections, or approvals that do not become requirements until after bids are received or negotiations ~~concluded~~ concluded and (2) tests, inspections or approvals where building codes or applicable laws or regulations prohibit the Owner from delegating the costs to the Contractor, unless such tests, inspection or approvals were necessitated by the Contractor's failure to perform the Work in accordance with the Contract Documents in which event the Contractor shall bear the costs. The Owner shall directly arrange and pay for tests, inspections, or approvals where building codes or applicable laws or regulations so require.

The Owner shall bear costs of (1) tests, inspections or approvals that do not become requirements until after bids are received or negotiations concluded, and (2) tests, inspections or approvals where building codes or applicable laws or regulations prohibit the Owner from delegating the costs to the Contractor, unless such tests, inspection or approvals were necessitated by the Contractor's failure to perform the Work in accordance with the Contract Documents in which event the Contractor shall bear the costs.

PAGE 29

Dave Thommes
Oak Brook Park District
1450 Forest Gate Road
Oak Brook, IL 60523
T: 630-645-9534
Email: dthommes@obparks.org

...

If the Architect fails to certify payment as provided in Section 15.4.1 for a period of 30 days through no fault of the Contractor, Contractor or for any undisputed payment and has not notified Contractor for the reason for withholding payment, or if the Owner fails to make payment as provided in Section 4.1.3 for a period of 30 days, the Contractor may, days through no fault of the Contractor or for any undisputed payment and has not notified Contractor for the reason for withholding payment, and such failure continues for a period of 90 days after notice from the Contractor, the Contractor may, as its sole remedy, upon seven additional days' notice to the Owner and the Architect, terminate the Contract and recover from the Owner payment for Work executed, including reasonable overhead and profit, costs

~~incurred by reason of such termination, and damages unless this reason is cured prior to the expiration of the notice period, and recover from Owner payment of Work properly executed in accordance with the Contract Documents (the basis for such payment shall be as provided in the Contract) provided said Work was authorized in advance by Owner. The Owner shall have the right to cure any defect or default prior to the date of termination stated in any written notice from Contractor as provided herein, in which event Contractor shall continue with the Work. If the Contractor terminates the Work and receives payment in connection with his equipment, tools or materials such items shall be left and remain on the Site if the Owner so elects. Owner shall not be responsible for damages for loss of anticipated profits on Work not performed.~~

...

- ~~.1 — repeatedly refuses or fails to supply enough properly skilled workers or proper materials;~~
- ~~.2 — fails to make~~

~~If the Contractor shall institute proceedings or consent to proceeding requesting relief or arrangement under the Federal Bankruptcy Act or any applicable Federal or State Law, or if a petition under any federal or state insolvency law is filed against the Contractor and such petition is not dismissed within sixty (60) days from the date of the filing, or if the Contractor admits in writing his inability to pay his debts generally as they become due, or if he makes a general assignment for the benefit of his creditors, or if a receiver, liquidator, trustee, or assignee is appointed on account of his bankruptcy or insolvency; or if a receiver of all or any substantial portion of the Contractor's properties is appointed; or if the Contractor abandons the Work; or if he fails, except in cases for which extension of time is provided, to prosecute promptly and diligently the Work or to supply enough properly skilled workmen or proper materials for the Work; or if the Contractor submits an application for payment, sworn statement, waiver of lien, affidavit or document of any nature whatsoever which is intentionally falsified; or if the Contractor fails to make prompt payment to Subcontractors for materials or labor in accordance with the respective agreements between the Contractor and the Subcontractors;~~

- ~~.3 — repeatedly disregards applicable laws, statutes, ordinances, codes, rules and regulations, or lawful orders of a public authority; or~~
- ~~.4 — otherwise is guilty of substantial breach of a provision of the Contract Documents, or otherwise breaches obligations under any subcontract with a Subcontractor; or if a lien or a notices of lien is filed against any part of the Project or Project funds or if the Contractor disregards any laws, statues, ordinances, rules, regulations or orders of any governmental body or public or quasi-public authority having jurisdiction of the Work or the Project premises; or if the Contractor otherwise violates any material provision of the Contract Documents, then, without prejudice to any right or remedy available Owner may, after giving the Contractor seven (7) days' written notice, terminate the Contractor, and take possession of the Project and all materials, equipment, tools, construction equipment and machinery thereon owned by the Contractor and accept assignment of Subcontracts and may complete the Work by whatever reasonable method the Owner may deem expedient. If requested by the Owner, the Contractor shall remove any part or all of this equipment, machinery and supplies from the Project within seven (7) days from the date of such request, and in such event at the Contractor's expense. Upon request of the Contractor, the Owner shall furnish to the Contractor a reasonably detailed accounting of the costs incurred by the Owner in completing the Work.~~

~~§ 20.2.2 When any of the reasons described in Section 20.2.1 exists, the Owner, upon certification by the Architect that sufficient cause exists to justify such action, may, without prejudice to any other remedy the Owner may have and after giving the Contractor seven days' notice, terminate the Contract and take possession of the site and of all materials, equipment, tools, and construction equipment and machinery thereon owned by the Contractor and may finish the Work by whatever reasonable method the Owner may deem expedient. Upon request of the Contractor, the Owner shall furnish to the Contractor a detailed accounting of the costs incurred by the Owner in finishing the Work. Intentionally omitted.~~

PAGE 30

~~§ 20.2.5 The Owner's right to terminate the contract pursuant to Section 20.2 shall be in addition to and not in limitation of its right to stop the Work without terminating the Contract as provided elsewhere in this Agreement.~~

The Owner may, at any time, terminate the Contract for the Owner's convenience and without cause. The Owner shall pay the Contractor for Work executed; and costs incurred by reason of such termination, including costs attributable to termination of Subcontracts; and a termination fee, if any, as follows:

(Insert the amount of or method for determining the fee payable to the Contractor by the Owner following a termination for the Owner's convenience, if any.)

Termination by the Owner under this Section 20.3 shall be by a written notice of termination specifying the extent of termination and the effective date.

§ 20.3.1 Upon receipt of a notice of termination for convenience, the Contractor shall immediately, in accordance with instructions from the Owner, proceed with performance of the following duties:

1. cease operation as specified in the notice;
2. place no further orders and enter into no further Subcontracts for materials, labor, services, equipment, or facilities except as necessary to complete continued portions of the Contract;
3. terminate all subcontracts and orders to the extent they relate to the Work terminated;
4. proceed to complete the performance of Work not terminated; and
5. take actions that may be necessary, or that the Owner may direct, for the protection and preservation of the terminated work.

§ 20.3.2 In the event of termination by Owner for convenience, the sum payable to the Contractor for the Work shall be prorated based upon the amount of properly performed Work completed. Owner shall receive proper credit for sums already paid. Upon any such termination, all obligations of Owner (other than payment of sums due Contractor for services properly performed but not previously paid prior to the date of termination) shall cease as of the effective date of termination.

§20.3.4 The Owner shall be credited for (1) payments previously made to the Contractor for the terminated portion of the Work, and (2) claims which the Owner has against the Contractor under the Contract.

§20.4 SUSPENSION BY THE OWNER FOR CONVENIENCE

§20.4.1 The Owner may without cause order the Contractor in writing to suspend, delay or interrupt the Work in whole or in part for such period of time as the Owner may determine.

§20.4.2 If suspension, delay or interruption ordered by the Owner constitutes in the aggregate more than twenty percent (20%) of the total number of days scheduled for completion, an adjustment shall be made for increases in the cost of the performance of this Contract, excluding profit caused by such suspension, delay or interruption. No adjustment shall be made to the extent:

- .1 That the performance is, was, or would have been so suspended, delayed or interrupted by another cause, including without limitation the fault or negligence of the Contractor or any Subcontractor; or
- .2 That an equitable adjustment is made or denied under another provision of this Contract.

§20.4.3 Adjustments made in the cost of performance may have a mutually agreed fixed or percentage fee.

§ 21.1 Claims, disputes, and other matters in question arising out of or relating to this Contract, including those alleging an error or omission by the Architect but excluding those arising under Section 16.2, shall be referred initially to the Architect for decision. Such matters, except those waived as provided for in Section 21.11 and Sections 15.7.3 and 15.7.4, shall, after initial decision by the Architect or 30 days after submission of the matter to the Architect, be subject to mediation as a condition precedent to binding dispute resolution.
Intentionally omitted.

PAGE 31

§ 21.2.1 Claims by either the Owner or Contractor, where the condition giving rise to the Claim is first discovered prior to expiration of the period for correction of the Work set forth in Section 18.2, shall be initiated by notice to the Architect within 21 days after occurrence of the event giving rise to such Claim or within 21 days after the claimant first recognizes the condition giving rise to the Claim, whichever is later.
Intentionally omitted.

...

The Owner and Contractor shall commence all claims and causes of action against the other and arising out of or related to the Contract in accordance with the requirements of the final dispute resolution method selected in this Agreement whether in contract, tort, breach of warranty, or otherwise, within the period specified by applicable law, but in any case not more than 10 years after the date of Substantial Completion of the Work. The Owner and Contractor waive all claims and causes of action not commenced in accordance with this Section 21.3. law.

...

~~§ 21.5 The parties shall endeavor to resolve their disputes by mediation which, unless the parties mutually agree otherwise, shall be administered by the American Arbitration Association in accordance with their Construction Industry Mediation Procedures in effect on the date of this Agreement. A request for mediation shall be made in writing, delivered to the other party to this Agreement, and filed with the person or entity administering the mediation. The request may be made concurrently with the binding dispute resolution but, in such event, mediation shall proceed in advance of binding dispute resolution proceedings, which shall be stayed pending mediation for a period of 60 days from the date of filing, unless stayed for a longer period by agreement of the parties or court order. If an arbitration is stayed pursuant to this Section, the parties may nonetheless proceed to the selection of the arbitrator(s) and agree upon a schedule for later proceedings.~~

Intentionally omitted.

~~§ 21.6 If the parties have selected arbitration as the method for binding dispute resolution in this Agreement, any claim, subject to, but not resolved by, mediation shall be subject to arbitration which, unless the parties mutually agree otherwise, shall be administered by the American Arbitration Association, in accordance with the Construction Industry Arbitration Rules in effect on the date of this Agreement. Demand for arbitration shall be made in writing, delivered to the other party to the Contract, and filed with the person or entity administering the arbitration. The award rendered by the arbitrator or arbitrators shall be final, and judgment may be entered upon it in accordance with applicable law in any court having jurisdiction thereof.~~

Intentionally omitted.

~~§ 21.7 Subject to the rules of the American Arbitration Association or other applicable arbitration rules, either party, at its sole discretion, may consolidate an arbitration conducted under this Agreement with any other arbitration to which it is a party provided that (1) the arbitration agreement governing the other arbitration permits consolidation; (2) the arbitrations to be consolidated substantially involve common questions of law or fact; and (3) the arbitrations employ materially similar procedural rules and methods for selecting arbitrator(s).~~

~~§ 21.8 Subject to the rules of the American Arbitration Association or other applicable arbitration rules, any party to an arbitration may include by joinder persons or entities substantially involved in a common question of law or fact whose presence is required if complete relief is to be accorded in arbitration provided that the party sought to be joined consents in writing to such joinder. Consent to arbitration involving an additional person or entity shall not constitute consent to arbitration of a Claim not described in the written Consent.~~

~~§ 21.7- § 21.9 The foregoing agreement to arbitrate and other agreements to arbitrate with an additional person or entity duly consented to by parties to this Agreement, shall be specifically enforceable under applicable law in any court having jurisdiction thereof. § 21.9 Intentionally omitted.~~

...

The Contractor and Owner waive claims against each other waives Claims against the Owner for consequential damages arising out of or relating to this Contract. This ~~mutual waiver includes~~

- ~~1 — damages incurred by the Owner for rental expenses, for losses of use, income, profit, financing, business and reputation, and for loss of management or employee productivity or of the services of such persons; and~~
- ~~2 — damages incurred by the~~ waiver includes, but is not limited to damages incurred by the Contractor for principal office expenses including the compensation of personnel stationed there, for losses of financing, business and reputation, and for loss of profit except anticipated profit arising directly from the Work.

~~This mutual-waiver is applicable, without limitation, to all consequential damages due to either party's Owner's termination in accordance with Article 20. Nothing contained in this Section 21.11 shall be deemed to preclude an award of liquidated damages, when applicable, in accordance with the requirements of the Contract Documents.~~

In any suit or action arising under this Contract the Owner shall be entitled to an award of reasonable attorney's fees and costs of litigation.

Any suit or action arising under this Contract shall be commenced in DuPage County, Illinois.

ARTICLE 22 OTHER CONDITIONS OR PROVISIONS

§ 22.1 The Contractor shall be responsible for the supply and maintenance of any and all temporary equipment, utilities, and facilities necessary to properly and safely complete and protect the Work, including without limitation those required by winter conditions. Contractor shall provide and erect barricades and other safeguards adequate to warn of danger at the site and to protect persons and property from injury resulting from the Work.

§ 22.2 The Contractor shall limit material and equipment storage to the immediate area of Work and such other areas as Owner may designate. The Contractor shall promptly remove and properly dispose off-site all construction material, trash, garbage and other debris.

§ 22.3 The Contractor shall notify Architect and Owner in advance (to the extent practicable, notice shall be made at least 48 hours in advance) of any and all deliveries of major materials to the Project Site and shall give notice of receipt of materials and equipment that Architect or Owner has indicated or customarily would want to inspect prior to commencement of the Work. Prior to resumption of the Work in the event of a temporary suspension lasting longer than 72 hours, and at such other time intervals during the process of the Work as requested by Owner, in order to permit Owner to properly coordinate its normal operations and facilities requirements with the Work.

§22.4 The following definitions are added to the Contract:

"Final completion" means the date the Contract has been fully performed, all the Work has been completed in accordance with the Contract Documents and the Owner has approved Final Payment to the Contractor.

"Indicated" and "shown" mean as described, detailed, discussed, scheduled, referenced, or called for in, or reasonably inferable from the Contract Documents in order to produce a first class Work product.

"Provide" or derivatives thereof means the Contractor shall properly fabricate, supply, furnish or procure all labor, materials, equipment, apparatus, and accessory appurtenances necessary to transport, deliver, install, erect and construct the specified item, complete, in place and ready for operation and use, including any final connections, in strict accordance with the Drawings, Specifications and other Contract Documents. The words "Contractor shall" are implied and shall be so understood whenever the direction or term "provide" is used.

"Unit Price" is an amount stated in the Contractor's bid proposal or in the Contract Documents as a price per unit of measurement for materials, equipment or services for a portion of the Work as described in the Bidding Documents or the Contract Documents. A Unit Price includes all costs associated with the performance of the portion of the Work for which the Unit Price is provided, including but not limited to labor, materials, equipment, loading, transportation, handling, unloading, overhead and profit.

§22.5 Except as otherwise specifically provided in the Contract Documents, if and to the extent of any inconsistency, ambiguity, conflict, discrepancy or error in the Contract Document, and otherwise in interpreting the Contract Documents, the Parties shall give precedence to the Contract Documents in the following order of priority:

- (i) Modifications.
- (ii) This Agreement except that the Supplementary Conditions shall take precedence over the General Conditions of the Contract.
- (iii) Specifications.

ARTICLE 23 • COMPLIANCE WITH LAWS

§ 23.1 The Contractor shall comply with all federal, state, county and local laws, codes, rules and regulations

Additions and Deletions Report for AIA Document A104™ – 2017 (formerly A107™ – 2007). Copyright © 1936, 1951, 1958, 1961, 1963, 1966, 1970, 1974, 1978, 1987, 1997, 2007 and 2017 by The American Institute of Architects. All rights reserved. **WARNING: This AIA® Document is protected by U.S. Copyright Law and International Treaties. Unauthorized reproduction or distribution of this AIA® Document, or any portion of it, may result in severe civil and criminal penalties, and will be prosecuted to the maximum extent possible under the law.** This document was produced by AIA software at 15:57:50 ET on 02/20/2020 under Order No.8830539077 which expires on 06/25/2020, and is not for resale.

User Notes:

(1899329843)

applicable to the Work including without limitation all building codes, permit conditions, the American with Disabilities Act and the equal employment opportunity clause of the Illinois Human Rights Act and the rules and regulations of the Illinois Department of Human Rights, the Illinois Prevailing Wage Act, and all laws and regulations pertaining to occupational and work safety, hours of operation and disposal of construction debris. A copy of the Contractor's certification of compliance with applicable laws is attached to and made a part of this Agreement.

§23.2 The Contractor shall maintain and shall require its Subcontractors to maintain policies of employment as follows:

§23.3.1 In the event of the Contractor's non-compliance with the provisions of this equal opportunity clause, the Illinois Human Rights Act or the Rules and Regulations of the Illinois Department of Human Rights ("Department"), Contractor may be declared ineligible for future contracts or subcontracts with the State of Illinois or any of its political subdivisions or municipal corporations, and the Contract may be cancelled or voided in whole or in part, and such other sanctions or penalties may be imposed or remedies invoked as provided by statute or regulation. During the performance of this Contract, Contractor agrees as follows:

- 1) That it will not discriminate against any employee or applicant for employment because of race, color, religion, sex, sexual orientation or preference, marital status, national origin or ancestry, citizenship status, age, physical or mental disability unrelated to a person's ability to perform the essential functions of the job, association with a person with a disability, military status or an unfavorable discharge from military service, or record of arrest; and further that it will examine all job classifications to determine if minority persons or women are underutilized and will take appropriate affirmative action to rectify any such underutilization.
- 2) That, if it hires additional employees in order to perform this Contract or any portions thereof, it will determine the availability (in accordance with the Department's Rules and Regulations) of minorities and women in the area(s) from which it may reasonably recruit and it will hire for each job classification for which employees are hired in such a way that minorities and women are not underutilized.
- 3) That, in all solicitations or advertisements for employees placed by it or on its behalf, it will state that all applicants will be afforded equal opportunity without discrimination because of race, color, religion, sex, sexual orientation, marital status, national origin or ancestry, citizenship status, age, physical or mental handicap or disability unrelated to a person's ability to perform the essential function of the job, or association with a person with a disability, military status or an unfavorable discharge from military service, or record of arrest.
- 4) That it will send to each labor organization or representative of workers with which it has or is bound by a collective bargaining or other agreement or understanding, a notice advising such labor organization or representative of the Contractor's obligations under the Illinois Human Rights Act and the Department's rules and regulations. If any such labor organization or representative fails or refuses to cooperate with the Contractor in its efforts to comply with such Act and rules and regulations, the Contractor will promptly notify the Department and the Owner and will recruit employees from other sources when necessary to fulfill its obligations thereunder.
- 5) That it will submit reports as required by the Department's rules and regulations, furnish all relevant information as may from time to time be requested by the Department or the Owner, and in all respects comply with the Illinois Human Rights Act and the Department's rules and regulations.
- 6) That it will permit access to all relevant books, records, accounts and work sites by personnel of the Owner and the Department for purposes of investigation to ascertain Department's rules and regulations.
- 7) That it will include verbatim or by reference the provisions of this clause in every subcontract it awards under which any portion of the Contract obligations are undertaken or assumed, so that such provisions will be binding upon such subcontractor. In the same manner as with other provisions of this Contract. The Contractor will be liable for compliance with applicable provisions of this clause

by such subcontractors; and further it will promptly notify the Owner and the Department in the event any subcontractor fails or refuses to comply therewith. In addition, the Contractor will not utilize any subcontractor declared by the Illinois Human Rights Commission to be ineligible (or contracts or subcontracts with the State of Illinois or any of its political subdivisions or municipal corporations.

§23.4 The Contractor is encouraged to utilize qualified minority businesses as subcontractors for supplies, services and construction.

§23.5 The Contractor shall comply with the requirements of the Illinois Prevailing Wage Act (820 ILCS 130/0.01 et seq.) requiring payment of prevailing wages. The Contractor shall pay or cause to be paid not less than the prevailing rate of hourly wage in the county the Work is performed as determined by the Illinois Department of Labor for the month in which the Work is performed including but not limited to all laborers, workers and mechanics. All contractors and subcontractors rendering services under this contract must comply with all requirements under the Act, including but not limited to, all wage, notice and record keeping duties.

The Contractor is required to verify current prevailing wage prior to the first day of each month and to pay the then-current prevailing wage rate as determined by the Illinois Department of Labor. Any increases in costs to the Contractor due to the changes in the prevailing wage during the term of this Contract shall be at the expense of Contractor and not at the expense of Owner. Current prevailing wage rates are published at the following:

<https://www2.illinois.gov/idol/Laws-Rules/CDN/MI/D/Pages/2018-Rates.aspx>. The Contractor agrees to indemnify and hold harmless the Park District for any violations of the Prevailing Wage Act.

The Contractor shall also: (1) insert into each subcontract and the project specifications for each subcontract, a written stipulation that the subcontractor shall not pay less than the prevailing rate of hourly wage to all laborers, workers, and mechanics performing work under the contract; and (2) require each subcontractor to insert into each lower-tiered contract and the project specifications for each lower-tiered subcontract, a stipulation that the subcontractor shall not pay less than prevailing rate of hourly wage to all laborers, workers, and mechanics performing work under the contract.

The Contractor shall include on all bonds and shall cause all subcontractors' bonds required under the Contract Documents to guarantee compliance with the Prevailing Wage Act.

Additionally, the Contractor and each subcontractor shall make and keep, for a period of not less than 5 years from the date of the last payment on a contract or subcontract, records of all laborers, mechanics, and other workers employed by them on the Project; the records shall include each worker's name, address, telephone number when available, social security number, classification or classifications, the hourly wages paid in each pay period, the number of hours worked each day, and the starting and ending times of work each day. The Contractor shall submit monthly, no later than the 10th day of each calendar month, in person, by mail, or electronically a certified payroll to the Park District with each monthly pay request in the form required by the Illinois Prevailing Wage Act. The certified payroll shall be accompanied by a statement signed by the Contractor or subcontractor which states that: (i) he or she has examined the certified payroll and such records are true and accurate; (ii) the hourly rate paid to each worker is not less than the general prevailing rate of hourly wages required by this Act; and (iii) the Contractor or subcontractor is aware that filing a certified payroll that he or she knows to be false is a Class A misdemeanor. The Contractor may rely on the certification of a lower tier subcontractor, provided the Contractor does not knowingly rely upon a subcontractor's false certification. The records submitted in accordance with this payroll submittal provision shall be considered public records pursuant to Section 5 of the Prevailing Wage Act, 820 ILCS 130/5 (2004, as amended by P.A. 94-515). The Park District may, at its option, immediately terminate the Contract in the event that Contractor violates any provision of this paragraph or the Prevailing Wage Act.

Contractor shall also post the prevailing wage rates for each craft or type of worker or mechanic needed to complete the project at either: (1) a location on the project site easily accessible to the workers engaged on the project; or (2) in lieu of posting on the project site, if the Contractor has a business location where laborers, workers, and mechanics may regularly visit, the Contractor may either post the prevailing rate of wages in each county the Contractor works in a conspicuous location or provide the laborers, workers or mechanics engaged on the project a written notice indicating the prevailing rate of wages for the project.

Upon seven business days' notice, the Contractor and each subcontractor shall make available for inspection and copying at a location within this State during reasonable hours, the records identified in 820 ILCS 130/5(a)(1) to the Owner, and its officers and agents.

§23.6 Central Park West shall remain open to the public during weekends for the duration of the Project. As such, Contractor shall maintain the Project site in a manner that ensures safe access to Central Park West amenities by the public, Park District staff and others requiring access to Central Park West. Additionally, the Contractor shall ensure that the Project site is clean, all tools are either removed from the Project site or safely security on-site in a manner that will not restrict access to Central Park West by the public and Park District staff, and Central Park West is otherwise able to be occupied and operated as a rental space during the weekends by the public. Contractor shall comply with and give notices required by applicable laws, statutes, ordinances, codes, rules and regulations, and lawful orders of public authorities bearing on safety of persons or property or their protection from damage, injury or loss.

§23.7 Contractor shall only perform work four (4) days a week and only on the designated days as specified on the Central Park West Monthly Calendar included in these Bid Documents.

OAK BROOK PARK DISTRICT

Certification of Document's Authenticity

AIA® Document D401™ – 2003

I, Nicole L. Karas, hereby certify, to the best of my knowledge, information and belief, that I created the attached final document simultaneously with its associated Additions and Deletions Report and this certification at 15:57:50 ET on 02/20/2020 under Order No. 8830539077 from AIA Contract Documents software and that in preparing the attached final document I made no changes to the original text of AIA® Document A104™ – 2017, Standard Abbreviated Form of Agreement Between Owner and Contractor, as published by the AIA in its software, other than those additions and deletions shown in the associated Additions and Deletions Report.

(Signed)

(Title)

(Dated)

Technical Specifications

Central Park West at Central Park West

Monthly Calendar For May 2020

Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday
					RENTAL	RENTAL
RENTAL	4	5	6	7	8	RENTAL
10 RENTAL	11	12	13	14		RENTAL
RENTAL		19	20 RENTAL	RENTAL	RENTAL	RENTAL
24	25	26	27	28	29	RENTAL
RENTAL						



DAYS CONTRACTOR MAY WORK ON SITE. CONTRACTOR SHALL COMPLETE A PORTION OF THE WORK AFTER EACH DESIGNATED FOUR (4) DAY WORK PERIOD. NO WORK SHALL BE COMPLETED ON OTHER DATES AND FACILITY SHALL BE LEFT IN A FINISHED, CLEAN CONDITION FOR PARK DISTRICT USE AFTER EACH PERIOD.

Central Park West at Central Park West

Monthly Calendar For June 2020

Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday
	1	2	3	4 SUBSTANTIAL COMPLETION	5 RENTAL	6
RENTAL	8	9	10	11 FINAL COMPLETION	12	13 RENTAL
14 RENTAL	15 RENTAL	16 RENTAL	17 RENTAL	18 RENTAL	19 RENTAL	
	22	23	24	25	26	27
28	29	30				



DAYS CONTRACTOR MAY WORK ON SITE. CONTRACTOR SHALL COMPLETE A PORTION OF THE WORK AFTER EACH DESIGNATED FOUR (4) DAY WORK PERIOD. NO WORK SHALL BE COMPLETED ON OTHER DATES AND FACILITY SHALL BE LEFT IN A FINISHED, CLEAN CONDITION FOR PARK DISTRICT USE AFTER EACH PERIOD.



DATE OF SUBSTANTIAL COMPLETION - JUNE 4, 2020. DATE OF FINAL COMPLETION - JUNE 11, 20

SECTION 01 20 00
PRICE AND PAYMENT PROCEDURES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Procedures for preparation and submittal of applications for progress payments.
- B. Documentation of changes in Contract Sum and Contract Time.
- C. Correlation of Contractor submittals based on changes.
- D. Procedures for preparation and submittal of application for final payment.

1.02 RELATED REQUIREMENTS

1.03 SCHEDULE OF VALUES

- A. Form to be used: AIA G703.
- B. Electronic media printout including equivalent information will be considered in lieu of standard form specified; submit draft to Architect for approval.
- C. Forms filled out by hand will not be accepted.
- D. Schedule of Values: Submit a Schedule of Values within fifteen (15) business days after date of Owner-Contractor Agreement. See Document 01 20 00 - Price and Payment Procedures.
- E. Format: Utilize the Table of Contents of this Project Manual. Identify each line item with number and title of the specification Section. Identify bonds and insurance.
- F. Include separately from each line item, a direct proportional amount of Contractor's overhead and profit.
- G. Revise schedule to list approved Change Orders, with each Application For Payment.
- H. Preparation of Schedule of Values.
 - 1. Itemize separate line cost for each of following cost items:
 - a. Insurance.
 - b. Bonds.
 - c. General Conditions and overhead.
 - d. Profit and fees.
 - e. Construction allowance amounts.
 - f. Mobilization.
 - g. Dumpsters.
 - h. Daily clean-up.
 - i. Final cleaning.
 - j. Temporary barricades and fencing.
 - k. Hoisting and craning.
 - l. Warranties.
 - m. Operations and maintenance manuals
 - n. As-built drawings.
 - o. Owner demonstration and training.
 - p. Attic stock materials and equipment.
 - q. Any additional line items requested by the Owner, Construction Manager or Architect.
 - 2. Itemize separate line item cost for work specified in each section of the specifications. Identify work of:
 - a. Trade Contractor's own labor forces.
 - b. All subcontractors.
 - c. All major suppliers of products or equipment.
 - 3. Break down installed costs into:
 - a. Delivered cost of product, with taxes paid.
 - b. Labor cost.

4. For each line item which has an installed value of more than \$10,000.00 break down costs to list amount of labor and amount of materials under each item.
 - a. Contractor, subcontractor or supplier.
 - b. Specification section number.
 - c. Description of work or material.
 - d. Quantity.
 - e. Unit Price.
 - f. Scheduled value.
 - g. Percentage (%) of Contract.
5. Round off figures to nearest one dollar.
6. Make sum of total costs of all items listed in Schedule equal to total contract sum.

1.04 APPLICATIONS FOR PROGRESS PAYMENTS

- A. Payment Period: Submit at intervals stipulated in the Agreement.
- B. Form to be used: AIA G702 and G703.
- C. Electronic media printout including equivalent information will be considered in lieu of standard form specified; submit sample to Architect for approval.
- D. Forms filled out by hand will not be accepted.
- E. For each item, provide a column for listing each of the following:
 1. Item Number.
 2. Description of work.
 3. Scheduled Values.
 4. Scheduled Values.
 5. Scheduled Values.
 6. Previous Applications.
 7. Work in Place and Stored Materials under this Application.
 8. Authorized Change Orders.
 9. Total Completed and Stored to Date of Application.
 10. Percentage of Completion.
 11. Balance to Finish.
 12. Retainage.
- F. Execute certification by signature of authorized officer.
- G. Use data from approved Schedule of Values. Provide dollar value in each column for each line item for portion of work performed and for stored products.
- H. List each Allowance as separate line items consisting of the following.
 1. List each authorized Allowance Authorization Requests (AARs).
 2. List the amount of Allowance Dollars Remaining such that the sum of all Allowance Authorization Requests listed and the Allowance Dollars Remaining totals the Allowance amount specified in 01 21 00 - Allowances.
- I. List each authorized Change Order as a separate line item, listing Change Order number and dollar amount as for an original item of Work.
- J. When Architect requires substantiating information, submit data justifying dollar amounts in question. Provide one copy of data with cover letter for each copy of submittal. Show application number and date, and line item by number and description.

1.05 APPLICATION FOR PROGRESS PAYMENT SUBMISSION AND REVIEW PROCESS:

- A. Contractor is to submit one electronic copy of draft Application for Payment (pencil copy) to the Architect's Project Manager and the Owner's Representative for initial review.
- B. If the Architect and Owner have comments or corrections, Contractor shall address all issues and take such actions as may be required by Owner and Architect pursuant to the Contract Documents and, upon completion of making any corrections and/or actions required, Contractor

shall resubmit. Resubmit one revised electronic copy of draft Application for Payment (pencil copy) for final review.

- C. Upon approval of the draft Application for Payment (pencil copy), Contractor shall submit two original copies of the Application for Payment (final copy), waivers of lien, sworn affidavits, and all substantiating paperwork required by the Contract Documents to Legat Architects' Corporate Studio at the following address:
 - 1. Attention: Cindy Hopkins.
 - 2. Address: 1125 Tri-State Parkway, Suite 730, Illinois 60031
 - 3. Phone: (847) 662-3535.
- D. Legat Architects' Corporate Studio will review the Application for Payment (final copy) and all supporting materials. A representative of the Legat Architects' Corporate Studio may contact the Contractor directly if supporting materials are missing or incorrect.
- E. Upon Legat's review and approval of Contractor's Application for Payment in accordance with the Contract Documents, Legat Architects' Corporate Studio will forward the original copies of the Application for Payment (final copy) to the Owner for review. Owner will make payment in accordance with the Contract Documents.
- F. The Owner will review and approve the Application for Payment (final copy) in accordance with the Contract Documents.
- G. Attached following this document is a Payment Schedule with milestone dates corresponding to the Progress Payment Process. Failure by the Contractor to adhere to the Progress Payment Process and the Payment Schedule may result in payments not being made in a timely manner.

1.06 MODIFICATION PROCEDURES

- A. Submit name of the individual authorized to receive change documents and who will be responsible for informing others in Contractor's employ or subcontractors of changes to the Contract Documents.
- B. For minor changes not involving an adjustment to the Contract Sum or Contract Time, Architect will issue instructions directly to Contractor.
- C. For other required changes, Architect will issue a document signed by Owner instructing Contractor to proceed with the change, for subsequent inclusion in a Change Order.
 - 1. The document will describe the required changes and will designate method of determining any change in Contract Sum or Contract Time.
 - 2. Promptly execute the change.
- D. For changes for which advance pricing is desired, Architect will issue a document that includes a detailed description of a proposed change with supplementary or revised drawings and specifications, a change in Contract Time for executing the change with a stipulation of any overtime work required and the period of time during which the requested price will be considered valid. Contractor shall prepare and submit a fixed price quotation within 5 business days.
- E. Contractor may propose a change by submitting a request for change to Architect, describing the proposed change and its full effect on the work, with a statement describing the reason for the change in accordance with these specifications, and the effect on the Contract Sum and Contract Time with full documentation. Document any requested substitutions in accordance with Section 01 60 00.
- F. Computation of Change in Contract Amount: As specified in the Agreement and Conditions of the Contract.
 - 1. For change requested by Architect for work falling under a fixed price contract, the amount will be based on Contractor's price quotation.
 - 2. For change requested by Contractor, the amount will be based on the Contractor's request for a Change Order as approved by Architect and Owner.

3. For change ordered by Architect without a quotation from Contractor, the amount will be determined by Architect based on the Contractor's substantiation of costs as specified for Time and Material work.
- G. Substantiation of Costs: Provide full information required for evaluation.
1. On request, provide the following data:
 - a. Quantities of products, labor, and equipment.
 - b. Taxes, insurance, and bonds.
 - c. Overhead and profit.
 - d. Justification for any change in Contract Time.
 - e. Credit for deletions from Contract, similarly documented.
 2. Support each claim for additional costs with additional information:
 - a. Origin and date of claim.
 - b. Dates and times work was performed, and by whom.
 - c. Time records and wage rates paid.
 - d. Invoices and receipts for products, equipment, and subcontracts, similarly documented.
 3. For Time and Material work, submit itemized account and supporting data after completion of change, within time limits indicated in the Conditions of the Contract.
- H. Adjustments to the Contract Sum, excluding those calculated using unit prices, shall calculate overhead, profit, and general conditions combined in accordance with the Contract Documents.
- I. After execution of Change Order, promptly revise Schedule of Values and Application for Payment forms to record each authorized Change Order as a separate line item and adjust the Contract Sum.
- J. Promptly revise progress schedules to reflect any change in Contract Time, revise sub-schedules to adjust times for other items of work affected by the change, and resubmit.
- K. Promptly enter changes in Project Record Documents.

1.07 APPLICATION FOR FINAL PAYMENT

- A. Prepare Application for Final Payment as specified for progress payments, identifying total adjusted Contract Sum, previous payments, and sum remaining due.
- B. Application for Final Payment will not be considered until the following have been accomplished:
 1. All closeout procedures specified in Section 01 70 00.
 2. All documents have been submitted in accordance with the Contract Documents.

END OF SECTION

SECTION 01 23 00

ALTERNATES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Description of Alternates.
- B. Procedures for pricing Alternates.
- C. Documentation of changes to Contract Price and Contract Time.

1.02 ACCEPTANCE OF ALTERNATES

- A. Alternates quoted on Bid Forms will be reviewed and accepted or rejected at Owner's option. Accepted Alternates will be identified in the Owner-Contractor Agreement.
- B. Indicate bid price for Alternates listed on the Bid Form. Unless noted otherwise, indicate bid price for Alternates as adding to or deducting from the Base Bid Price.
- C. Bids will be evaluated based on the total of the base bid price and the Alternates being considered.
- D. Coordinate related work and modify surrounding work to integrate the Work of each Alternate.

1.03 SCHEDULE OF ALTERNATES

- A. Alternate No. 1 - Aluminum Clad Wood Door and Frame:
 - 1. Alternate Item: Section 08 22 23 and Drawing number F/A-101.2 including referenced details for door number A109C.
 - 2. State the amount to be ADDED to the Base Bid to remove and replace existing door and frame with new Aluminum Clad Wood Door and Frame.
- B. Alternate No. 2 - Aluminum Clad Wood Window:
 - 1. Alternate Item: Section 08 52 23 and Drawing number W/A-101.2 including referenced details for window W2.
 - 2. State the amount to be ADDED to the Base Bid to remove and replace existing fixed window and frame with new Aluminum Clad Wood Window.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01 25 00
SUBSTITUTION PROCEDURES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Procedural requirements for proposed substitutions.

1.02 RELATED REQUIREMENTS

1.03 DEFINITIONS

- A. Substitutions: Changes from Contract Documents requirements proposed by Contractor to materials, products, assemblies, and equipment.
 - 1. Substitutions for Cause: Proposed due to changed Project circumstances beyond Contractor's control.
 - a. Unavailability.
 - b. Regulatory changes.
 - 2. Substitutions for Convenience: Proposed due to possibility of offering substantial advantage to the Project.
 - a. Substitution requests offering advantages solely to the Contractor will not be considered.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 GENERAL REQUIREMENTS

- A. Provide products as specified unless substitutions are submitted in the manner described herein, accepted, and documented.
- B. Products proposed for substitution that do not meet or exceed all aspects of the products specified will not be considered.
- C. A Substitution Request for products, assemblies, materials, and equipment constitutes a representation that the submitter:
 - 1. Has investigated proposed product and determined that it meets or exceeds the quality level of the specified product, equipment, assembly, or system.
 - 2. Agrees to provide the same warranty for the substitution as for the specified product.
 - 3. Agrees to coordinate installation and make changes to other work that may be required for the work to be complete, with no additional cost to Owner.
 - 4. Waives claims for additional costs or time extension that may subsequently become apparent.
- D. A Substitution Request for specified installer constitutes a representation that the submitter:
 - 1. Has acted in good faith to obtain services of specified installer, but was unable to come to commercial, or other terms.
- E. Document each request with complete data substantiating compliance of proposed substitution with Contract Documents. Burden of proof is on proposer.
- F. Content: Include information necessary for tracking the status of each Substitution Request, and information necessary to provide an actionable response.
 - 1. No specific form is required. Contractor's Substitution Request documentation must include the following:
 - a. Project Information:
 - 1) Official project name and number, and any additional required identifiers established in Contract Documents.
 - 2) Owner's, Architect's, and Contractor's names.
 - b. Substitution Request Information:

- 1) Discrete and consecutive Substitution Request number, and descriptive subject/title.
 - 2) Indication of whether the substitution is for cause or convenience.
 - 3) Issue date.
 - 4) Reference to particular Contract Document(s) specification section number, title, and article/paragraph(s).
 - 5) Description of Substitution.
 - 6) Reason why the specified item cannot be provided.
 - 7) Differences between proposed substitution and specified item.
 - 8) Description of how proposed substitution affects other parts of work.
- c. Attached Comparative Data: Provide point-by-point, side-by-side comparison addressing essential attributes specified, as appropriate and relevant for the item:
- 1) Physical characteristics.
 - 2) In-service performance.
 - 3) Expected durability.
 - 4) Visual effect.
 - 5) Sustainable design features.
 - 6) Warranties.
 - 7) Other salient features and requirements.
 - 8) Include, as appropriate or requested, the following types of documentation:
 - (a) Product Data:
 - (b) Samples.
 - (c) Certificates, test, reports or similar qualification data.
 - (d) Drawings, when required to show impact on adjacent construction elements.
- d. Impact of Substitution:
- 1) Savings to Owner for accepting substitution.
 - 2) Change to Contract Time due to accepting substitution.

G. Limit each request to a single proposed substitution item.

3.02 SUBSTITUTION PROCEDURES DURING PROCUREMENT

- A. Section 00 21 13 - Instructions to Bidders specifies time restrictions for submitting requests for substitutions during the bidding period, and the documents required.
- B. Prior to Bid Closing: Substitute products will be considered up to seven (7) business days prior to bid closing. Requests received after this date will not be considered.
1. When a request to substitute a product is made, Architect may approve the substitution and, if approved, will document the approval by issuing an Addendum to known bidders.
 2. Products approved by the Architect during the bidding period but not shown in addenda shall be identified in the bidding forms on Document 004325 - Proposed Substitutions if said materials are to be considered.

3.03 SUBSTITUTION PROCEDURES DURING CONSTRUCTION

- A. After the Bid Closing: No substitutions will be considered unless one or more of the following conditions exist:
1. Product is discontinued.
 2. Delays beyond control such as labor strikes, lockouts, severe weather conditions, fires, or acts of God which may preclude the production and/or delivery of products for purposes of the Project.
 3. Owner otherwise determines use of a substitute product is in its best interest.
- B. Submit request for Substitution for Cause within 14 days of discovery of need for substitution, but not later than 14 days prior to time required for review and approval by Architect, in order to stay on approved project schedule.
- C. Substitutions will not be considered under one or more of the following circumstances:
1. Failure to award subcontract in sufficient time;

2. Failure to place orders to ensure delivery without delaying work.
3. Insufficient quantity of product;
4. When they are indicated or implied on shop drawing or product data submittals, without having received prior approval;
5. Without a separate written request;
6. When acceptance will require revisions to the Contract Documents;
7. When they offer advantages solely to the Contractor.

3.04 RESOLUTION

- A. Architect may request additional information and documentation prior to rendering a decision. Provide this data in an expeditious manner.
- B. Architect will notify Contractor in writing of decision to accept or reject request.

3.05 ACCEPTANCE

- A. Accepted substitutions change the work of the Project. They will be documented and incorporated into work of the project by Change Order, Construction Change Directive, Architectural Supplementary Instructions, or similar instruments provided for in the Conditions of the Contract.

3.06 CLOSEOUT ACTIVITIES

- A. See Section 01 78 00 - Closeout Submittals, for closeout submittals.
- B. Include completed Substitution Request Forms as part of the Project record. Include both approved and rejected Requests.

END OF SECTION

SECTION 01 30 00
ADMINISTRATIVE REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. General administrative requirements.
- B. Electronic document submittal service - encouraged but not required.
- C. Preconstruction meeting.
- D. Progress meetings.
- E. Coordination drawings.
- F. Submittals for review, information, and project closeout.
- G. Number of copies of submittals.
- H. Requests for Interpretation (RFI) procedures.
- I. Submittal procedures.

1.02 RELATED REQUIREMENTS

- A. Document 01 30 05 - Electronic File Waiver: Required to obtain electronic background files.
- B. Section 01 32 16 - Construction Progress Schedule: Form, content, and administration of schedules.
- C. Section 01 60 00 - Product Requirements: General product requirements.
- D. Section 01 70 00 - Execution and Closeout Requirements: Additional coordination requirements.
- E. Section 01 78 00 - Closeout Submittals: Project record documents; operation and maintenance data; warranties and bonds.

1.03 GENERAL ADMINISTRATIVE REQUIREMENTS

- A. Comply with requirements of Section 01 70 00 - Execution and Closeout Requirements for coordination of execution of administrative tasks with timing of construction activities.
- B. Make the following types of submittals to Architect:
 - 1. Requests for Interpretation (RFI).
 - 2. Requests for substitution.
 - 3. Shop drawings, product data, and samples.
 - 4. Test and inspection reports.
 - 5. Design data.
 - 6. Manufacturer's instructions and field reports.
 - 7. Applications for payment and change order requests.
 - 8. Progress schedules.
 - 9. Coordination drawings.
 - 10. Correction Punch List and Final Correction Punch List for Substantial Completion.
 - 11. Closeout submittals.

1.04 PROJECT COORDINATOR

- A. Project Coordinator: Owner's Construction Supervisor.
- B. Cooperate with the Project Coordinator in allocation of mobilization areas of site, materials staging, construction traffic, deliveries, and parking.
- C. During construction, coordinate use of site and facilities through the Project Coordinator.
- D. Comply with Project Coordinator's procedures for intra-project communications; submittals, reports and records, schedules, coordination drawings, and recommendations; and resolution of ambiguities and conflicts.

- E. Comply with instructions of the Project Coordinator for use of temporary utilities and construction facilities. Responsibility for providing temporary utilities and construction facilities as identified by Owner.
- F. Coordinate field engineering and layout work under instructions of the Project Coordinator.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 ELECTRONIC DOCUMENT SUBMITTAL SERVICE

- A. **Use of an electronic document submittal service is not required.**
 - However, the Contractor is encouraged to utilize this type of service for this project.
- B. All documents transmitted for purposes of administration of the contract are to be in electronic (PDF, MS Word, or MS Excel) format, as appropriate to the document, and transmitted via an Internet-based submittal service that receives, logs and stores documents, provides electronic stamping and signatures, and notifies addressees via email.
 - 1. Besides submittals for review, information, and closeout, this procedure applies to Requests for Interpretation (RFIs), progress documentation, contract modification documents (e.g. supplementary instructions, change proposals, change orders), applications for payment, field reports and meeting minutes, Contractor's correction punchlist, and any other document any participant wishes to make part of the project record.
 - 2. Contractor and Architect are required to use this service.
 - 3. It is Contractor's responsibility to submit documents in allowable format.
 - 4. Subcontractors, suppliers, and Architect's consultants are to be permitted to use the service at no extra charge.
 - 5. Users of the service need an email address, internet access, and PDF review software that includes ability to mark up and apply electronic stamps (such as Adobe Acrobat, www.adobe.com, or Bluebeam PDF Revu, www.bluebeam.com), unless such software capability is provided by the service provider.
 - 6. Paper document transmittals will not be reviewed; emailed electronic documents will not be reviewed.
 - 7. All other specified submittal and document transmission procedures apply, except that electronic document requirements do not apply to samples or color selection charts.
- C. Cost: The cost of the service is to be paid by Contractor; include the cost of the service in the Contract Sum.
- D. Submittal Service: Use one of the following:
 - 1. ProCore: www.procore.com
 - 2. Submittal Exchange: www.submittalexchange.com.
 - 3. Newforma Project Cloud: www.newforma.com/products/newforma-project-cloud.
- E. Training: One, one-hour, web-based training session will be arranged for all participants, with representatives of Architect and Contractor participating; further training is the responsibility of the user of the service.
 - 1. Representatives of Owner are scheduled and included in this training.
- F. Project Closeout: Architect will determine when to terminate the service for the project and is responsible for obtaining archive copies of files for Owner.

3.02 PRECONSTRUCTION MEETING

- A. Project Coordinator will schedule a meeting after Notice of Award.
- B. Attendance Required:
 - 1. Owner.
 - 2. Architect.
 - 3. Project Engineer(s).
 - 4. Environmental Consultant.
 - 5. Contractor.

6. Project Manager.
 - a. Field Superintendent.
 - b. Safety Representative.
 - c. Major Subcontractors.
 - d. Major Equipment Suppliers.
 - e. Temperature Control Contractor.
- C. Agenda:
 1. Execution of Owner-Contractor Agreement.
 2. Submission of executed bonds and insurance certificates.
 3. Distribution of Contract Documents.
 4. Submission of list of subcontractors, list of products, schedule of values, and progress schedule.
 5. Designation of personnel representing the parties to Contract and Architect.
 6. Procedures and processing of field decisions, submittals, substitutions, applications for payments, proposal request, Change Orders, and Contract closeout procedures.
 7. Scheduling.
- D. Record minutes and distribute copies within two days after meeting to participants, with two copies to Architect, Owner, participants, and those affected by decisions made.

3.03 PROGRESS MEETINGS

- A. Meeting Schedule:
 1. After Notice of Award:
 - Schedule and administer meetings at maximum interval of every three weeks.
 2. During Construction Time - During Phases 2 and 3:
 - Schedule and administer meetings at maximum weekly intervals.
 3. After Substantial Completion and through completion of the punchlist:
 - Schedule and administer meetings at maximum every two weeks intervals.
 4. During Warranty Period: Meetings may be scheduled as required.
- B. Make arrangements for meetings, prepare agenda with copies for participants, preside at meetings.
- C. Attendance Required:
 1. Contractor.
 - a. Project Manager.
 - b. Field Superintendent.
 - c. Safety Representative.
 - d. Major Subcontractors.
 - e. Major Equipment Suppliers.
 - f. Temperature Control Contractor.
 2. Owner.
 3. Architect.
 4. Project Engineer(s).
 5. Environmental Consultant.
- D. Agenda:
 1. Review minutes of previous meetings.
 2. Review of work progress.
 3. Field observations, problems, and decisions.
 4. Identification of problems that impede, or will impede, planned progress.
 5. Review of submittals schedule and status of submittals.
 6. Review of off-site fabrication and delivery schedules.
 7. Maintenance of progress schedule.
 8. Corrective measures to regain projected schedules.
 9. Planned progress during succeeding work period.

10. Coordination of projected progress.
 11. Maintenance of quality and work standards.
 12. Effect of proposed changes on progress schedule and coordination.
 13. Other business relating to work.
- E. Record minutes and distribute copies within two days after meeting to participants, with two copies to Architect, Owner, participants, and those affected by decisions made.

3.04 CONSTRUCTION PROGRESS SCHEDULE - SEE SECTION 01 32 16

3.05 COORDINATION DRAWINGS

- A. Provide information required by Project Coordinator for preparation of coordination drawings.
- B. Review drawings prior to submission to Architect.

3.06 REQUESTS FOR INTERPRETATION (RFI)

- A. Definition: A request seeking one of the following:
 1. An interpretation, amplification, or clarification of some requirement of Contract Documents arising from inability to determine from them the exact material, process, or system to be installed; or when the elements of construction are required to occupy the same space (interference); or when an item of work is described differently at more than one place in the Contract Documents.
 2. A resolution to an issue which has arisen due to field conditions and affects design intent.
- B. Whenever possible, request clarifications at the next appropriate project progress meeting, with response entered into meeting minutes, rendering unnecessary the issuance of a formal RFI.
- C. Preparation: Prepare an RFI immediately upon discovery of a need for interpretation of the Contract Documents. Failure to submit a RFI in a timely manner is not a legitimate cause for claiming additional costs or delays in execution of the work.
 1. Prepare a separate RFI for each specific item.
 - a. Review, coordinate, and comment on requests originating with subcontractors and/or materials suppliers.
 - b. Do not forward requests which solely require internal coordination between subcontractors.
 2. Prepare using an electronic version of the form appended to this section.
 3. Prepare using software provided by the Electronic Document Submittal Service.
 4. Combine RFI and its attachments into a single electronic file. PDF format is preferred.
- D. Reason for the RFI: Prior to initiation of an RFI, carefully study all Contract Documents to confirm that information sufficient for their interpretation is definitely not included.
 1. Include in each request Contractor's signature attesting to good faith effort to determine from the Contract Documents information requiring interpretation.
 2. Unacceptable Uses for RFIs: Do not use RFIs to request the following::
 - a. Approval of submittals (use procedures specified elsewhere in this section).
 - b. Approval of substitutions (see Section - 01 60 00 - Product Requirements)
 - c. Changes that entail change in Contract Time and Contract Sum (comply with provisions of the Conditions of the Contract).
 - d. Different methods of performing work than those indicated in the Contract Drawings and Specifications (comply with provisions of the Conditions of the Contract).
 3. Improper RFIs: Requests not prepared in compliance with requirements of this section, and/or missing key information required to render an actionable response. They will be returned without a response, with an explanatory notation.
 4. Frivolous RFIs: Requests regarding information that is clearly indicated on, or reasonably inferable from, the Contract Documents, with no additional input required to clarify the question. They will be returned without a response, with an explanatory notation.
 - a. The Owner reserves the right to assess the Contractor for the costs (on time-and-materials basis) incurred by the Architect, and any of its consultants, due to processing of such RFIs.

- E. Content: Include identifiers necessary for tracking the status of each RFI, and information necessary to provide an actionable response.
 - 1. Official Project name and number, and any additional required identifiers established in Contract Documents.
 - 2. Owner's, Architect's, and Contractor's names.
 - 3. Discrete and consecutive RFI number, and descriptive subject/title.
 - 4. Issue date, and requested reply date.
 - 5. Reference to particular Contract Document(s) requiring additional information/interpretation. Identify pertinent drawing and detail number and/or specification section number, title, and paragraph(s).
 - 6. Annotations: Field dimensions and/or description of conditions which have engendered the request.
 - 7. Contractor's suggested resolution: A written and/or a graphic solution, to scale, is required in cases where clarification of coordination issues is involved, for example; routing, clearances, and/or specific locations of work shown diagrammatically in Contract Documents. If applicable, state the likely impact of the suggested resolution on Contract Time or the Contract Sum.
- F. Attachments: Include sketches, coordination drawings, descriptions, photos, submittals, and other information necessary to substantiate the reason for the request.
- G. RFI Log: Prepare and maintain a tabular log of RFIs for the duration of the project.
 - 1. Indicate current status of every RFI. Update log promptly and on a regular basis.
 - 2. Note dates of when each request is made, and when a response is received.
 - 3. Highlight items requiring priority or expedited response.
 - 4. Highlight items for which a timely response has not been received to date.
 - 5. Identify and include improper or frivolous RFIs.
- H. Review Time: Architect will respond and return RFIs to Contractor within seven calendar days of receipt. For the purpose of establishing the start of the mandated response period, RFIs received after 12:00 noon will be considered as having been received on the following regular working day.
 - 1. Response period may be shortened or lengthened for specific items, subject to mutual agreement, and recorded in a timely manner in progress meeting minutes.
- I. Responses: Content of answered RFIs will not constitute in any manner a directive or authorization to perform extra work or delay the project. If in Contractor's belief it is likely to lead to a change to Contract Sum or Contract Time, promptly issue a notice to this effect, and follow up with an appropriate Change Order request to Owner.
 - 1. Response may include a request for additional information, in which case the original RFI will be deemed as having been answered, and an amended one is to be issued forthwith. Identify the amended RFI with an R suffix to the original number.
 - 2. Do not extend applicability of a response to specific item to encompass other similar conditions, unless specifically so noted in the response.
 - 3. Upon receipt of a response, promptly review and distribute it to all affected parties, and update the RFI Log.
 - 4. Notify Architect within seven calendar days if an additional or corrected response is required by submitting an amended version of the original RFI, identified as specified above.

3.07 SUBMITTAL SCHEDULE

- A. Submit to Architect for review a schedule for submittals in tabular format.
 - 1. Submit at the same time as the preliminary schedule specified in Section - 01 32 16 - Construction Progress Schedule.
 - 2. Coordinate with Contractor's construction schedule and schedule of values.
 - 3. Format schedule to allow tracking of status of submittals throughout duration of construction.

4. Arrange information to include scheduled date for initial submittal, specification number and title, submittal category (for review or for information), description of item of work covered, and role and name of subcontractor.
5. Account for time required for preparation, review, manufacturing, fabrication and delivery when establishing submittal delivery and review deadline dates.
 - a. For assemblies, equipment, systems comprised of multiple components and/or requiring detailed coordination with other work, allow for additional time to make corrections or revisions to initial submittals, and time for their review.

3.08 SUBMITTALS FOR REVIEW

- A. When the following are specified in individual sections, submit them for review:
 1. Product data.
 2. Shop drawings.
 3. Samples for selection.
 4. Samples for verification.
- B. Submit to Architect for review for the limited purpose of checking for compliance with information given and the design concept expressed in the contract documents.
- C. Samples will be reviewed for aesthetic, color, or finish selection.
- D. After review, provide copies and distribute in accordance with SUBMITTAL PROCEDURES article below and for record documents purposes described in Section 01 78 00 - Closeout Submittals.

3.09 SUBMITTALS FOR INFORMATION

- A. When the following are specified in individual sections, submit them for information:
 1. Design data.
 2. Certificates.
 3. Test reports.
 4. Inspection reports.
 5. Manufacturer's instructions.
 6. Manufacturer's field reports.
 7. Other types indicated.
- B. Submit for Architect's knowledge as contract administrator or for Owner.

3.10 SUBMITTALS FOR PROJECT CLOSEOUT

- A. Submit Correction Punch List for Substantial Completion.
- B. Submit Final Correction Punch List for Substantial Completion.
- C. When the following are specified in individual sections, submit them at project closeout in compliance with requirements of Section 01 78 00 - Closeout Submittals:
 1. Project record documents.
 2. Operation and maintenance data.
 3. Warranties.
 4. Bonds.
 5. Other types as indicated.
- D. Submit for Owner's benefit during and after project completion.

3.11 NUMBER OF COPIES OF SUBMITTALS

- A. Electronic Documents: Submit one electronic copy in PDF format; an electronically-marked up file will be returned. Create PDFs at native size and right-side up; illegible files will be rejected.
 1. Product Data: Submit electronic documents.
 2. Shop Drawings: Submit electronic documents.
 3. Color Charts for initial selection: Submit manufacturer's printed materials. Websites, printouts from websites, and digital scans are not acceptable and will be rejected.
 4. Samples for color and finish selection: Submit physical samples.

- B. Samples: Submit the number specified in individual specification sections; one of which will be retained by Architect.
 - 1. After review, produce duplicates.
 - 2. Retained samples will not be returned to Contractor unless specifically so stated.

3.12 SUBMITTAL PROCEDURES

- A. General Requirements:
 - 1. Use a single transmittal for related items.
 - 2. Submit separate packages of submittals for review and submittals for information, when included in the same specification section.
 - 3. Sequentially identify each item. For revised submittals use original number and a sequential numerical suffix.
 - 4. Identify: Project; Contractor; subcontractor or supplier; pertinent drawing and detail number; and specification section number and article/paragraph, as appropriate on each copy.
 - 5. Apply Contractor's stamp, signed or initialed certifying that review, approval, verification of products required, field dimensions, adjacent construction work, and coordination of information is in accordance with the requirements of the work and Contract Documents.
 - a. Submittals from sources other than the Contractor, or without Contractor's stamp will not be acknowledged, reviewed, or returned.
 - 6. Deliver each submittal on date noted in submittal schedule, unless an earlier date has been agreed to by all affected parties, and is of the benefit to the project.
 - a. Upload submittals in electronic form to Electronic Document Submittal Service website.
 - 7. Schedule submittals to expedite the Project, and coordinate submission of related items.
 - a. For each submittal for review, allow 15 days excluding delivery time to and from the Contractor.
 - b. For sequential reviews involving Architect's consultants, Owner, or another affected party, allow an additional 7 days.
 - 8. Identify variations from Contract Documents and product or system limitations that may be detrimental to successful performance of the completed work.
 - 9. Provide space for Contractor and Architect review stamps.
 - 10. When revised for resubmission, identify all changes made since previous submission.
 - 11. Distribute reviewed submittals. Instruct parties to promptly report inability to comply with requirements.
 - 12. Incomplete submittals will not be reviewed, unless they are partial submittals for distinct portion(s) of the work, and have received prior approval for their use.
 - 13. Submittals not requested will be recognized, and will be returned "Not Reviewed",
- B. Product Data Procedures:
 - 1. Submit only information required by individual specification sections.
 - 2. Collect required information into a single submittal.
 - 3. Do not submit (Material) Safety Data Sheets for materials or products.
- C. Shop Drawing Procedures:
 - 1. Prepare accurate, drawn-to-scale, original shop drawing documentation by interpreting the Contract Documents and coordinating related work.
 - 2. Do not reproduce the Contract Documents to create shop drawings.
 - 3. Generic, non-project-specific information submitted as shop drawings do not meet the requirements for shop drawings.
- D. Samples Procedures:
 - 1. Transmit related items together as single package.
 - 2. Identify each item to allow review for applicability in relation to shop drawings showing installation locations.
 - 3. Include with transmittal high-resolution image files of samples to facilitate electronic review and approval. Provide separate submittal page for each item image.

- E. General procedures applicable to all submittals:
- F. Contractor Responsibilities:
 1. Review shop drawings, product data and samples prior to submission to the next level of authority.
 2. Verify:
 - a. Field dimensions and drawing dimensions.
 - b. Field construction criteria.
 - c. Catalog numbers and similar data.
 - d. Compliance of items submitted with Contract Documents.
 - e. Dimensions and elevations requirements necessary to properly install product.
 3. Coordinate each submittal with requirements of:
 - a. The Work.
 - b. The Contract Documents.
 - c. The work of other subcontractors.
 4. Contractor's responsibility for errors and omissions in submittals is not relieved by Architect/Engineer's review of submittals.
 5. Notify Architect in writing prior to submission and specifically on the submittal, of proposed deviations in submittals from contract requirements.
 6. Trade Contractor's responsibility for notifying Architect of deviations and for correcting deviations not properly identified in submittals is not relieved by Architect's review of improperly documented submittals.
 7. Do not begin any work which requires submittals without having Architect's stamp and initials or signature indicating review.
 8. After Architect's review, make response required by Architect's stamp and distribute copies. Indicate by transmittal that copy of approved data has been distributed.
- G. Architect's Responsibilities
 1. Review each submittal within ten (10) business days, excluding delivery time to and from the Contractor.
 2. Review for compliance to design concept of project.
 3. Review all requests for proposed deviations. Obtain Owner's concurrence and respond to Contractor's request.
 4. Review of separate item does not constitute review of an assembly in which item functions.
 5. Affix stamp, date, and initials or signature certifying to review of submittal, and with instructions for contractor response.
 6. Return submittals to Contractor for response or distribution.
 7. Select product colors upon receipt of all shop drawings and submittals requiring color selections.

3.13 SUBMITTAL REVIEW

- A. Submittals for Review: Architect will review each submittal, and approve, or take other appropriate action.
- B. Submittals for Information: Architect will acknowledge receipt and review. See below for actions to be taken.
- C. Architect's actions will be reflected by marking each returned submittal using virtual stamp on electronic submittals.
 1. Notations may be made directly on submitted items and/or listed on appended Submittal Review cover sheet.
- D. Architect's and consultants' actions on items submitted for review:
 1. Authorizing purchasing, fabrication, delivery, and installation:
 - a. "Approved", or language with same legal meaning.
 - b. "Approved as Noted, Resubmission not required", or language with same legal meaning.

- 1) At Contractor's option, submit corrected item, with review notations acknowledged and incorporated.
 - c. "Approved as Noted, Resubmit for Record", or language with same legal meaning.
 2. Not Authorizing fabrication, delivery, and installation:
 - a. "Revise and Resubmit".
 - 1) Resubmit revised item, with review notations acknowledged and incorporated.
 - 2) Non-responsive resubmittals may be rejected.
 - b. "Rejected".
 - 1) Submit item complying with requirements of Contract Documents.
- E. Architect's and consultants' actions on items submitted for information:
 1. Items for which no action was taken:
 - a. "Received" - to notify the Contractor that the submittal has been received for record only.
 2. Items for which action was taken:
 - a. "Reviewed" - no further action is required from Contractor.

END OF SECTION

**SECTION 01 30 05
ELECTRONIC FILE WAIVER**

ELECTRONIC FILE WAIVER

1.01 PROJECT

- A. Project Name: Oak Brook Park District - Central Park West Door and Window Replacement Project.
- B. Project Location: Oak Brook Park District - Central Park West.
- C. Project Address: 1500 Forest Gate Road, Oak Brook, IL 60523
- D. Owner: Oak Brook Park District.
- E. Architect's Name: Legat Architects, Inc.

1.02 GENERAL

- A. Legat Architects, Inc. agrees to convey the requested electronic file(s) identified below to the organization identified by the undersigned upon receipt of this document with an original signature by an authorized representative of said organization.
- B. The requested electronic file(s) are a copyrighted product of Owner and Legat Architects, Inc. Sale, distribution, and/or unauthorized use of the electronic file(s) and the information contained therein, in whole or part, without consent from Owner and Legat Architects, Inc. is prohibited.
- C. The information contained within in the electronic file(s) is provided in a good faith effort to expedite the Project and simplify the efforts of the Trade Contractor with no guarantee by the issuer as to the accuracy or correctness of the information provided. The Architect, Engineer, or other Specialty Consultant(s) accept no responsibility or liability for the use of these electronic files by the undersigned.
- D. The undersigned agrees to notify Legat Architects, Inc. within five business days of receipt of the electronic files of any issues preventing the electronic files from being accessed.

1.03 ELECTRONIC DRAWING FILES TO BE CONVEYED

- A. Electronic Drawing File Name(s): _____ Requested File Format(s): _____
1. _____
2. _____
3. _____
- B. Company Name: _____
- C. Name of Contractor: _____
(Printed/Typed Name of Authorized Agent of Contractor)
- D. Name of Contractor: _____
(Signature of Authorized Agent of Contractor)
- E. Date: _____

END OF SECTION

SECTION 01 32 16
CONSTRUCTION PROGRESS SCHEDULE

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Preliminary schedule.
- B. Construction progress schedule, bar chart type.

1.02 RELATED SECTIONS

1.03 REFERENCE STANDARDS

- A. AGC (CPSM) - Construction Planning and Scheduling Manual; 2004.
- B. M-H (CPM) - CPM in Construction Management - Project Management with CPM; O'Brien; 2006.

1.04 SUBMITTALS

- A. Within twenty-one (21) business days after date of the Letter of Intent to Award a Construction Contract, submit Preliminary Project Schedule which encompasses the full duration of the Project.
- B. Within ten (10) business days after date of the Pre-Construction Meeting, submit Final Project Schedule which encompasses the full duration of the Project.

1.05 QUALITY ASSURANCE

- A. Scheduler: Contractor's personnel or specialist Consultant specializing in CPM scheduling with one years minimum experience in scheduling construction work of a complexity comparable to this Project, and having use of computer facilities capable of delivering a detailed graphic printout within 48 hours of request.

1.06 SCHEDULE FORMAT

- A. Listings: In chronological order according to the start date for each activity. Identify each activity with the applicable specification section number.
- B. Sheet Size: Multiples of 8-1/2 x 11 inches (216 x 280 mm).
- C. Scale and Spacing: To allow for notations and revisions.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 PRELIMINARY SCHEDULE

- A. Prepare preliminary schedule in the form of a horizontal bar chart.

3.02 CONTENT

- A. Show complete sequence of construction by activity, with dates for beginning and completion of each element of construction.
- B. Identify each item by specification section number.
- C. Identify work of separate phases and other logically grouped activities.
- D. Provide sub-schedules to define critical portions of the entire schedule.
- E. Include conferences and meetings in schedule.
- F. Show accumulated percentage of completion of each item, and total percentage of Work completed, as of the first day of each month.
- G. Provide separate schedule of submittal dates for shop drawings, product data, and samples, owner-furnished products, products identified under Allowances, and dates reviewed submittals will be required from Architect. Indicate decision dates for selection of finishes.
- H. Indicate delivery dates for owner-furnished products.

- I. Coordinate content with schedule of values specified in Section 01 20 00 - Price and Payment Procedures.
- J. Provide legend for symbols and abbreviations used.

3.03 BAR CHARTS

- A. Include a separate bar for each major portion of Work or operation.
- B. Identify the first work day of each week.

3.04 REVIEW AND EVALUATION OF SCHEDULE

- A. Participate in joint review and evaluation of schedule with Architect at each submittal.
- B. Evaluate project status to determine work behind schedule and work ahead of schedule.
- C. After review, revise as necessary as result of review, and resubmit within 10 days.

3.05 UPDATING SCHEDULE

- A. Maintain schedules to record actual start and finish dates of completed activities.
- B. Indicate progress of each activity to date of revision, with projected completion date of each activity.
- C. Annotate diagrams to graphically depict current status of Work.
- D. Identify activities modified since previous submittal, major changes in Work, and other identifiable changes.
- E. Indicate changes required to maintain Date of Substantial Completion.
- F. Submit reports required to support recommended changes.

3.06 DISTRIBUTION OF SCHEDULE

- A. Distribute copies of updated schedules to Contractor's project site file, to subcontractors, suppliers, Architect, Owner, and other concerned parties.
- B. Instruct recipients to promptly report, in writing, problems anticipated by projections indicated in schedules.

END OF SECTION

SECTION 01 40 00
QUALITY REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Submittals.
- B. Quality assurance.
- C. References and standards.
- D. Testing and inspection agencies and services.
- E. Control of installation.
- F. Mock-ups.
- G. Tolerances.
- H. Manufacturers' field services.
- I. Defect Assessment.

1.02 RELATED REQUIREMENTS

- A. Section 01 30 00 - Administrative Requirements: Submittal procedures.
- B. Section 01 60 00 - Product Requirements: Requirements for material and product quality.

1.03 REFERENCE STANDARDS

- A. ASTM C1021 - Standard Practice for Laboratories Engaged in Testing of Building Sealants; 2008 (Reapproved 2014).
- B. ASTM C1077 - Standard Practice for Laboratories Testing Concrete and Concrete Aggregates for Use in Construction and Criteria for Laboratory Evaluation; 2014.
- C. ASTM C1093 - Standard Practice for Accreditation of Testing Agencies for Masonry; 2015ae1.
- D. ASTM D3740 - Standard Practice for Minimum Requirements for Agencies Engaged in the Testing and/or Inspection of Soil and Rock as Used in Engineering Design and Construction; 2012a.
- E. ASTM E329 - Standard Specification for Agencies Engaged in Construction Inspection and/or Testing; 2014a.
- F. ASTM E543 - Standard Specification for Agencies Performing Nondestructive Testing; 2015.
- G. IAS AC89 - Accreditation Criteria for Testing Laboratories; 2010.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Test Reports: After each test/inspection, promptly submit two copies of report to Architect and to Contractor.
 - 1. Include:
 - a. Date issued.
 - b. Project title and number.
 - c. Name of inspector.
 - d. Date and time of sampling or inspection.
 - e. Identification of product and specifications section.
 - f. Location in the Project.
 - g. Type of test/inspection.
 - h. Date of test/inspection.
 - i. Results of test/inspection.
 - j. Compliance with Contract Documents.
 - k. When requested by Architect, provide interpretation of results.

2. Test report submittals are for Architect's knowledge as contract administrator for the limited purpose of assessing compliance with information given and the design concept expressed in the contract documents, or for Owner's information.
- C. Certificates: When specified in individual specification sections, submit certification by the manufacturer and Contractor or installation/application subcontractor to Architect, in quantities specified for Product Data.
1. Indicate material or product complies with or exceeds specified requirements. Submit supporting reference data, affidavits, and certifications as appropriate.
 2. Certificates may be recent or previous test results on material or product, but must be acceptable to Architect.
- D. Manufacturer's Instructions: When specified in individual specification sections, submit printed instructions for delivery, storage, assembly, installation, start-up, adjusting, and finishing, for the Owner's information. Indicate special procedures, perimeter conditions requiring special attention, and special environmental criteria required for application or installation.
- E. Manufacturer's Field Reports: Submit reports for Architect's benefit as contract administrator or for Owner.
1. Submit for information for the limited purpose of assessing compliance with information given and the design concept expressed in the contract documents.

1.05 QUALITY ASSURANCE

- A. Testing Agency Qualifications:
1. Prior to start of work, submit agency name, address, and telephone number, and names of full time registered Engineer and responsible officer.

1.06 REFERENCES AND STANDARDS

- A. For products and workmanship specified by reference to a document or documents not included in the Project Manual, also referred to as reference standards, comply with requirements of the standard, except when more rigid requirements are specified or are required by applicable codes.
- B. Comply with reference standard of date of issue current on date of Contract Documents, except where a specific date is established by applicable code.
- C. Obtain copies of standards where required by product specification sections.
- D. Maintain copy at project site during submittals, planning, and progress of the specific work, until Substantial Completion.
- E. Should specified reference standards conflict with Contract Documents, request clarification from Architect before proceeding.
- F. Neither the contractual relationships, duties, or responsibilities of the parties in Contract nor those of Architect shall be altered from the Contract Documents by mention or inference otherwise in any reference document.

1.07 TESTING AND INSPECTION AGENCIES AND SERVICES

- A. Contractor shall employ and pay for services of an independent testing agency to perform other specified testing.
- B. Employment of agency in no way relieves Contractor of obligation to perform Work in accordance with requirements of Contract Documents.
- C. Contractor Employed Agency:
1. Testing agency: Comply with requirements of ASTM E329, ASTM E543, ASTM C1021, ASTM C1077, ASTM C1093, ASTM D3740, and _____.
 2. Laboratory: Authorized to operate in the State in which the Project is located.
 3. Laboratory Staff: Maintain a full time registered Engineer on staff to review services.

PART 3 EXECUTION

2.01 CONTROL OF INSTALLATION

- A. Monitor quality control over suppliers, manufacturers, products, services, site conditions, and workmanship, to produce work of specified quality.
- B. Comply with manufacturers' instructions, including each step in sequence.
- C. Should manufacturers' instructions conflict with Contract Documents, request clarification from Architect before proceeding.
- D. Comply with specified standards as minimum quality for the work except where more stringent tolerances, codes, or specified requirements indicate higher standards or more precise workmanship.
- E. Have work performed by persons qualified to produce required and specified quality.
- F. Verify that field measurements are as indicated on shop drawings or as instructed by the manufacturer.
- G. Secure products in place with positive anchorage devices designed and sized to withstand stresses, vibration, physical distortion, and disfigurement.

2.02 MOCK-UPS

- A. Before installing portions of the Work where mock-ups are required, construct mock-ups in location and size indicated for each form of construction and finish required to comply with the following requirements, using materials indicated for the completed Work. The purpose of mock-up is to demonstrate the proposed range of aesthetic effects and workmanship.
- B. Accepted mock-ups establish the standard of quality the Architect will use to judge the Work.
- C. Integrated Exterior Mock-ups: Construct integrated exterior mock-up as indicated on drawings. Coordinate installation of exterior envelope materials and products as required in individual Specification Sections. Provide adequate supporting structure for mock-up materials as necessary.
- D. Notify Architect fifteen (15) working days in advance of dates and times when mock-ups will be constructed.
- E. Tests shall be performed under provisions identified in this section and identified in the respective product specification sections.
- F. Assemble and erect specified items with specified attachment and anchorage devices, flashings, seals, and finishes.
- G. Obtain Architect's approval of mock-ups before starting work, fabrication, or construction.
 - 1. Architect will issue written comments within seven (7) working days of initial review and each subsequent follow up review of each mock-up.
 - 2. Make corrections as necessary until Architect's approval is issued.
- H. Accepted mock-ups shall be a comparison standard for the remaining Work.
- I. Where mock-up has been accepted by Architect and is specified in product specification sections to be removed, protect mock-up throughout construction, remove mock-up and clear area when directed to do so by Architect.

2.03 TOLERANCES

- A. Monitor fabrication and installation tolerance control of products to produce acceptable Work. Do not permit tolerances to accumulate.
- B. Comply with manufacturers' tolerances. Should manufacturers' tolerances conflict with Contract Documents, request clarification from Architect before proceeding.
- C. Adjust products to appropriate dimensions; position before securing products in place.

2.04 TESTING AND INSPECTION

- A. Testing Agency Duties:

1. Provide qualified personnel at site. Cooperate with Architect and Contractor in performance of services.
 2. Perform specified sampling and testing of products in accordance with specified standards.
 3. Ascertain compliance of materials and mixes with requirements of Contract Documents.
 4. Promptly notify Architect and Contractor of observed irregularities or non-compliance of Work or products.
 5. Perform additional tests and inspections required by Architect.
 6. Submit reports of all tests/inspections specified.
- B. Limits on Testing/Inspection Agency Authority:
1. Agency may not release, revoke, alter, or enlarge on requirements of Contract Documents.
 2. Agency may not approve or accept any portion of the Work.
 3. Agency may not assume any duties of Contractor.
 4. Agency has no authority to stop the Work.
- C. Contractor Responsibilities:
1. Deliver to agency at designated location, adequate samples of materials proposed to be used that require testing, along with proposed mix designs.
 2. Cooperate with laboratory personnel, and provide access to the Work and to manufacturers' facilities.
 3. Provide incidental labor and facilities:
 - a. To provide access to Work to be tested/inspected.
 - b. To obtain and handle samples at the site or at source of Products to be tested/inspected.
 - c. To facilitate tests/inspections.
 - d. To provide storage and curing of test samples.
 4. Notify Architect and laboratory 24 hours prior to expected time for operations requiring testing/inspection services.
 5. Employ services of an independent qualified testing laboratory and pay for additional samples, tests, and inspections required by Contractor beyond specified requirements.
 6. Arrange with Owner's agency and pay for additional samples, tests, and inspections required by Contractor beyond specified requirements.
- D. Re-testing required because of non-compliance with specified requirements shall be performed by the same agency on instructions by Architect.
- E. Re-testing required because of non-compliance with specified requirements shall be paid for by Contractor.

2.05 MANUFACTURERS' FIELD SERVICES

- A. When specified in individual specification sections, require material or product suppliers or manufacturers to provide qualified staff personnel to observe site conditions, conditions of surfaces and installation, quality of workmanship, start-up of equipment, test, adjust and balance of equipment as applicable, and to initiate instructions when necessary.
- B. Report observations and site decisions or instructions given to applicators or installers that are supplemental or contrary to manufacturers' written instructions.

2.06 DEFECT ASSESSMENT

- A. Replace Work or portions of the Work not complying with specified requirements.
- B. If, in the opinion of Architect, it is not practical to remove and replace the work, Architect will direct an appropriate remedy or adjust payment.

END OF SECTION

SECTION 01 41 00
REGULATORY REQUIREMENTS

PART 1 GENERAL

1.01 SUMMARY OF REFERENCE STANDARDS

- A. Regulatory requirements applicable to this project are the following:
- B. Illinois Accessibility Code (IAC), 1997. This code shall apply in lieu of ICC International Building Code, Chapter 11.
- C. Illinois Plumbing Code (IPC), 2014. This code shall apply in lieu of Section 101.4.4 of Chapter 1 and be incorporated in Chapter 35 of the ICC International Building Code.
- D. Illinois State Fire Marshall - Boiler and Pressure Vessel Safety (41 IL Adm. Code 120), 2014. This code shall apply in lieu of Section 101.4.4 of Chapter 1 and be incorporated in Chapter 35 of the ICC International Building Code.
- E. 28 CFR 35 - Nondiscrimination on the Basis of Disability in State and Local Government Services; Final Rule; Department of Justice; current edition.
- F. 28 CFR 36 - Nondiscrimination by Public Accommodations and in Commercial Facilities; Final Rule; Department of Justice; current edition.
- G. 36 CFR 1191 - Americans with Disabilities Act (ADA) Accessibility Guidelines for Buildings and Facilities; Architectural Barriers Act (ABA) Accessibility Guidelines; current edition.
- H. 29 CFR 1910 - Occupational Safety and Health Standards; current edition.
- I. ICC A117.1 - Accessible and Usable Buildings and Facilities; 2009.
- J. ICC (IFC) - International Fire Code; 2012.
 - 1. Excluding Chapter 4.
- K. ICC (IBC) - International Building Code; 2015.
 - 1. Excluding Chapter 11.
- L. ICC (IMC) - International Mechanical Code; 2012.
- M. ICC (IFGC) - International Fuel Gas Code; 2012.
- N. ICC (IECC) - International Energy Conservation Code; 2012.
- O. ICC (IEBC) - ICC International Existing Building Code, 2015.

1.02 RELATED REQUIREMENTS

- A. Section 01 40 00 - Quality Requirements.

1.03 QUALITY ASSURANCE

- A. Contractor's Designer Qualifications: Refer to Section - 01 40 00 - Quality Requirements.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01 50 00
TEMPORARY FACILITIES AND CONTROLS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Temporary utilities.
- B. Temporary telecommunications services.
- C. Temporary sanitary facilities.
- D. Temporary Controls: Barriers, enclosures, and fencing.
- E. Vehicular access and parking.
- F. Materials receiving and handling.
- G. Waste removal facilities and services.
- H. Field offices.
- I. Construction Aids.

1.02 RELATED REQUIREMENTS

1.03 REFERENCE STANDARDS

- A. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2015a.

1.04 TEMPORARY UTILITIES - SEE SECTION 01 51 00

- A. Owner will provide the following:
 - 1. Electrical power and metering, consisting of connection to existing facilities.
 - 2. Water supply, consisting of connection to existing facilities.
- B. The Owner provide and pay for all electrical power, lighting, water, heating and cooling, and ventilation required for construction purposes.
- C. Existing facilities may be used.
- D. Use trigger-operated nozzles for water hoses, to avoid waste of water.

1.05 TELECOMMUNICATIONS SERVICES

- A. The Contractor shall have and maintain the capability to communicate via voice (telephone and mobile phone), text (mobile phone), email (mobile smart phone and computer), and electronic document submittal service (mobile smart phone or computer).
 - 1. The Contractor's place of business shall be equipped to communicate via voice, email, and electronic document submittal service.
 - 2. The Contractor's job site office(s) shall be equipped to communicate via voice, email, and electronic document submittal service.
 - 3. The Contractor's Project manager and Site Superintendent(s) shall be equipped with mobile smart phones capable of communicating via voice, text, email, and electronic document submittal service.
- B. Provide, maintain, and pay for telecommunications services to field office at time of project mobilization.
- C. Telecommunications services shall include:
 - 1. Windows-based personal computer dedicated to project telecommunications, with necessary software and laser printer.
 - 2. Internet Connections: Minimum of one; DSL modem or faster.
 - 3. Email: Minimum of one individual account/address for the Contractor's Project Manager, Site Superintendent, and other project-related personnel.

1.06 TEMPORARY SANITARY FACILITIES

- A. Provide and maintain required facilities and enclosures. Provide at time of project mobilization.
- B. Use of existing facilities is permitted.
- C. Maintain daily in clean and sanitary condition.
- D. At end of construction, return facilities to same or better condition as originally found.

1.07 BARRIERS

- A. Provide barriers to prevent unauthorized entry to construction areas, to prevent access to areas that could be hazardous to workers or the public, to allow for owner's use of site and to protect existing facilities and adjacent properties from damage from construction operations and demolition.
- B. Provide barricades and covered walkways required by governing authorities for public rights-of-way and for public access to existing building.
- C. Provide protection for plants designated to remain. Replace damaged plants.
 - 1. Provide temporary barriers 4 foot high around each, or around each group of trees and plants at drip line.
- D. Protect non-owned vehicular traffic, stored materials, site, and structures from damage.
- E. Materials may be new or used, suitable for purpose. Comply with specified codes and standards.

1.08 FENCING

- A. Provide 8 foot (2.4 m) high fence around construction site; equip with vehicular and pedestrian gates with locks.

1.09 INTERIOR ENCLOSURES

- A. Provide temporary partitions as indicated to separate work areas from Owner-occupied areas, to prevent penetration of dust and moisture into Owner-occupied areas, and to prevent damage to existing materials and equipment.
- B. Temporary Enclosure Type A: Low-adhesion, "painter's" tape applied to gaps around existing doors which are in a closed and locked condition.
- C. Temporary Enclosure Type B: Wood framing around perimeter of enclosure and infilled with reinforced polyethylene sheet material. Close all joints and seal edges where enclosure abuts existing surfaces. Provide zippered access where required.
- D. Temporary Enclosure Type C: Wood stud framed partition with 5/8" plywood sheet material on one side. Close all joints and seal edges where enclosure abuts existing surfaces. Provide hinged door which can be secured and locked where required. Prime and finish paint temporary enclosure.
- E. Temporary Enclosure Type D: Wood stud framed partition with 5/8" gypsum board sheet material on one side. Seal edges where enclosure abuts existing surfaces. Tape and finish gypsum board to Level 4 finish. Prime and finish paint. Provide cased and hinged door which can be secured and locked where required.
- F. Paint surfaces exposed to view from Owner-occupied areas.

1.10 SECURITY - SEE SECTION 01 35 53

1.11 VEHICULAR ACCESS AND PARKING

- A. Comply with regulations relating to use of streets and sidewalks, access to emergency facilities, and access for emergency vehicles.
- B. Coordinate access and haul routes with governing authorities and Owner.
- C. Provide and maintain access to fire hydrants, free of obstructions.
- D. Provide means of removing mud from vehicle wheels before entering streets.

- E. Use of existing on-site and adjacent streets and driveways for construction traffic is permitted only where designated.
- F. Provide temporary parking areas to accommodate construction personnel. When site space is not adequate, provide additional off-site parking.

1.12 MATERIALS RECEIVING

- A. Receive deliveries where shown on the Construction Operations Plan and directed by the Owner.
- B. Contractor shall be solely responsible to receive and sign for deliveries.
- C. Contractor shall provide and maintain equipment to handle deliveries and provide the personnel required. Use of the Owner's personnel and equipment is prohibited.
- D. Use of the Owner's Loading Dock is permitted given the following conditions:
 - 1. The Owner's use of the Loading Dock has priority over the Contractor's use.
 - 2. The Contractor shall coordinate delivery schedules with the Owner prior to delivery vehicles arriving on-site.
 - 3. The driver of a vehicle accessing the Loading Dock shall remain with their vehicle at all times.
 - 4. Parking in the Loading Dock is prohibited.
 - 5. Parking in reserved spaces near the Loading Dock is prohibited.
 - 6. The Contractor's deliveries cannot remain on the Loading Dock.
 - a. Promptly inspect deliveries to ensure shipments are correct.
 - b. Provide appropriate manpower at time of deliveries to promptly remove delivered materials to locations pre-arranged with the Owner.
- E. Use of the Owner's Freight Elevator is permitted given the following conditions:
 - 1. The Owner's use of the Freight Elevator has priority over the Contractor's use.
- F. Use of the Owner's Passenger Elevators is not permitted

1.13 WASTE REMOVAL

- A. Provide waste removal facilities and services as required to maintain the site in clean and orderly condition.
- B. If materials to be recycled or re-used on the project must be stored on-site, provide suitable non-combustible containers; locate containers holding flammable material outside the structure unless otherwise approved by the authorities having jurisdiction.
- C. Open free-fall chutes are not permitted. Terminate closed chutes into appropriate containers with lids.
- D. Use of the Owner waste removal equipment, facilities, and services is not permitted.
- E. Provide waste removal facilities and services as required to maintain the site in clean and orderly condition.
 - 1. Maintain areas under Contractor's control free of waste materials, debris and rubbish.
 - 2. Remove debris and rubbish from closed or remote spaces, prior to closing the space.
 - 3. Control cleaning operations so that dust and other particulates will not adhere to wet or newly-coated surfaces.
- F. Provide containers with lids. Remove trash from site on a weekly basis, minimum. Provide additional collections and disposal of debris whenever regular schedule is insufficient to prevent accumulation.
- G. Owner requests that this project generate the least amount of trash and waste possible.
 - 1. Employ processes that ensure the generation of as little waste as possible due to error, poor planning, breakage, mishandling, contamination, or other factors.
 - 2. Minimize trash/waste disposal in landfills; reuse, salvage, or recycle as much waste as economically feasible.
- H. Methods of trash/waste disposal that are not acceptable are:

1. Burning on the project site.
 2. Burying on the project site.
 3. Dumping or burying on other property, public or private.
 4. Other illegal dumping or burying.
 5. Incineration, either on- or off-site.
- I. Regulatory Requirements: Contractor is responsible for knowing and complying with regulatory requirements, including but not limited to Federal, state and local requirements, pertaining to legal disposal of all construction and demolition waste materials.
 - J. Prevent contamination of soil, water or atmosphere by the discharge of noxious substances from construction operations. Provide equipment and personnel, perform emergency measures to contain all spillages, and to remove contaminated soils or liquids.
 - K. Take special measures to prevent harmful substances from entering public waters. Prevent disposal of wastes, effluents, chemicals, or other such substances adjacent to streams, or in sanitary or storm sewer.

1.14 FIELD OFFICES

- A. Office: Weathertight, with lighting, electrical outlets, heating, cooling equipment, and equipped with sturdy furniture, drawing rack, and drawing display table.
- B. Provide space for Project meetings, with table and chairs to accommodate 6 persons.
- C. Locate offices a minimum distance of 30 feet (10 m) from existing and new structures.

1.15 CONSTRUCTION AIDS

- A. Provide and maintain all miscellaneous temporary facilities and equipment such as ladders, ramps, scaffolds, hoists, railings, chutes, barricades, enclosures, platforms, walks, etc., as required for the proper execution of the Work.
- B. Consult with Owner's representative to review site conditions and factors which may affect construction procedures and construction aids. Include review of adjacent properties and public ways which may also be affected by the Work.
- C. Installation:
 1. Comply with respective Project Manual Specifications Sections.
 2. Relocate construction aids as construction progresses to expedite storage or work requirements and to accommodate legitimate requirements of Owners and other contractors at the site.

1.16 REMOVAL OF UTILITIES, FACILITIES, AND CONTROLS

- A. Remove temporary utilities, equipment, facilities, materials, prior to Date of Substantial Completion inspection.
- B. Remove underground installations to a minimum depth of 2 feet (600 mm). Grade site as indicated.
- C. Clean and repair damage caused by installation or use of temporary work.
- D. Restore existing facilities used during construction to original condition.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01 60 00
PRODUCT REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. General product requirements.
- B. Re-use of existing products.
- C. Transportation, handling, storage and protection.
- D. Product option requirements.
- E. Substitution limitations.
- F. Procedures for Owner-supplied products.
- G. Maintenance materials, including extra materials, spare parts, tools, and software.

1.02 RELATED REQUIREMENTS

- A. Section 01 25 00 - Substitution Procedures: Substitutions made during procurement and/or construction phases.
- B. Section 01 40 00 - Quality Requirements: Product quality monitoring.

1.03 REFERENCE STANDARDS

- A. NEMA MG 1 - Motors and Generators; 2014.
- B. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.

1.04 SUBMITTALS

- A. Product Data Submittals: Submit manufacturer's standard published data. Mark each copy to identify applicable products, models, options, and other data. Supplement manufacturers' standard data to provide information specific to this Project.
- B. Shop Drawing Submittals: Prepared specifically for this Project; indicate utility and electrical characteristics, utility connection requirements, and location of utility outlets for service for functional equipment and appliances.
- C. Sample Submittals: Illustrate functional and aesthetic characteristics of the product, with integral parts and attachment devices. Coordinate sample submittals for interfacing work.
 - 1. For selection from standard finishes, submit samples of the full range of the manufacturer's standard colors, textures, and patterns.

PART 2 PRODUCTS

2.01 EXISTING PRODUCTS

- A. Do not use materials and equipment removed from existing premises unless specifically required or permitted by the Contract Documents.
- B. Unforeseen historic items encountered remain the property of the Owner; notify Owner promptly upon discovery; protect, remove, handle, and store as directed by Owner.
- C. Existing materials and equipment indicated to be removed, but not to be re-used, relocated, reinstalled, delivered to the Owner, or otherwise indicated as to remain the property of the Owner, become the property of the Contractor; remove from site.
- D. Specific Products to be Reused: The reuse of certain materials and equipment already existing on the project site is required.
 - 1. If reuse of other existing materials or equipment is desired, submit substitution request.

2.02 NEW PRODUCTS

- A. Provide new products unless specifically required or permitted by the Contract Documents.
- B. Use of products having any of the following characteristics is not permitted:
 - 1. Made using or containing CFC's or HCFC's.
 - 2. Containing lead, cadmium, or asbestos.
- C. Where other criteria are met, Contractor shall give preference to products that:
 - 1. If used on interior, have lower emissions, as defined in Section 01 61 16.
 - 2. If wet-applied, have lower VOC content, as defined in Section 01 61 16.
 - 3. Result in less construction waste. See Section 01 74 19
 - 4. Are made of recycled materials.
 - 5. If made of wood, are made of sustainably harvested wood, wood chips, or wood fiber.

2.03 PRODUCT OPTIONS

- A. Products Specified by Reference Standards or by Description Only: Use any product meeting those standards or description.
- B. Products Specified by Naming One or More Manufacturers: Use a product of one of the manufacturers named and meeting specifications, or equal or superior product approved by Architect and Owner.
- C. Products Specified by Naming One or More Manufacturers with a Provision for Substitutions: Submit a request for an equal to or superior to substitution for any manufacturer not named.

2.04 MAINTENANCE MATERIALS

- A. Furnish extra materials, spare parts, tools, and software of types and in quantities specified in individual specification sections.
- B. Deliver to Project site; obtain receipt prior to final payment.

PART 3 EXECUTION

3.01 SUBSTITUTION LIMITATIONS

- A. See Section 01 25 00 - Substitution Procedures.
- B. Substitutions may be considered when a product becomes unavailable through no fault of the Contractor.

3.02 OWNER-SUPPLIED PRODUCTS

- A. Owner's Responsibilities:
 - 1. Arrange for and deliver Owner reviewed shop drawings, product data, and samples, to Contractor.
 - 2. Arrange and pay for product delivery to site.
 - 3. On delivery, inspect products jointly with Contractor.
 - 4. Submit claims for transportation damage and replace damaged, defective, or deficient items.
 - 5. Arrange for manufacturers' warranties, inspections, and service.
- B. Contractor's Responsibilities:
 - 1. Review Owner reviewed shop drawings, product data, and samples.
 - 2. Receive and unload products at site; inspect for completeness or damage jointly with Owner.
 - 3. Handle, store, install and finish products.
 - 4. Repair or replace items damaged after receipt.

3.03 TRANSPORTATION AND HANDLING

- A. Package products for shipment in manner to prevent damage; for equipment, package to avoid loss of factory calibration.
- B. If special precautions are required, attach instructions prominently and legibly on outside of packaging.

- C. Coordinate schedule of product delivery to designated prepared areas in order to minimize site storage time and potential damage to stored materials.
- D. Transport and handle products in accordance with manufacturer's instructions.
- E. Transport materials in covered trucks to prevent contamination of product and littering of surrounding areas.
- F. Promptly inspect shipments to ensure that products comply with requirements, quantities are correct, and products are undamaged.
- G. Provide equipment and personnel to handle products by methods to prevent soiling, disfigurement, or damage, and to minimize handling.
- H. Arrange for the return of packing materials, such as wood pallets, where economically feasible.

3.04 STORAGE AND PROTECTION

- A. Designate receiving/storage areas for incoming products so that they are delivered according to installation schedule and placed convenient to work area in order to minimize waste due to excessive materials handling and misapplication. See Section 01 74 19.
- B. Store and protect products in accordance with manufacturers' instructions.
- C. Store with seals and labels intact and legible.
- D. Store sensitive products in weathertight, climate-controlled enclosures in an environment favorable to product.
- E. For exterior storage of fabricated products, place on sloped supports above ground.
- F. Provide off-site storage and protection when site does not permit on-site storage or protection.
- G. Protect products from damage or deterioration due to construction operations, weather, precipitation, humidity, temperature, sunlight and ultraviolet light, dirt, dust, and other contaminants.
- H. Comply with manufacturer's warranty conditions, if any.
- I. Do not store products directly on the ground.
- J. Cover products subject to deterioration with impervious sheet covering. Provide ventilation to prevent condensation and degradation of products.
- K. Store loose granular materials on solid flat surfaces in a well-drained area. Prevent mixing with foreign matter.
- L. Prevent contact with material that may cause corrosion, discoloration, or staining.
- M. Provide equipment and personnel to store products by methods to prevent soiling, disfigurement, or damage.
- N. Arrange storage of products to permit access for inspection. Periodically inspect to verify products are undamaged and are maintained in acceptable condition.

END OF SECTION

SECTION 01 70 00
EXECUTION AND CLOSEOUT REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Examination, preparation, and general installation procedures.
- B. Requirements for alterations work, including selective demolition.
- C. Pre-installation meetings.
- D. Cutting and patching.
- E. Surveying for laying out the work.
- F. Cleaning and protection.
- G. Starting of systems and equipment.
- H. Demonstration and instruction of Owner personnel.
- I. Closeout procedures, including Contractor's Correction Punch List, except payment procedures.

1.02 RELATED REQUIREMENTS

- A. Section 01 10 00 - Summary: Limitations on working in existing building; continued occupancy; work sequence; identification of salvaged and relocated materials.
- B. Section 01 30 00 - Administrative Requirements: Submittals procedures, Electronic document submittal service.
- C. Section 01 50 00 - Temporary Facilities and Controls: Temporary exterior enclosures.
- D. Section 01 50 00 - Temporary Facilities and Controls: Temporary interior partitions.
- E. Section 01 78 00 - Closeout Submittals: Project record documents, operation and maintenance data, warranties, and bonds.
- F. Section 01 79 00 - Demonstration and Training: Demonstration of products and systems to be commissioned and where indicated in specific specification sections
- G. Section 01 91 13 - General Commissioning Requirements: Contractor's responsibilities in regard to commissioning.
- H. Section 02 41 00 - Demolition: Demolition of whole structures and parts thereof; site utility demolition.
- I. Section 07 84 00 - Firestopping.

1.03 REFERENCE STANDARDS

- A. NFPA 241 - Standard for Safeguarding Construction, Alteration, and Demolition Operations; 2013.

1.04 SUBMITTALS

- A. Cutting and Patching: Submit written request in advance of cutting or alteration that affects:
 - 1. Structural integrity of any element of Project.
 - 2. Integrity of weather exposed or moisture resistant element.
 - 3. Efficiency, maintenance, or safety of any operational element.
 - 4. Visual qualities of sight exposed elements.
 - 5. Work of Owner or separate Contractor.
- B. Project Record Documents: Accurately record actual locations of capped and active utilities.

1.05 QUALIFICATIONS

- A. For surveying work, employ a land surveyor registered in the State in which the Project is located and acceptable to Architect. Submit evidence of surveyor's Errors and Omissions insurance coverage in the form of an Insurance Certificate. Employ only individual(s) trained

and experienced in collecting and recording accurate data relevant to ongoing construction activities,

- B. For design of temporary shoring and bracing, employ a Professional Engineer experienced in design of this type of work and licensed in the State in which the Project is located.

1.06 PROJECT CONDITIONS

- A. Use of explosives is not permitted.
- B. Grade site to drain. Maintain excavations free of water. Provide, operate, and maintain pumping equipment.
- C. Protect site from puddling or running water. Provide water barriers as required to protect site from soil erosion.
- D. Ventilate enclosed areas to assist cure of materials, to dissipate humidity, and to prevent accumulation of dust, fumes, vapors, or gases.
- E. Dust Control: Execute work by methods to minimize raising dust from construction operations. Provide positive means to prevent air-borne dust from dispersing into atmosphere and over adjacent property.
 - 1. Provide dust-proof enclosures to prevent entry of dust generated outdoors.
 - 2. Provide dust-proof barriers between construction areas and areas continuing to be occupied by Owner.
- F. Erosion and Sediment Control: Plan and execute work by methods to control surface drainage from cuts and fills, from borrow and waste disposal areas. Prevent erosion and sedimentation.
- G. Noise Control: Provide methods, means, and facilities to minimize noise produced by construction operations.
 - 1. At All Times: Excessively noisy tools and operations will not be tolerated inside the building at any time of day; excessively noisy includes jackhammers.
 - 2. Outdoors: Limit conduct of especially noisy exterior work to the hours of 8 am to 5 pm.
- H. Pollution Control: Provide methods, means, and facilities to prevent contamination of soil, water, and atmosphere from discharge of noxious, toxic substances, and pollutants produced by construction operations. Comply with federal, state, and local regulations.

1.07 COORDINATION

- A. Coordinate scheduling, submittals, and work of the various sections of the Project Manual to ensure efficient and orderly sequence of installation of interdependent construction elements, with provisions for accommodating items installed later.
- B. Notify affected utility companies and comply with their requirements.
- C. Verify that utility requirements and characteristics of new operating equipment are compatible with building utilities. Coordinate work of various sections having interdependent responsibilities for installing, connecting to, and placing in service, such equipment.
- D. Coordinate space requirements, supports, and installation of mechanical and electrical work that are indicated diagrammatically on drawings. Follow routing indicated for pipes, ducts, and conduit, as closely as practicable; place runs parallel with lines of building. Utilize spaces efficiently to maximize accessibility for other installations, for maintenance, and for repairs.
- E. In finished areas except as otherwise indicated, conceal pipes, ducts, and wiring within the construction. Coordinate locations of fixtures and outlets with finish elements.
- F. Coordinate completion and clean-up of work of separate sections.
- G. After Owner occupancy of premises, coordinate access to site for correction of defective work and work not in accordance with Contract Documents, to minimize disruption of Owner's activities.

PART 2 PRODUCTS

2.01 PATCHING MATERIALS

- A. New Materials: As specified in product sections; match existing products and work for patching and extending work.
- B. Type and Quality of Existing Products: Determine by inspecting and testing products where necessary, referring to existing work as a standard.
- C. Product Substitution: For any proposed change in materials, submit request for substitution described in Section 01 60 00 - Product Requirements.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that existing site conditions and substrate surfaces are acceptable for subsequent work. Start of work means acceptance of existing conditions.
- B. Verify that existing substrate is capable of structural support or attachment of new work being applied or attached.
- C. Examine and verify specific conditions described in individual specification sections.
- D. Take field measurements before confirming product orders or beginning fabrication, to minimize waste due to over-ordering or misfabrication.
- E. Verify that utility services are available, of the correct characteristics, and in the correct locations.
- F. Prior to Cutting: Examine existing conditions prior to commencing work, including elements subject to damage or movement during cutting and patching. After uncovering existing work, assess conditions affecting performance of work. Beginning of cutting or patching means acceptance of existing conditions.

3.02 PREPARATION

- A. Clean substrate surfaces prior to applying next material or substance.
- B. Seal cracks or openings of substrate prior to applying next material or substance.
- C. Apply manufacturer required or recommended substrate primer, sealer, or conditioner prior to applying any new material or substance in contact or bond.

3.03 PREINSTALLATION MEETINGS

- A. When required in individual specification sections, convene a preinstallation meeting at the site prior to commencing work of the section.
- B. Require attendance of parties directly affecting, or affected by, work of the specific section.
- C. Notify Architect four days in advance of meeting date.
- D. Prepare agenda and preside at meeting:
 - 1. Review conditions of examination, preparation and installation procedures.
 - 2. Review coordination with related work.
- E. Record minutes and distribute copies within two days after meeting to participants, with two copies to Architect, Owner, participants, and those affected by decisions made.

3.04 LAYING OUT THE WORK

- A. Verify locations of survey control points prior to starting work.
- B. Promptly notify Architect of any discrepancies discovered.
- C. Protect survey control points prior to starting site work; preserve permanent reference points during construction.
- D. Promptly report to Architect the loss or destruction of any reference point or relocation required because of changes in grades or other reasons.
- E. Utilize recognized engineering survey practices.

- F. Establish elevations, lines and levels. Locate and lay out by instrumentation and similar appropriate means:
 1. Site improvements including pavements; stakes for grading, fill and topsoil placement; utility locations, slopes, and invert elevations.
 2. Grid or axis for structures.
- G. Periodically verify layouts by same means.
- H. Maintain a complete and accurate log of control and survey work as it progresses.

3.05 GENERAL INSTALLATION REQUIREMENTS

- A. Install products as specified in individual sections, in accordance with manufacturer's instructions and recommendations, and so as to avoid waste due to necessity for replacement.
- B. Make vertical elements plumb and horizontal elements level, unless otherwise indicated.
- C. Install equipment and fittings plumb and level, neatly aligned with adjacent vertical and horizontal lines, unless otherwise indicated.
- D. Make consistent texture on surfaces, with seamless transitions, unless otherwise indicated.
- E. Make neat transitions between different surfaces, maintaining texture and appearance.

3.06 ALTERATIONS

- A. Drawings showing existing construction and utilities are based on casual field observation and existing record documents only.
 1. Verify that construction and utility arrangements are as indicated.
 2. Report discrepancies to Architect before disturbing existing installation.
 3. Beginning of alterations work constitutes acceptance of existing conditions.
- B. Keep areas in which alterations are being conducted separated from other areas that are still occupied.
 1. Provide, erect, and maintain temporary dustproof partitions of construction specified in Section 01 50 00 in locations indicated on drawings.
- C. Maintain weatherproof exterior building enclosure except for interruptions required for replacement or modifications; take care to prevent water and humidity damage.
 1. Where openings in exterior enclosure exist, provide construction to make exterior enclosure weatherproof.
 2. Insulate existing ducts or pipes that are exposed to outdoor ambient temperatures by alterations work.
- D. Remove existing work as indicated and as required to accomplish new work.
 1. Remove rotted wood, corroded metals, and deteriorated masonry and concrete; replace with new construction specified.
 2. Remove items indicated on drawings.
 3. Relocate items indicated on drawings.
 4. Where new surface finishes are to be applied to existing work, perform removals, patch, and prepare existing surfaces as required to receive new finish; remove existing finish if necessary for successful application of new finish.
 5. Where new surface finishes are not specified or indicated, patch holes and damaged surfaces to match adjacent finished surfaces as closely as possible.
- E. Services (Including but not limited to HVAC, Plumbing, Electrical, and Telecommunications): Remove, relocate, and extend existing systems to accommodate new construction.
 1. Maintain existing active systems that are to remain in operation; maintain access to equipment and operational components; if necessary, modify installation to allow access or provide access panel.
 2. Where existing systems or equipment are not active and Contract Documents require reactivation, put back into operational condition; repair supply, distribution, and equipment as required.

3. Where existing active systems serve occupied facilities but are to be replaced with new services, maintain existing systems in service until new systems are complete and ready for service.
 - a. Disable existing systems only to make switchovers and connections; minimize duration of outages.
 - b. Provide temporary connections as required to maintain existing systems in service.
 4. Verify that abandoned services serve only abandoned facilities.
 5. Remove abandoned pipe, ducts, conduits, and equipment, including those above accessible ceilings; remove back to source of supply where possible, otherwise cap stub and tag with identification; patch holes left by removal using materials specified for new construction.
- F. Protect existing work to remain.
1. Prevent movement of structure; provide shoring and bracing if necessary.
 2. Perform cutting to accomplish removals neatly and as specified for cutting new work.
 3. Repair adjacent construction and finishes damaged during removal work.
- G. Adapt existing work to fit new work: Make as neat and smooth transition as possible.
1. When existing finished surfaces are cut so that a smooth transition with new work is not possible, terminate existing surface along a straight line at a natural line of division and make recommendation to Architect.
 2. Where removal of partitions or walls results in adjacent spaces becoming one, rework floors, walls, and ceilings to a smooth plane without breaks, steps, or bulkheads.
 3. Where a change of plane of 1/4 inch (6 mm) or more occurs in existing work, submit recommendation for providing a smooth transition for Architect review and request instructions.
 4. Trim existing wood doors as necessary to clear new floor finish. Refinish trim as required.
- H. Patching: Where the existing surface is not indicated to be refinished, patch to match the surface finish that existed prior to cutting. Where the surface is indicated to be refinished, patch so that the substrate is ready for the new finish.
- I. Refinish existing surfaces as indicated:
1. Where rooms or spaces are indicated to be refinished, refinish all visible existing surfaces to remain to the specified condition for each material, with a neat transition to adjacent finishes.
 2. If mechanical or electrical work is exposed accidentally during the work, re-cover and refinish to match.
- J. Clean existing systems and equipment.
- K. Remove demolition debris and abandoned items from alterations areas and dispose of off-site; do not burn or bury.
- L. Do not begin new construction in alterations areas before demolition is complete.
- M. Comply with all other applicable requirements of this section.

3.07 CUTTING AND PATCHING

- A. Whenever possible, execute the work by methods that avoid cutting or patching.
- B. See Alterations article above for additional requirements.
- C. Perform whatever cutting and patching is necessary to:
 1. Complete the work.
 2. Fit products together to integrate with other work.
 3. Provide openings for penetration of mechanical, electrical, and other services.
 4. Match work that has been cut to adjacent work.
 5. Repair areas adjacent to cuts to required condition.
 6. Repair new work damaged by subsequent work.
 7. Remove samples of installed work for testing when requested.

- 8. Remove and replace defective and non-complying work.
- D. Execute work by methods that avoid damage to other work and that will provide appropriate surfaces to receive patching and finishing. In existing work, minimize damage and restore to original condition.
- E. Employ original installer to perform cutting for weather exposed and moisture resistant elements, and sight exposed surfaces.
- F. Cut rigid materials using masonry saw or core drill. Pneumatic tools not allowed without prior approval.
- G. Restore work with new products in accordance with requirements of Contract Documents.
- H. Fit work air tight to pipes, sleeves, ducts, conduit, and other penetrations through surfaces.
- I. At penetrations of fire rated walls, partitions, ceiling, or floor construction, completely seal voids with fire rated material in accordance with Section 07 84 00, to full thickness of the penetrated element.
- J. Patching:
 - 1. Finish patched surfaces to match finish that existed prior to patching. On continuous surfaces, refinish to nearest intersection or natural break. For an assembly, refinish entire unit.
 - 2. Match color, texture, and appearance.
 - 3. Repair patched surfaces that are damaged, lifted, discolored, or showing other imperfections due to patching work. If defects are due to condition of substrate, repair substrate prior to repairing finish.

3.08 PROGRESS CLEANING

- A. Maintain areas free of waste materials, debris, and rubbish. Maintain site in a clean and orderly condition.
- B. Remove debris and rubbish from pipe chases, plenums, attics, crawl spaces, and other closed or remote spaces, prior to enclosing the space.
- C. Broom and vacuum clean interior areas prior to start of surface finishing, and continue cleaning to eliminate dust.
- D. Collect and remove waste materials, debris, and trash/rubbish from site periodically and dispose off-site; do not burn or bury.

3.09 PROTECTION OF INSTALLED WORK

- A. Protect installed work from damage by construction operations.
- B. Provide special protection where specified in individual specification sections.
- C. Provide temporary and removable protection for installed products. Control activity in immediate work area to prevent damage.
- D. Provide protective coverings at walls, projections, jambs, sills, and soffits of openings.
- E. Protect finished floors, stairs, and other surfaces from traffic, dirt, wear, damage, or movement of heavy objects, by protecting with durable sheet materials.
- F. Prohibit traffic or storage upon waterproofed or roofed surfaces. If traffic or activity is necessary, obtain recommendations for protection from waterproofing or roofing material manufacturer.
- G. Remove protective coverings when no longer needed; reuse or recycle coverings if possible.

3.10 SYSTEM STARTUP

- A. Coordinate schedule for start-up of various equipment and systems.
- B. Verify that each piece of equipment or system has been checked for proper lubrication, drive rotation, belt tension, control sequence, and for conditions that may cause damage.

- C. Verify tests, meter readings, and specified electrical characteristics agree with those required by the equipment or system manufacturer.
- D. Verify that wiring and support components for equipment are complete and tested.
- E. Execute start-up under supervision of applicable Contractor personnel and manufacturer's representative in accordance with manufacturers' instructions.
- F. Submit a written report that equipment or system has been properly installed and is functioning correctly.

3.11 DEMONSTRATION AND INSTRUCTION

- A. See Section 01 79 00 - Demonstration and Training.

3.12 ADJUSTING

- A. Adjust operating products and equipment to ensure smooth and unhindered operation.

3.13 FINAL CLEANING

- A. Use cleaning materials that are nonhazardous.
- B. Clean interior and exterior glass, surfaces exposed to view; remove temporary labels, stains and foreign substances, polish transparent and glossy surfaces, vacuum carpeted and soft surfaces.
- C. Remove all labels that are not permanent. Do not paint or otherwise cover fire test labels or nameplates on mechanical and electrical equipment.
- D. Clean equipment and fixtures to a sanitary condition with cleaning materials appropriate to the surface and material being cleaned.
- E. Clean filters of operating equipment.
- F. Clean debris from roofs, gutters, downspouts, scuppers, overflow drains, area drains, and drainage systems.
- G. Clean site; sweep paved areas, rake clean landscaped surfaces.
- H. Remove waste, surplus materials, trash/rubbish, and construction facilities from the site; dispose of in legal manner; do not burn or bury.

3.14 CLOSEOUT PROCEDURES

- A. Make submittals that are required by governing or other authorities.
 - 1. Provide copies to Architect and Owner.
- B. Accompany Project Coordinator on preliminary inspection to determine items to be listed for completion or correction in the Contractor's Correction Punch List for Contractor's Notice of Substantial Completion.
- C. Notify Architect when work is considered ready for Architect's Substantial Completion inspection.
- D. Submit written certification containing Contractor's Correction Punch List, that Contract Documents have been reviewed, work has been inspected, and that work is complete in accordance with Contract Documents and ready for Architect's Substantial Completion inspection.
- E. Conduct Substantial Completion inspection and create Final Correction Punch List containing Architect's and Contractor's comprehensive list of items identified to be completed or corrected and submit to Architect.
- F. Correct items of work listed in Final Correction Punch List and comply with requirements for access to Owner-occupied areas.
- G. Accompany Project Coordinator on Contractor's preliminary final inspection.
- H. Notify Architect when work is considered finally complete and ready for Architect's Substantial Completion final inspection.

- I. Complete items of work determined by Architect listed in executed Certificate of Substantial Completion.

END OF SECTION

SECTION 01 78 00
CLOSEOUT SUBMITTALS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Project Record Documents.
- B. Operation and Maintenance Data.
- C. Warranties and bonds.

1.02 RELATED REQUIREMENTS

- A. Section 01 30 00 - Administrative Requirements: Submittals procedures, shop drawings, product data, and samples.
- B. Section 01 70 00 - Execution and Closeout Requirements: Contract closeout procedures.
- C. Individual Product Sections: Specific requirements for operation and maintenance data.
- D. Individual Product Sections: Warranties required for specific products or Work.

1.03 SUBMITTALS

- A. Project Record Documents: Submit documents to Architect with claim for final Application for Payment.
- B. Operation and Maintenance Data:
 - 1. Submit two copies of preliminary draft or proposed formats and outlines of contents before start of Work. Architect will review draft and return one copy with comments.
 - 2. For equipment, or component parts of equipment put into service during construction and operated by Owner, submit completed documents within ten days after acceptance.
 - 3. Submit one copy of completed documents 15 days prior to final inspection. This copy will be reviewed and returned after final inspection, with Architect comments. Revise content of all document sets as required prior to final submission.
 - 4. Submit two sets of revised final documents in final form within 10 days after final inspection.
- C. Warranties and Bonds:
 - 1. For equipment or component parts of equipment put into service during construction with Owner's permission, submit documents within 10 days after acceptance.
 - 2. Make other submittals within 10 days after Date of Substantial Completion, prior to final Application for Payment.
 - 3. For items of Work for which acceptance is delayed beyond Date of Substantial Completion, submit within 10 days after acceptance, listing the date of acceptance as the beginning of the warranty period.

1.04 ELECTRONIC CLOSEOUT DOCUMENTATION SUBMITTAL

- A. Final Closeout Documentation shall be submitted in electronic .PDF format and burned to compact disks which utilizes a customizable document management viewing system.
 - 1. All closeout documents shall be created or scanned to be compatible with the electronic format identified.
 - 2. Include scanned copies of warranties and bonds with electronic submittal.
- B. Document Management Viewing System.
 - 1. Description: System shall provide a customized means of organizing and viewing project documentation by utilizing an intuitive point-and-click system to navigate through various menus.
 - 2. Software: System shall not require a user to purchase any software other than standard software for viewing .pdf files.
 - 3. Document Search: Users shall be able to locate documents via point-and-click menus and a keyboarded search.

4. Providers: The organization of documents, setup of the document management viewing system, and creation of the compact disk shall be performed by vendors experienced with organizing construction documents in this manner.
 - a. Approved Vendors:
 - 1) BHFX Imaging.
 - (a) Contact Person: Sarah Jacobs at (847) 593-3161 extension 206 or sarah.jacobs@bhfx.net.
 - 2) Substitutions: Not permitted.
 - b. BHFX Imaging process and procedures:
 - 1) Contact BHFX Imaging for a Project Order Form a minimum of three months prior to the date of Substantial Completion to schedule a pre-closeout meeting.
 - 2) Prepare the following:
 - (a) Provide contact information for the individual responsible for the collection and transfer of the Electronic Closeout Documentation
 - (b) Identify folder structure for storage and transfer of files.
 - (c) Schedule deadline for collection of all documentation.
 - (d) Schedule deadline for turn-over of closeout documentation.
 - (e) Assemble all documents in PDF electronic format.
 - (f) Provide clean and accurate paper copies of all marked-up Record Documents, including but not limited to drawings and specifications, for scanning.
 - (g) Review a complete listing of Electronic Closeout Documentation Package contents.
 - 3) Provide all documentation to BHFX Imaging for processing no later than 30 days after the date of Substantial Completion.
 - 4) Schedule the training conference.
- C. Contents: The following documents shall be the minimum included on the final Closeout Documentation CD.
1. Chapter 1 - Project Directory:
 - a. Directory, listing names, addresses, telephone numbers, email addresses, and web site addresses of Architect, Engineer(s), Construction Manager, Trade Contractor(s), sub-contractors, and major equipment suppliers.
 2. Chapter 2 - Contract Documents:
 - a. Issued for Bidding Drawings.
 - b. Issued for Bidding Project Manual and Specifications.
 - c. Addenda.
 - d. Issued for Construction Drawings.
 - e. Issued for Construction Project Manual and Specifications.
 3. Chapter 3 - Submittals:
 - a. Approved Submittals for Review.
 - b. Reviewed Submittals for Information.
 - c. Documentation of selected finish samples.
 - d. Manufacturer's instructions for assembly, installation, adjusting, and maintenance.
 4. Chapter 4 - Record Documents:
 - a. Field Sketches.
 - b. As-Built Drawings.
 - c. As-Built Project Manual and Specifications.
 - d. Change Orders and other documented modifications to the Contract.
 5. Chapter 5 - Operations & Maintenance Data:
 - a. Refer to Part 3 - Execution of this Section.
 6. Chapter 6 - Training Videos:
 - a. Refer to Part 3 - Execution of this Section.
 7. Chapter 7 - Project Certifications and Warranties:
 - a. Refer to Part 3 - Execution of this Section.

- D. Organization: Use the following hierarchy for organizing the contents within each chapter:
 - 1. Construction discipline or Trade Contractor.
 - 2. Specification Divisions.
 - 3. Specification Sections.
- E. Training: Provide an on-site training conference which includes representatives from the Owner, Architect, Engineers, and General Contractor to present the completed Electronic Closeout Documentation submittal and instruct all attendees on how to interface with the software and its content.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 PROJECT RECORD DOCUMENTS

- A. Maintain on site one set of the following record documents; record actual revisions to the Work:
 - 1. Drawings.
 - 2. Specifications.
 - 3. Addenda.
 - 4. Change Orders and other modifications to the Contract.
- B. Ensure entries are complete and accurate, enabling future reference by Owner.
- C. Store record documents separate from documents used for construction.
- D. Record information concurrent with construction progress.
- E. Specifications: Legibly mark and record at each product section description of actual products installed, including the following:
 - 1. Product substitutions or alternates utilized.
 - 2. Changes made by Addenda and modifications.
- F. Record Drawings: Legibly mark each item to record actual construction including:
 - 1. Measured horizontal and vertical locations of underground utilities and appurtenances, referenced to permanent surface improvements.
 - 2. Measured locations of internal utilities and appurtenances concealed in construction, referenced to visible and accessible features of the Work.
 - 3. Field changes of dimension and detail.
 - 4. Details not on original Contract drawings.

3.02 OPERATION AND MAINTENANCE DATA

- A. Source Data: For each product or system, list names, addresses and telephone numbers of Subcontractors and suppliers, including local source of supplies and replacement parts.
- B. Product Data: Mark each sheet to clearly identify specific products and component parts, and data applicable to installation. Delete inapplicable information.
- C. Drawings: Supplement product data to illustrate relations of component parts of equipment and systems, to show control and flow diagrams. Do not use Project Record Documents as maintenance drawings.
- D. Typed Text: As required to supplement product data. Provide logical sequence of instructions for each procedure, incorporating manufacturer's instructions.

3.03 OPERATION AND MAINTENANCE DATA FOR MATERIALS AND FINISHES

- A. For Each Product, Applied Material, and Finish:
 - 1. Product data, with catalog number, size, composition, and color and texture designations.
 - 2. Information for re-ordering custom manufactured products.
- B. Instructions for Care and Maintenance: Manufacturer's recommendations for cleaning agents and methods, precautions against detrimental cleaning agents and methods, and recommended schedule for cleaning and maintenance.

- C. Where additional instructions are required, beyond the manufacturer's standard printed instructions, have instructions prepared by personnel experienced in the operation and maintenance of the specific products.

3.04 OPERATION AND MAINTENANCE DATA FOR EQUIPMENT AND SYSTEMS

- A. For Each Item of Equipment and Each System:
 - 1. Description of unit or system, and component parts.
 - 2. Identify function, normal operating characteristics, and limiting conditions.
 - 3. Include performance curves, with engineering data and tests.
 - 4. Complete nomenclature and model number of replaceable parts.
- B. Where additional instructions are required, beyond the manufacturer's standard printed instructions, have instructions prepared by personnel experienced in the operation and maintenance of the specific products.
- C. Panelboard Circuit Directories: Provide electrical service characteristics, controls, and communications; typed.
- D. Operating Procedures: Include start-up, break-in, and routine normal operating instructions and sequences. Include regulation, control, stopping, shut-down, and emergency instructions. Include summer, winter, and any special operating instructions.
- E. Maintenance Requirements: Include routine procedures and guide for preventative maintenance and trouble shooting; disassembly, repair, and reassembly instructions; and alignment, adjusting, balancing, and checking instructions.
- F. Provide servicing and lubrication schedule, and list of lubricants required.
- G. Include manufacturer's printed operation and maintenance instructions.
- H. Include sequence of operation by controls manufacturer.
- I. Provide original manufacturer's parts list, illustrations, assembly drawings, and diagrams required for maintenance.
- J. Provide control diagrams by controls manufacturer as installed.
- K. Provide charts of valve tag numbers, with location and function of each valve, keyed to flow and control diagrams.
- L. Provide list of original manufacturer's spare parts, current prices, and recommended quantities to be maintained in storage.
- M. Include test and balancing reports.
- N. Additional Requirements: As specified in individual product specification sections.

3.05 ASSEMBLY OF OPERATION AND MAINTENANCE MANUALS

- A. Assemble operation and maintenance data into durable manuals for Owner's personnel use, with data arranged in the same sequence as, and identified by, the specification sections.
- B. Where systems involve more than one specification section, provide separate tabbed divider for each system.
- C. Binders: Commercial quality, 8-1/2 by 11 inch (216 by 280 mm) three D side ring binders with durable plastic covers; 2 inch (50 mm) maximum ring size. When multiple binders are used, correlate data into related consistent groupings.
- D. Cover: Identify each binder with typed or printed title OPERATION AND MAINTENANCE INSTRUCTIONS; identify title of Project; identify subject matter of contents.
- E. Project Directory: Title and address of Project; names, addresses, and telephone numbers of Architect, Consultants, Contractor and subcontractors, with names of responsible parties.
- F. Tables of Contents: List every item separated by a divider, using the same identification as on the divider tab; where multiple volumes are required, include all volumes Tables of Contents in each volume, with the current volume clearly identified.

- G. Dividers: Provide tabbed dividers for each separate product and system; identify the contents on the divider tab; immediately following the divider tab include a description of product and major component parts of equipment.
- H. Text: Manufacturer's printed data, or typewritten data on 20 pound paper.
- I. Drawings: Provide with reinforced punched binder tab. Bind in with text; fold larger drawings to size of text pages.
- J. Arrangement of Contents: Organize each volume in parts as follows:
 - 1. Project Directory.
 - 2. Table of Contents, of all volumes, and of this volume.
 - 3. Operation and Maintenance Data: Arranged by system, then by product category.
 - a. Source data.
 - b. Operation and maintenance data.
 - c. Field quality control data.
 - d. Photocopies of warranties and bonds.

3.06 WARRANTIES AND BONDS

- A. Obtain warranties and bonds, executed in duplicate by responsible Subcontractors, suppliers, and manufacturers, within 10 days after completion of the applicable item of work. Except for items put into use with Owner's permission, leave date of beginning of time of warranty until Date of Substantial completion is determined.
- B. Verify that documents are in proper form, contain full information, and are notarized.
- C. Co-execute submittals when required.
- D. Retain warranties and bonds until time specified for submittal.
- E. Include originals of each in operation and maintenance manuals, indexed separately on Table of Contents.

END OF SECTION

SECTION 01 79 00
DEMONSTRATION AND TRAINING

PART 1 GENERAL

1.01 SUMMARY

- A. Demonstration of products and systems to be commissioned and where indicated in specific specification sections.
- B. Training of Owner personnel in operation and maintenance is required for:
 - 1. HVAC systems and equipment.
 - 2. Plumbing equipment.
 - 3. Electrical systems and equipment.
 - 4. Items specified in individual product Sections.
- C. Training of Owner personnel in care, cleaning, maintenance, and repair is required for:
 - 1. Fixtures and fittings.
 - 2. Items specified in individual product Sections.

1.02 RELATED REQUIREMENTS

- A. Section 01 78 00 - Closeout Submittals: Operation and maintenance manuals.
- B. Other Specification Sections: Additional requirements for demonstration and training.

1.03 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures; except:
 - 1. Make all submittals specified in this section, and elsewhere where indicated for commissioning purposes, directly to the Commissioning Authority.
 - 2. Submit one copy to the Commissioning Authority, not to be returned.
 - 3. Make commissioning submittals on time schedule specified by Commissioning Authority.
 - 4. Submittals indicated as "Draft" are intended for the use of the Commissioning Authority in preparation of overall Training Plan; submit in editable electronic format, Microsoft Word 2003 preferred.
- B. Draft Training Plans: Owner will designate personnel to be trained; tailor training to needs and skill-level of attendees.
 - 1. Submit to Commissioning Authority for review and inclusion in overall training plan.
 - 2. Submit not less than four weeks prior to start of training.
 - 3. Revise and resubmit until acceptable.
 - 4. Provide an overall schedule showing all training sessions.
 - 5. Include at least the following for each training session:
 - a. Identification, date, time, and duration.
 - b. Description of products and/or systems to be covered.
 - c. Name of firm and person conducting training; include qualifications.
 - d. Intended audience, such as job description.
 - e. Objectives of training and suggested methods of ensuring adequate training.
 - f. Methods to be used, such as classroom lecture, live demonstrations, hands-on, etc.
 - g. Media to be used, such as slides, hand-outs, etc.
 - h. Training equipment required, such as projector, projection screen, etc., to be provided by Contractor.
- C. Training Manuals: Provide training manual for each attendee; allow for minimum of two attendees per training session.
 - 1. Include applicable portion of O&M manuals.
 - 2. Include copies of all hand-outs, slides, overheads, video presentations, etc., that are not included in O&M manuals.

3. Provide one extra copy of each training manual to be included with operation and maintenance data.
- D. Training Reports:
1. Identification of each training session, date, time, and duration.
 2. Sign-in sheet showing names and job titles of attendees.
 3. List of attendee questions and written answers given, including copies of and references to supporting documentation required for clarification; include answers to questions that could not be answered in original training session.
 4. Include Commissioning Authority's formal acceptance of training session.
- E. Video Recordings: Submit digital video recording of each demonstration and training session for Owner's subsequent use.
1. Format: DVD Disc.
 2. Label each disc and container with session identification and date.

1.04 QUALITY ASSURANCE

- A. Instructor Qualifications: Familiar with design, operation, maintenance and troubleshooting of the relevant products and systems.
1. Provide as instructors the most qualified trainer of those contractors and/or installers who actually supplied and installed the systems and equipment.
 2. Where a single person is not familiar with all aspects, provide specialists with necessary qualifications.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 DEMONSTRATION - GENERAL

- A. Demonstrations conducted during system start-up do not qualify as demonstrations for the purposes of this section, unless approved in advance by Owner.
- B. Demonstrations conducted during Functional Testing need not be repeated unless Owner personnel training is specified.
- C. Demonstration may be combined with Owner personnel training if applicable.
- D. Operating Equipment and Systems: Demonstrate operation in all modes, including start-up, shut-down, seasonal changeover, emergency conditions, and troubleshooting, and maintenance procedures, including scheduled and preventive maintenance.
1. Perform demonstrations not less than two weeks prior to Substantial Completion.
 2. For equipment or systems requiring seasonal operation, perform demonstration for other season within six months.
- E. Non-Operating Products: Demonstrate cleaning, scheduled and preventive maintenance, and repair procedures.
1. Perform demonstrations not less than two weeks prior to Substantial Completion.

3.02 TRAINING - GENERAL

- A. Commissioning Authority will prepare the Training Plan based on draft plans submitted.
- B. Conduct training on-site unless otherwise indicated.
- C. Owner will provide classroom and seating at no cost to Contractor.
- D. Do not start training until Functional Testing is complete, unless otherwise specified or approved by the Commissioning Authority.
- E. Provide training in minimum two hour segments.
- F. The Commissioning Authority is responsible for determining that the training was satisfactorily completed and will provide approval forms.
- G. Training schedule will be subject to availability of Owner's personnel to be trained; re-schedule training sessions as required by Owner; once schedule has been approved by Owner failure to

conduct sessions according to schedule will be cause for Owner to charge Contractor for personnel "show-up" time.

- H. Review of Facility Policy on Operation and Maintenance Data: During training discuss:
 - 1. The location of the O&M manuals and procedures for use and preservation; backup copies.
 - 2. Typical contents and organization of all manuals, including explanatory information, system narratives, and product specific information.
 - 3. Typical uses of the O&M manuals.
- I. Product- and System-Specific Training:
 - 1. Review the applicable O&M manuals.
 - 2. For systems, provide an overview of system operation, design parameters and constraints, and operational strategies.
 - 3. Review instructions for proper operation in all modes, including start-up, shut-down, seasonal changeover and emergency procedures, and for maintenance, including preventative maintenance.
 - 4. Provide hands-on training on all operational modes possible and preventive maintenance.
 - 5. Emphasize safe and proper operating requirements; discuss relevant health and safety issues and emergency procedures.
 - 6. Discuss common troubleshooting problems and solutions.
 - 7. Discuss any peculiarities of equipment installation or operation.
 - 8. Discuss warranties and guarantees, including procedures necessary to avoid voiding coverage.
 - 9. Review recommended tools and spare parts inventory suggestions of manufacturers.
 - 10. Review spare parts and tools required to be furnished by Contractor.
 - 11. Review spare parts suppliers and sources and procurement procedures.
- J. Be prepared to answer questions raised by training attendees; if unable to answer during training session, provide written response within three days.

END OF SECTION

SECTION 02 41 00
DEMOLITION

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Selective demolition of built site elements.
- B. Selective demolition of building elements for alteration purposes.

1.02 RELATED REQUIREMENTS

- A. Section 01 50 00 - Temporary Facilities and Controls: Site fences, security, protective barriers, and waste removal.
- B. Section 01 60 00 - Product Requirements: Handling and storage of items removed for salvage and relocation.
- C. Section 01 70 00 - Execution and Closeout Requirements: Project conditions; protection of bench marks, survey control points, and existing construction to remain; reinstallation of removed products; temporary bracing and shoring.

1.03 REFERENCE STANDARDS

- A. 29 CFR 1926 - U.S. Occupational Safety and Health Standards; current edition.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Site Plan: Showing:
 - 1. Vegetation to be protected.
 - 2. Areas for temporary construction and field offices.
 - 3. Areas for temporary and permanent placement of removed materials.
- C. Demolition Plan: Submit demolition plan as specified by OSHA and local authorities.
 - 1. Indicate extent of demolition, removal sequence, bracing and shoring, and location and construction of barricades and fences.
 - 2. Identify demolition firm and submit qualifications.
- D. Project Record Documents: Accurately record actual locations of capped and active utilities and subsurface construction.

1.05 QUALITY ASSURANCE

- A. Demolition Firm Qualifications: Company specializing in the type of work required.
 - 1. Minimum of three years of documented experience.

PART 3 EXECUTION

2.01 SCOPE

- A. Remove the building and site elements as shown on the drawings.
- B. Remove other items indicated, for salvage and relocation.

2.02 GENERAL PROCEDURES AND PROJECT CONDITIONS

- A. Comply with other requirements specified in Section 01 70 00.
- B. Comply with applicable codes and regulations for demolition operations and safety of adjacent structures and the public.
 - 1. Obtain required permits.
 - 2. Use of explosives is not permitted.
 - 3. Take precautions to prevent catastrophic or uncontrolled collapse of structures to be removed; do not allow worker or public access within range of potential collapse of unstable structures.
 - 4. Provide, erect, and maintain temporary barriers and security devices.

5. Use physical barriers to prevent access to areas that could be hazardous to workers or the public.
 6. Conduct operations to minimize effects on and interference with adjacent structures and occupants.
 7. Do not close or obstruct roadways or sidewalks without permit.
 8. Conduct operations to minimize obstruction of public and private entrances and exits; do not obstruct required exits at any time; protect persons using entrances and exits from removal operations.
 9. Obtain written permission from owners of adjacent properties when demolition equipment will traverse, infringe upon or limit access to their property.
- C. Do not begin removal until receipt of notification to proceed from Owner.
 - D. Do not begin removal until built elements to be salvaged or relocated have been removed.
 - E. Do not begin removal until vegetation to be relocated has been removed and specified measures have been taken to protect vegetation to remain.
 - F. Protect existing structures and other elements that are not to be removed.
 1. Provide bracing and shoring.
 2. Prevent movement or settlement of adjacent structures.
 3. Stop work immediately if adjacent structures appear to be in danger.
 - G. Minimize production of dust due to demolition operations; do not use water if that will result in ice, flooding, sedimentation of public waterways or storm sewers, or other pollution.
 - H. If hazardous materials are discovered during removal operations, stop work and notify Architect and Owner; hazardous materials include regulated asbestos containing materials, lead, PCB's, and mercury.
 - I. Perform demolition in a manner that maximizes salvage and recycling of materials.
 1. Dismantle existing construction and separate materials.
 2. Set aside reusable, recyclable, and salvageable materials; store and deliver to collection point or point of reuse.

2.03 EXISTING UTILITIES

- A. Coordinate work with utility companies; notify before starting work and comply with their requirements; obtain required permits.
- B. Protect existing utilities to remain from damage.
- C. Do not disrupt public utilities without permit from authority having jurisdiction.
- D. Do not close, shut off, or disrupt existing life safety systems that are in use without at least 7 days prior written notification to Owner.
- E. Do not close, shut off, or disrupt existing utility branches or take-offs that are in use without at least 3 days prior written notification to Owner.
- F. Locate and mark utilities to remain; mark using highly visible tags or flags, with identification of utility type; protect from damage due to subsequent construction, using substantial barricades if necessary.
- G. Remove exposed piping, valves, meters, equipment, supports, and foundations of disconnected and abandoned utilities.
- H. Prepare building demolition areas by disconnecting and capping utilities outside the demolition zone; identify and mark utilities to be subsequently reconnected, in same manner as other utilities to remain.

2.04 SELECTIVE DEMOLITION FOR ALTERATIONS

- A. Drawings showing existing construction and utilities are based on casual field observation and existing record documents only.
 1. Verify that construction and utility arrangements are as indicated.
 2. Report discrepancies to Architect before disturbing existing installation.

3. Beginning of demolition work constitutes acceptance of existing conditions that would be apparent upon examination prior to starting demolition.
- B. Separate areas in which demolition is being conducted from other areas that are still occupied.
 1. Provide, erect, and maintain temporary dustproof partitions of construction specified in Section 01 50 00 in locations indicated on drawings.
- C. Maintain weatherproof exterior building enclosure except for interruptions required for replacement or modifications; take care to prevent water and humidity damage.
- D. Remove existing work as indicated and as required to accomplish new work.
 1. Remove rotted wood, corroded metals, and deteriorated masonry and concrete; replace with new construction specified.
 2. Remove items indicated on drawings.
- E. Services (Including but not limited to HVAC, Plumbing, Fire Protection, Electrical, and Telecommunications): Remove existing systems and equipment as indicated.
 1. Maintain existing active systems that are to remain in operation; maintain access to equipment and operational components.
 2. Where existing active systems serve occupied facilities but are to be replaced with new services, maintain existing systems in service until new systems are complete and ready for service.
 3. Verify that abandoned services serve only abandoned facilities before removal.
 4. Remove abandoned pipe, ducts, conduits, and equipment, including those above accessible ceilings; remove back to source of supply where possible, otherwise cap stub and tag with identification.
- F. Protect existing work to remain.
 1. Prevent movement of structure; provide shoring and bracing if necessary.
 2. Perform cutting to accomplish removals neatly and as specified for cutting new work.
 3. Repair adjacent construction and finishes damaged during removal work.
 4. Patch as specified for patching new work.

2.05 DEBRIS AND WASTE REMOVAL

- A. Remove debris, junk, and trash from site.
- B. Leave site in clean condition, ready for subsequent work.
- C. Clean up spillage and wind-blown debris from public and private lands.

END OF SECTION

SECTION 06 10 00
ROUGH CARPENTRY

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Rough opening framing for doors, windows, and roof openings.
- B. Fire retardant treated wood materials.
- C. Miscellaneous framing and sheathing.
- D. Concealed wood blocking, nailers, and supports.
- E. Miscellaneous wood nailers, furring, and grounds.

1.02 RELATED REQUIREMENTS

- A. Section 07 62 00 - Sheet Metal Flashing and Trim: Flashings at wall openings.

1.03 REFERENCE STANDARDS

- A. ASTM A153/A153M - Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware; 2016a.
- B. ASTM D2898 - Standard Test Methods for Accelerated Weathering of Fire-Retardant-Treated Wood for Fire Testing; 2010 (Reapproved 2017).
- C. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2015a.
- D. AWPA U1 - Use Category System: User Specification for Treated Wood; 2017.
- E. PS 1 - Structural Plywood; 2009.
- F. PS 20 - American Softwood Lumber Standard; 2015.
- G. SPIB (GR) - Grading Rules; 2014.

1.04 DELIVERY, STORAGE, AND HANDLING

- A. General: Cover wood products to protect against moisture. Support stacked products to prevent deformation and to allow air circulation.
- B. Fire Retardant Treated Wood: Prevent exposure to precipitation during shipping, storage, or installation.

PART 2 PRODUCTS

2.01 GENERAL REQUIREMENTS

- A. Dimension Lumber: Comply with PS 20 and requirements of specified grading agencies.
 - 1. Species: Southern Pine, unless otherwise indicated.
 - 2. If no species is specified, provide any species graded by the agency specified; if no grading agency is specified, provide lumber graded by any grading agency meeting the specified requirements.
 - 3. Grading Agency: Any grading agency whose rules are approved by the Board of Review, American Lumber Standard Committee (www.alsc.org) and who provides grading service for the species and grade specified; provide lumber stamped with grade mark unless otherwise indicated.

2.02 DIMENSION LUMBER FOR CONCEALED APPLICATIONS

- A. Grading Agency: Southern Pine Inspection Bureau, Inc; SPIB (GR).
- B. Sizes: Nominal sizes as indicated on drawings, S4S.
- C. Moisture Content: S-dry or MC19.
- D. Stud Framing (2 by 2 through 2 by 6 (50 by 50 mm through 50 by 150 mm)):
 - 1. Species: Any allowed under referenced grading rules.
 - 2. Grade: No. 2.

- E. Miscellaneous Framing, Blocking, Nailers, Grounds, and Furring:
 - 1. Lumber: S4S, No. 2 or Standard Grade.
 - 2. Boards: Standard or No. 3.

2.03 CONSTRUCTION PANELS

- A. Wall Sheathing: Plywood, PS 1, Grade C-D, Exposure I.

2.04 ACCESSORIES

- A. Fasteners and Anchors:
 - 1. Metal and Finish: Hot-dipped galvanized steel complying with ASTM A153/A153M for high humidity and preservative-treated wood locations, unfinished steel elsewhere.
 - 2. Drywall Screws: Bugle head, hardened steel, power driven type, length three times thickness of sheathing.
 - 3. Anchors: Toggle bolt type for anchorage to hollow masonry.
- B. Water-Resistive Barrier: As specified in Section 07 25 00.
- C. Building Paper: Water resistant Kraft paper.

2.05 FACTORY WOOD TREATMENT

- A. Treated Lumber and Plywood: Comply with requirements of AWPA U1 - Use Category System for wood treatments determined by use categories, expected service conditions, and specific applications.
 - 1. Fire-Retardant Treated Wood: Mark each piece of wood with producer's stamp indicating compliance with specified requirements.
- B. Fire Retardant Treatment:
 - 1. Manufacturers:
 - a. Lonza Group: www.wolmanizedwood.com/#sle.
 - b. Hoover Treated Wood Products, Inc: www.frtw.com/#sle.
 - c. Koppers, Inc: www.koppersperformancechemicals.com/#sle.
 - d. Viance, LLC: www.treatedwood.com/#sle.
 - e. or equal to or superior to substitute approved by Architect and Owner.
 - f. Substitutions: See Section 01 60 00 - Product Requirements.
 - 2. Interior Type A: AWPA U1, Use Category UCFA, Commodity Specification H, low temperature (low hygroscopic) type, chemically treated and pressure impregnated; capable of providing a maximum flame spread index of 25 when tested in accordance with ASTM E84, with no evidence of significant combustion when test is extended for an additional 20 minutes.
 - a. Kiln dry wood after treatment to a maximum moisture content of 19 percent for lumber and 15 percent for plywood.
 - b. Treat rough carpentry items as indicated .
 - c. Do not use treated wood in applications exposed to weather or where the wood may become wet.

PART 3 EXECUTION

3.01 PREPARATION

- A. Coordinate installation of rough carpentry members specified in other sections.

3.02 INSTALLATION - GENERAL

- A. Select material sizes to minimize waste.
- B. Reuse scrap to the greatest extent possible; clearly separate scrap for use on site as accessory components, including: shims, bracing, and blocking.
- C. Where treated wood is used on interior, provide temporary ventilation during and immediately after installation sufficient to remove indoor air contaminants.

3.03 BLOCKING, NAILERS, AND SUPPORTS

- A. Provide framing and blocking members as indicated or as required to support finishes, fixtures, specialty items, and trim.
- B. In framed assemblies that have concealed spaces, provide solid wood fireblocking as required by applicable local code, to close concealed draft openings between floors and between top story and roof/attic space; other material acceptable to code authorities may be used in lieu of solid wood blocking.
- C. In walls, provide blocking attached to studs as backing and support for wall-mounted items, unless item can be securely fastened to two or more studs or other method of support is explicitly indicated.
- D. Where ceiling-mounting is indicated, provide blocking and supplementary supports above ceiling, unless other method of support is explicitly indicated.

3.04 INSTALLATION OF CONSTRUCTION PANELS

- A. Wall Sheathing: Secure with long dimension perpendicular to wall studs, with ends over firm bearing and staggered, using screws.
 - 1. Place water-resistive barrier horizontally over wall sheathing, weather lapping edges and ends.

3.05 TOLERANCES

- A. Framing Members: 1/4 inch (6 mm) from true position, maximum.
- B. Variation from Plane (Other than Floors): 1/4 inch in 10 feet (2 mm/m) maximum, and 1/4 inch in 30 feet (7 mm in 10 m) maximum.

3.06 CLEANING

- A. Do not leave any wood, shavings, sawdust, etc. on the ground or buried in fill.
- B. Prevent sawdust and wood shavings from entering the storm drainage system.

END OF SECTION

SECTION 06 20 00
FINISH CARPENTRY

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Finish carpentry items.
- B. Wood casings and moldings.
- C. Hardware and attachment accessories.

1.02 RELATED REQUIREMENTS

- A. Section 06 10 00 - Rough Carpentry: Support framing, grounds, and concealed blocking.
- B. Section 09 91 13 - Exterior Painting: Painting of finish carpentry items.
- C. Section 09 91 23 - Interior Painting: Painting of finish carpentry items.

1.03 REFERENCE STANDARDS

- A. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2015a.
- B. AWI (QCP) - Quality Certification Program; Current Edition.
- C. AWI/AWMAC/WI (AWS) - Architectural Woodwork Standards; 2014, with Errata (2018).
- D. AWMAC/WI (NAAWS) - North American Architectural Woodwork Standards, U.S. Version 3.1; 2016, with Errata (2018).
- E. HPVA HP-1 - American National Standard for Hardwood and Decorative Plywood; 2016.
- F. WDMA I.S. 4 - Industry Specification for Preservative Treatment for Millwork; 2015a.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data:
 - 1. Provide manufacturer's product data, storage and handling instructions for factory-fabricated units.
 - 2. Provide data on fire retardant treatment materials and application instructions.
 - 3. Provide instructions for attachment hardware, finish hardware, and _____.
- C. Shop Drawings: Indicate materials, component profiles, fastening methods, jointing details, and accessories.
 - 1. Provide the information required by AWI/AWMAC/WI (AWS) or AWMAC/WI (NAAWS).
- D. Samples: Submit two samples of finish plywood, 12x12 inch (____by____ mm) in size illustrating wood grain and specified finish.
- E. Samples: Submit two samples of wood trim 12 inch (____ mm) long.

1.05 MOCK-UP

- A. Provide panel with board batten mock-up, full size, illustrating finish and construction.
- B. See Section 01 40 00 - Quality Requirements for additional requirements.
- C. Locate where directed.
- D. Mock-up may remain as part of the Work.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Store finish carpentry items under cover, elevated above grade, and in a dry, well-ventilated area not exposed to heat or sunlight.
- B. Protect from moisture damage.
- C. Handle materials and products to prevent damage to edges, ends, or surfaces.

PART 2 PRODUCTS

2.01 FINISH CARPENTRY ITEMS

- A. Surface Burning Characteristics: Provide materials having fire and smoke properties as required by applicable code.
- B. Exterior Woodwork Items:
 - 1. Window Casings and Moldings: Rough sawn clear cedar to match existing; prepare for paint finish.
- C. Interior Woodwork Items:
 - 1. Battens, Moldings, Bases, Casings, and Miscellaneous Trim: Rough sawn clear cedar to match existing; prepare for paint finish.
 - 2. Wood paneling to match existing: Rough sawn clear cedar to match existing; prepare for paint finish..

2.02 FASTENINGS

- A. Fasteners: Of size and type to suit application; _____ finish in concealed locations and _____ finish in exposed locations.
- B. Fasteners for Exterior Applications: Stainless steel; length required to penetrate wood substrate 1-1/2 inch (38 mm) minimum.

2.03 FABRICATION

- A. Shop assemble work for delivery to site, permitting passage through building openings.
- B. When necessary to cut and fit on site, provide materials with ample allowance for cutting. Provide trim for scribing and site cutting.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify adequacy of backing and support framing.
- B. Verify mechanical, electrical, and building items affecting work of this section are placed and ready to receive this work.

3.02 INSTALLATION

- A. Set and secure materials and components in place, plumb and level.
- B. Carefully scribe work abutting other components, with maximum gaps of 1/32 inch (0.79 mm). Do not use additional overlay trim to conceal larger gaps.

3.03 PREPARATION FOR SITE FINISHING

- A. Set exposed fasteners. Apply wood filler in exposed fastener indentations. Sand work smooth.
- B. Site Finishing: See Section 09 91 13 and 09 91 23.
- C. Before installation, prime paint surfaces of items or assemblies to be in contact with cementitious materials.

3.04 TOLERANCES

- A. Maximum Variation from True Position: 1/16 inch (1.6 mm).
- B. Maximum Offset from True Alignment with Abutting Materials: 1/32 inch (0.79 mm).

END OF SECTION

SECTION 07 62 00
SHEET METAL FLASHING AND TRIM

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Miscellaneous flashings.
- B. Through-wall flashings.

1.02 RELATED SECTIONS

- A. Section 06 10 10 - Rough Carpentry.

1.03 REFERENCES

- A. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc Coated (Galvanized) by the Hot-Dip Process, Structural (Physical) Quality.
- B. ASTM B32 - Standard Specification for Solder Metal.
- C. ASTM B370 - Standard Specification for Copper Sheet and Strip for Building Construction.
- D. ASTM D2178 - Standard Specification for Asphalt - Saturated Glass Felt Used in Roofing and Waterproofing.
- E. FS TT-C-494 - Coating Compound, Bituminous, Solvent Type, Acid Resistant.
- F. SMACNA (Sheet Metal and Air Conditioning Contractors National Association) - Architectural Sheet Metal Manual, Fifth Edition, 1993.

1.04 DESIGN REQUIREMENTS

- A. Sheet Metal Flashings: Comply with the criteria of SMACNA "Architectural Sheet Metal Manual."

1.05 SUBMITTALS FOR REVIEW

- A. Section 01 30 00 - Administrative Requirements: Procedures for submittals.
- B. Shop Drawings: Indicate material profile, jointing pattern, jointing details, fastening methods, flashings, terminations, and installation details.
- C. Product Data: Provide data on sheet metal material and prefabricated components.
- D. Selection Samples: Submit manufacturer's printed literature identifying all standard and premium colors/finishes available for initial color selection.
- E. Verification Samples: Submit two appropriately sized samples of coping and gravel stop, illustrating component shape, finish, and color.

1.06 SUBMITTALS AT PROJECT CLOSEOUT

- A. Section 01700 - Execution Requirements Procedures for submittals.
- B. Section 01 78 00 - Closeout Submittals
- C. Warranty: Submit manufacturer's 20 year material warranty. Ensure forms have been completed in Owner's name and registered with manufacturer.
- D. Warranty: Submit contractor's two year workmanship warranty.

1.07 QUALITY ASSURANCE

- A. Perform work in accordance with SMACNA Architectural Sheet Metal Manual requirements and standard details, except as otherwise noted.
- B. Fabricator and Installer Qualifications: Company specializing in architectural sheet metal work with five years documented experience.

1.08 PRE-INSTALLATION MEETING

- A. Section 01 70 00 - Execution Requirements: Pre-installation meeting.
- B. Convene One week before starting work of this section.

1.09 DELIVERY, STORAGE, AND PROTECTION

- A. Section 01 60 00 - Product Requirements: Transport, handle, store, and protect.
- B. Stock material to prevent twisting, bending, and abrasion, and to provide ventilation. Slope metal sheets to ensure drainage.
 - 1. When material is stored on the roof it must be placed on ½" minimum plywood on 1" rigid insulation. Ends of plywood shall exceed end of sheet metal goods by 2'-0".
- C. Prevent contact with materials which may cause discoloration or staining.
- D. All field cutting of sheet metal performed over new roofing shall be permitted only where the new roof is protected by ½" minimum plywood on 1" rigid insulation.

1.10 PROJECT CONDITIONS

- A. Project Coordination: Section 01 30 00 - Administrative Requirements.

1.11 WARRANTY

- A. Section 01 78 00 - Closeout Submittals
- B. Sheet Metal Contractor to issue workmanship warranty to correct defective work within a two year period after Date of Substantial Completion. Defective work includes failure of watertightness or seals and oil canning due to rupture restricted expansion/contractors or faulty workmanship.
- C. Material warranty from the sheet metal manufacturer for a period of 20 years against deterioration of color, chalking and film integrity.

PART 2 PRODUCTS

2.01 SHEET MATERIALS

- A. Pre-Finished Galvanized Steel Sheet: ASTM A653/A653M, G90 zinc coating; 0.02 inch, 24 gauge core steel, shop pre-coated with PVDF (polyvinylidene fluoride) coating; color to match existing siding color.
- B. Stainless Steel: ASTM A167, Type 304, soft temper, 0.015 inch thick; smooth No. 4 finish.

2.02 ACCESSORIES

- A. Fasteners: Stainless steel with neoprene washers.
- B. Primer: Zinc molybdate type.
- C. Protective Backing Paint: Zinc molybdate alkyd.
- D. Sealant: Polyurethane type, manufactured by
 - 1. Tremco: Dymeric
 - 2. Sonnoborn: NPI.
- E. Termination Bar: 1/8" x 1" stainless steel bar stock.
- F. Splash Pads: Precast concrete type, of sizes and profiles indicated; minimum 3000 psi at 28 days, with minimum 5 percent air entrainment.
- G. Solder: ASTM B32; 50/50 type.
- H. Reglets: Surface mounted type, galvanized steel; face and ends covered with plastic tape;

2.03 FABRICATION - GENERAL

- A. Fabricate continuous cleats of same materials as coping minimum 3 inches wide, interlocking with sheet a min. of ½".
 - 1. Drill pilot holes at 4" o.c. for attachment to wood.
 - 2. Drill pilot holes at 6" o.c. for attachment to masonry or concrete.
- B. All fastener locations will have predrilled pilot holes:
 - 1. Nails - 1/4" diameter @ 4" o.c.
 - 2. Screw Fasteners - 5/16" diameter @ 1'-0" o.c.
- C. Form pieces in longest possible lengths.

- D. Hem exposed edges on underside 1/2 inch; miter and seam corners.
- E. Form material with flat lock seams, except where otherwise indicated. At moving joints, use sealed lapped, bayonet-type or interlocking hooked seams.
- F. Fabricate corners from one piece with minimum 24-inch long legs; drive cleat for rigidity, seal with sealant and post finished to match adjacent finish..
- G. Fabricate vertical faces with bottom edge formed outward 1/2 inch and hemmed to form drip.
- H. Anchorage Devices: in accordance with SMACNA requirements.
- I. Seal metal joints.

2.04 FACTORY FINISHING

- A. PVDF coating: Multiple coat, thermally cured, fluoropolymer system conforming to AAMA 605.2.
- B. Primer Coat: Finish concealed side of metal sheets with primer compatible with finish system, as recommended by finish system manufacturer.
 - 1. All metal materials to be delivered to the site with protective, strippable plastic film.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Do not start sheet metal work until conditions relevant to sheet metal work are acceptable. Commencing of work will indicate acceptance of condition.

3.02 PREPARATION

- A. Install starter and edge strips, and cleats before starting installation.
- B. Paint dissimilar metals with bituminous paint to form a complete barrier.

3.03 INSTALLATION

- A. Insert flashings into reglets to form tight fit. Secure in place with lead wedges. Pack remaining spaces with foam rod. Prime surfaces to receive sealant and seal flashings into reglets with sealant.
- B. Secure flashings in place using concealed fasteners as indicated in the drawings.
- C. Thru Wall Flashing: Coordinate with masonry contractor.
 - 1. Set backer plates.
 - 2. Notch and remove portion of receiver so that horizontal flanges lap 3" and receivers butt. Set lap in sealant and pop rivet. Cover lap with ice and water shield.
 - 3. At corners, lap horizontal flanges in sealant and pop rivet.
- D. Miscellaneous Flashings: Install as indicated on drawings.
 - 1. Coordinate with interfacing contractors.

3.04 CLEANING

- A. Leave material clean and free of stains.
- B. Remove all sheet metal debris from roof top daily.
- C. Remove all sheet metal debris from site daily.

3.05 FIELD QUALITY CONTROL

- A. Section 01 40 00 - Quality Requirements: Field inspection.
- B. Inspection will involve surveillance of work during installation to ascertain compliance with specified requirements.

END OF SECTION

SECTION 08 22 23
ALUMINUM-CLAD WOOD PATIO DOORS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Aluminum-clad wood commercial out-swing French hinged doors and gliding patio doors.

1.02 RELATED SECTIONS

- A. Section 07270 (07 27 00) - Air Barriers: Water-resistant barrier.
- B. Section 07920 (07 92 00) - Joint Sealants: Sealants and caulking.
- C. Section 08710 (08 71 00) - Door Hardware.

1.03 REFERENCES

- A. American Architectural Manufacturers Association (AAMA):
 - 1. AAMA 502 - Voluntary Specification for Field Testing of Windows and Sliding Doors.
 - 2. AAMA 2603 - Voluntary Specification, Performance Requirements and Test Procedures for Pigmented Organic Coatings on Aluminum Extrusions and Panels.
 - 3. AAMA 2605 - Voluntary Specification, Performance Requirements and Test Procedures for Superior Performing Organic Coatings on Aluminum Extrusions and Panels.
- B. American Society for Testing and Materials (ASTM):
 - 1. ASTM B 117 - Operating Salt Spray (Fog) Apparatus.
 - 2. ASTM C 1036 - Flat Glass.
 - 3. ASTM C 1048 - Heat-Treated Flat Glass - Kind HS, Kind FT Coated and Uncoated Glass.
 - 4. ASTM D 1149 - Rubber Deterioration - Surface Ozone Cracking in a Chamber.
 - 5. ASTM D 2803 - Filiform Corrosion Resistance of Organic Coatings on Metal.
 - 6. ASTM D 3656 - Insect Screening and Louver Cloth Woven from Vinyl-Coated Glass Yarns.
 - 7. ASTM D 4060 - Abrasion Resistance of Organic Coatings by the Taber Abraser.
 - 8. ASTM E 283 - Rate of Air Leakage Through Exterior Windows, Curtain Walls and Doors Under Specified Pressure Difference Across the Specimen.
 - 9. ASTM E 330 - Structural Performance of Exterior Windows, Curtain Walls and Doors by Uniform Static Air Pressure Difference.
 - 10. ASTM E 547 - Water Penetration of Exterior Windows, Curtain Walls and Doors by Cyclic Static Air Pressure Differential.
 - 11. ASTM E 1105 - Standard Test Method for Field Determination of Water Penetration of Exterior Windows, Doors, Skylights and Curtain Walls by Uniform Static Air Pressure Difference
 - 12. ASTM G 85 - Modified Salt Spray (Fog) Testing.
- C. Window and Door Manufacturers Association (WDMA):
 - 1. AAMA/WDMA/CSA 101/I.S.2/A440 - North American Fenestration Standard/Specification for windows, doors and skylights
 - 2. WDMA I.S.4 - Industry Specification for Preservative Treatment for Millwork.

1.04 PERFORMANCE REQUIREMENTS

- A. Doors not rated due to 0 psf water performance with low profile sill.
- B. Door Unit Air Leakage, ASTM E 283, 1.57 psf (25 mph): 0.15 cfm per square foot of frame or less.

1.05 SUBMITTALS

- A. Comply with Division 1 requirements.
- B. Product Data: Submit manufacturer's product data, including installation instructions.
- C. Shop Drawings: Submit manufacturer's shop drawings, indicating dimensions, construction, component connections and locations, anchorage methods and locations, hardware locations, and installation details.

- D. Samples: Submit full-size or partial full-size sample of door illustrating glazing system, quality of construction, and color of finish.

1.06 QUALITY ASSURANCE

- A. Mockup:
 - 1. Provide sample installation for field testing door performance requirements and to determine acceptability of door installation methods.
 - 2. Approved mockup shall represent minimum quality required for the Work.
- B. Approved mockup may remain in place within the Work.
 - 1. Installer Qualifications:
 - a. Minimum five years' experience in the commercial installation of products required for the Project.
 - b. Experience on at least five projects of similar size, type and complexity as the Project.
 - c. An entity utilizing workers competent in techniques required by manufacturer for product types and applications indicated

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Delivery: Deliver materials to site undamaged in manufacturer's or sales branch's original, unopened containers and packaging, with labels clearly identifying manufacturer and product name. Include installation instructions.
- B. Storage: Store materials in an upright position, off ground, under cover, and protected from weather, direct sunlight, and construction activities.
- C. Handling: Protect materials and finish during handling and installation to prevent damage.

1.08 WARRENTY

- A. Warranty Period: 5 years from date of Substantial Completion.

PART 2 PRODUCTS

2.01 MANUFACTURER

- A. Basis of Design:
 - 1. Andersen E-series Patio Doors
- B. or equal to or superior to substitute approved by Architect and Owner by Marvin or Pella
- C. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 ALUMINUM-CLAD WOOD COMMERCIAL OUT-SWING FRENCH HINGED DOORS AND SLIDING PATIO DOORS

- A. Aluminum-Clad Wood Commercial Out-Swing Single and Double Panel French Hinged Doors and Double Panel Gliding Patio Doors: Architect Series factory-assembled aluminum-clad wood doors with outward-swing and gliding door panels installed in frame.
- B. Frame:
 - 1. Select woods, water-repellent, preservative-treated in accordance with WDMA I.S.-4.
 - 2. Interior Exposed Surfaces: Douglas Fir veneered and edge-banded with no visible fastener holes. Stained: Factory-applied before assembly, water-based,
 - 3. Exterior Surfaces: Clad with extruded aluminum at head and jambs, minimum .05" thickness.
 - 4. Metal Sill: Solid aluminum, ADA approved, low profile.
- C. Finish: To be selected from manufacturer's full range of standard colors.
- D. Overall Frame Depth: As indicated on the drawings.
- E. Door Panel:
 - 1. Select woods, water-repellent, preservative-treated with EnduraGuard in accordance with WDMA I.S.-4.
 - 2. Panels: Three-ply construction. Randomly finger-jointed blocks laminated with water-resistant glue.

3. Interior Exposed Surfaces: Pine core veneered with Douglas Fir, with glass stops.
 4. Exterior Surfaces: Clad with painted aluminum. Factory applied baked on polyester enamel in compliance with AAMA 2605 Clad with aluminum.
- F. Corners: Urethane-sealed and secured with metal fasteners.
- G. Sash Thickness: As indicated on Drawings.
- H. Weather Strip:
1. Urethane foam.

2.03 GLAZING

- A. Glazing:
1. Float Glass: ASTM C 1036, Quality 1.
 2. Tempered Glass: ASTM C 1048.
- B. Type: Urethane-glazed, dual-seal, tempered insulating glass with [interior wood removable stops. Clear, multi-layer Low-E coated with argon, Low-E coated.
- C. Integral Light Technology Glazing and Grilles:
1. Insulating glass contains non-glare spacer between the panes of glass.
 2. Grid: Adhered to glass on double pane and a metal spacer on triple pane.
- D. Bars shall be adhered to both sides of insulating glass with VHB acrylic adhesive tape and aligned with non-glare grid.
- E. Finish: Finish color matches interior and exterior finish colors.

2.04 HARDWARE

2.05 HINGES:

- A. Hinged Patio Door
1. Door Handle selected from manufacturers standard finish.
 2. Hinge type and finish: Heavy duty commercial grade, finish to match door handle.
 3. Patio Door Lock Type and Finish: Keyed exterior, finish to match handle.
- B. Gliding Patio Door
1. Gliding Panel Latch Type and Material: Single-actuation, two-point locking system, galvanized steel and engineered polymer components.
 2. Gliding Panel Latch Type and Material: Single-actuation, two-point locking system, galvanized steel and engineered polymer components.
 3. Gliding Patio Door Auxiliary Foot Lock Type and Finish: Foot-operated device designed to secure sliding panel in track, finish to match door handle.
 4. Gliding Patio Door Lock Type and Finish: Unkeyed exterior, finish to match handle.
 5. Retractable Insect Screens – Top hung, aluminum framed, fiberglass mesh insect screen. Painted finish to match frame.

2.06 TOLERANCES

- A. Doors shall accommodate the following opening tolerances:
1. Vertical Dimensions Between High and Low Points: Plus 1/8 inch, minus 0 inch.
 2. Width Dimensions: Plus 1/8 inch, minus 0 inch.
 3. Building Columns or Masonry Openings: Plus or minus 1/8 inch from plumb.

2.07 FINISH

- A. Exterior Finish System:
1. Exterior aluminum surfaces shall be finished with the following multi-stage system:
 - a. Clean and etch aluminum surface of oxides.
 - b. Pre-treat with chrome phosphate conversion coating.
 - c. Pre-treat with chromic acid sealer/rinse.
 - d. Top coat with baked-on 70% fluoropolymer-based enamel.
 2. Color: To be selected from manufacturer's full range of standard colors.

3. Performance Requirements: Exterior aluminum finishes shall meet or exceed all performance requirements of AAMA 2605.
- B. Interior Finish: Factory finished stain. Color: To be selected from manufacturer's full range of standard colors.

2.08 INSTALLATION ACCESSORIES

- A. Flashing/Sealant Tape:
 1. Aluminum-foil-backed butyl window and door flashing tape.
 2. Maximum Total Thickness: 0.013 inch.
 3. UV resistant.
 4. Verify sealant compatibility with sealant manufacturer.
- B. Interior Insulating-Foam Sealant: Low-expansion, low-pressure polyurethane insulating window and door foam sealant.
- C. Exterior Perimeter Sealant: "Andersen Window and Door Installation Sealant" or equivalent high quality, multi-purpose sealant as specified in the joints sealant section.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Examine areas to receive doors. Notify Architect of conditions that would adversely affect installation or subsequent use. Do not proceed with installation until unsatisfactory conditions are corrected.

3.02 INSTALLATION

- A. Install doors in accordance with manufacturer's instructions and approved shop drawings.
- B. Install doors to be weather-tight and freely operating.
- C. Maintain alignment with adjacent work.
- D. Secure assembly to framed openings, plumb and square, without distortion.
- E. Integrate door system installation with exterior weather-resistant barrier using flashing/sealant tape. Apply and integrate flashing/sealant tape with weather-resistant barrier using watershed principles in accordance with door manufacturer's instructions.
- F. Place interior seal around door perimeter to maintain continuity of building thermal and air barrier using insulating-foam sealant.
- G. Seal door to exterior wall cladding with sealant and related backing materials at perimeter of assembly.
- H. Leave doors closed.

3.03 CLEANING

- A. Clean door frames and glass in accordance with Division 1 requirements.
- B. Do not use harsh cleaning materials or methods that would damage finish.
- C. Remove labels and visible markings.

3.04 PROTECTION

- A. Protect installed doors to ensure that, except for normal weathering, doors will be without damage or deterioration at time of substantial completion.

END OF SECTION

SECTION 08 52 23
ALUMINUM-CLAD WOOD FIXED-FRAME WINDOWS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Aluminum-clad wood fixed-frame windows.

1.02 RELATED SECTIONS

- A. Section 07270 (07 27 00) - Air Barriers: Water-resistant barrier.
- B. Section 07920 (07 92 00) - Joint Sealants: Sealants and caulking.

1.03 REFERENCES

- A. American Architectural Manufacturers Association (AAMA):
 - 1. AAMA 502 - Voluntary Specification for Field Testing of Windows and Sliding Doors.
 - 2. AAMA 2603 - Voluntary Specification, Performance Requirements and Test Procedures for Pigmented Organic Coatings on Aluminum Extrusions and Panels.
 - 3. AAMA 2605 - Voluntary Specification, Performance Requirements and Test Procedures for Superior Performing Organic Coatings on Aluminum Extrusions and Panels.
 - 4. AAMA 611 Voluntary Specification for Anodized Architectural Aluminum..
 - 5. AAMA 612 Voluntary Specification, Performance Requirements, and Test Procedures for Combined Coatings of Anodic Oxide and Transparent Organic Coatings on Architectural Aluminum.
- B. American Society for Testing and Materials (ASTM):
 - 1. ASTM B 117 - Operating Salt Spray (Fog) Apparatus.
 - 2. ASTM C1036 - Standard Specification for Flat Glass.
 - 3. ASTM C1048 - Standard Specification for Heat-Strengthened and Fully Tempered Flat Glass.
 - 4. AASTM D 1149 - Rubber Deterioration - Surface Ozone Cracking in a Chamber.
 - 5. ASTM D 2803 - Filliform Corrosion Resistance of Organic Coatings on Metal.
 - 6. ASTM D 4060 - Abrasion Resistance of Organic Coatings by the Taber Abraser.
 - 7. ASTM E 283 - Rate of Air Leakage Through Exterior Windows, Curtain Walls and Doors Under Specified Pressure Difference Across the Specimen.
 - 8. ASTM E 330 - Structural Performance of Exterior Windows, Curtain Walls and Doors by Uniform Static Air Pressure Difference.
 - 9. ASTM E 547 - Water Penetration of Exterior Windows, Curtain Walls and Doors by Cyclic Static Air Pressure Differential.
 - 10. ASTM E 1105 - Standard Test Method for Field Determination of Water Penetration of Exterior Windows, Doors, Skylights and Curtain Walls by Uniform Static Air Pressure Difference.
 - 11. ASTM G 85 - Modified Salt Spray (Fog) Testing.
- C. Window and Door Manufacturers Association (WDMA):
 - 1. AAMA/WDMA/CSA 101/I.S.2/A440 - North American Fenestration Standard/Specification for windows, doors and skylights
 - 2. WDMA I.S.4 - Industry Specification for Preservative Treatment for Millwork.

1.04 PERFORMANCE REQUIREMENTS

- A. Windows shall be Hallmark certified to a rating of FW-[AW] [CW]-PG specifications in accordance with ANSI/AAMA/WDMA 101/I.S.2/A440-08 or ANSI/AAMA/WDMA 101/I.S.2/A440-11.
- B. Window Unit Air Leakage, ASTM E 283, 6.24 psf (50 mph): 0.05 cfm per square foot of frame or less.
- C. Window Unit Water Penetration: No water penetration through window unit when tested in accordance with ASTM E 547, under static pressure of 14.2 psf (75 mph) after 4 cycles of 5 minutes each, with water being applied at a rate of 5 gallons per hour per square foot.

1.05 SUBMITTALS

- A. Comply with Division 1 requirements.
- B. Product Data: Submit manufacturer's product data, including installation instructions.
- C. Shop Drawings: Submit manufacturer's shop drawings, indicating dimensions, construction, component connections and locations, anchorage methods and locations, hardware locations, and installation details.
- D. Samples: Submit full-size or partial full-size sample of window illustrating glazing system, quality of construction, and color of finish.
- E. Warranty: Submit five (5) manufacturer's warranty.

1.06 QUALITY ASSURANCE

- A. Mockup:
 - 1. Provide sample installation for field testing window performance requirements and to determine acceptability of window installation methods.
 - 2. Approved mockup shall represent minimum quality required for the Work.
- B. Approved mockup may remain in place within the Work.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Delivery: Deliver materials to site undamaged in manufacturer's or sales branch's original, unopened containers and packaging, with labels clearly identifying manufacturer and product name. Include installation instructions.
- B. Storage: Store materials in an upright position, off ground, under cover, and protected from weather, direct sunlight, and construction activities.
- C. Handling: Protect materials and finish during handling and installation to prevent damage.

PART 2 PRODUCTS

2.01 MANUFACTURER

- A. Basis of Design:
 - 1. Andersen E-series metal clad wood windows.
- B. or equal to or superior to substitute approved by Architect and Owner by Marvin or Pella Windows
- C. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 ALUMINUM-CLAD WOOD FIXED-FRAME WINDOWS

- A. Aluminum-Clad Wood Fixed-Frame Windows: factory-assembled, aluminum-clad wood, fixed-frame windows.
- B. Frame:
 - 1. Select woods, water-repellent, preservative-treated with EnduraGuard® in accordance with WDMA I.S.-4. EnduraGuard includes water-repellency, three active fungicides and an insecticide applied to the frame.
 - 2. Interior Exposed Surfaces: Douglas Fir with no visible fastener holes.
 - 3. Exterior Surfaces: Clad with aluminum.
 - 4. Assembled with screws and concealed corner locks.
 - 5. Overall Frame Depth: As indicated on drawings.

2.03 GLAZING

- A. Glazing:
 - 1. Tempered Glass: ASTM C 1048.
- B. Type: Urethane-glazed, dual-seal, tempered insulating glass with [interior wood removable stops. Clear, multi-layer Low-E coated with argon, Low-E coated.

2.04 TOLERANCES

- A. Windows shall accommodate the following opening tolerances:

1. Vertical Dimensions Between High and Low Points: Plus 1/4 inch, minus 0 inch.
2. Width Dimensions: Plus 1/4 inch, minus 0 inch.
3. Building Columns or Masonry Openings: Plus or minus 1/4 inch from plumb.

2.05 FINISH

- A. Exterior Finish System:
 1. Painted Frame: Factory-applied baked-on silicone polyester enamel, in compliance with AAMA 2605 2.
 2. Color: To be selected from manufacturer's full range of standard colors.
- B. Interior Finish: Factory finished stain. Color: To be selected from manufacturer's full range of standard colors..

2.06 INSTALLATION ACCESSORIES

- A. Flashing/Sealant Tape:
 1. Aluminum-foil-backed butyl window and door flashing tape.
 2. Maximum Total Thickness: 0.013 inch.
 3. UV resistant.
 4. Verify sealant compatibility with sealant manufacturer.
- B. Interior Insulating-Foam Sealant: Low-expansion, low-pressure polyurethane insulating window and door foam sealant.
- C. Exterior Perimeter Sealant: "Andersen Window and Door Installation Sealant" or equivalent high quality, multi-purpose sealant as specified in the joints sealant section.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Examine areas to receive windows. Notify Architect of conditions that would adversely affect installation or subsequent use. Do not proceed with installation until unsatisfactory conditions are corrected.

3.02 INSTALLATION

- A. Install windows in accordance with manufacturer's instructions and approved shop drawings.
- B. Install windows to be weather-tight and freely operating.
- C. Maintain alignment with adjacent work.
- D. Secure assembly to framed openings, plumb and square, without distortion.
- E. Integrate window system installation with exterior weather-resistant barrier using flashing/sealant tape. Apply and integrate flashing/sealant tape with weather-resistant barrier using watershed principles in accordance with window manufacturer's instructions.
- F. Place interior seal around window perimeter to maintain continuity of building thermal and air barrier using insulating-foam sealant.
- G. Seal window to exterior wall cladding with sealant and related backing materials at perimeter of assembly.

3.03 CLEANING

- A. Clean window frames and glass in accordance with Division 1 requirements.
- B. Do not use harsh cleaning materials or methods that would damage finish.
- C. Remove labels and visible markings.

3.04 PROTECTION

- A. Protect installed windows to ensure that, except for normal weathering, windows will be without damage or deterioration at time of substantial completion.

END OF SECTION

SECTION 08 71 00
DOOR HARDWARE

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Hardware for aluminum clad wood hinged doors.
- B. Thresholds.
- C. Weatherstripping and gasketing.

1.02 RELATED REQUIREMENTS

- A. Section 07 92 00 - Joint Sealants: Sealants for setting exterior door thresholds.
- B. Section 08 22 23 - Aluminum clad wood hinged doors.

1.03 REFERENCE STANDARDS

- A. ADA Standards - Americans with Disabilities Act (ADA) Standards for Accessible Design; 2010.
- B. BHMA (CPD) - Certified Products Directory; 2017.
- C. BHMA A156.1 - American National Standard for Butts and Hinges; 2016.
- D. BHMA A156.2 - American National Standard for Bored and Preassembled Locks & Latches; 2017.
- E. BHMA A156.3 - American National Standard for Exit Devices; 2014.
- F. BHMA A156.4 - American National Standard for Door Controls - Closers; 2013.
- G. BHMA A156.6 - American National Standard for Architectural Door Trim; 2015.
- H. BHMA A156.8 - American National Standard for Door Controls - Overhead Stops and Holders; 2015.
- I. BHMA A156.15 - American National Standard for Release Devices - Closer Holder, Electromagnetic and Electromechanical; 2015.
- J. BHMA A156.16 - American National Standard for Auxiliary Hardware; 2013.
- K. BHMA A156.17 - American National Standard for Self Closing Hinges & Pivots; 2014.
- L. BHMA A156.18 - American National Standard for Materials and Finishes; 2016.
- M. BHMA A156.20 - American National Standard for Strap and Tee Hinges, and Hasps; 2006 (Reaffirmed 2012).
- N. BHMA A156.21 - American National Standard for Thresholds; 2014.
- O. BHMA A156.22 - American National Standard for Door Gasketing and Edge Seal Systems, Builders Hardware Manufacturers Association; 2017.
- P. BHMA A156.23 - American National Standard for Electromagnetic Locks; 2010.
- Q. BHMA A156.26 - American National Standard for Continuous Hinges; 2012.
- R. BHMA A156.115W - Hardware Preparation in Wood Doors with Wood or Steel Frames; 2006.
- S. DHI (H&S) - Sequence and Format for the Hardware Schedule; 1996.
- T. DHI WDHS.3 - Recommended Locations for Architectural Hardware for Flush Wood Doors; 1993; also in WDHS-1/WDHS-5 Series, 1996.
- U. ICC A117.1 - Accessible and Usable Buildings and Facilities; 2017.
- V. NFPA 70 - National Electrical Code; 2017.
- W. NFPA 80 - Standard for Fire Doors and Other Opening Protectives; 2016.
- X. NFPA 101 - Life Safety Code; 2017.
- Y. UL (DIR) - Online Certifications Directory; current listings at database.ul.com.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordinate the manufacture, fabrication, and installation of products that door hardware is installed on.
- B. Sequence installation to ensure utility connections are achieved in an orderly and expeditious manner.
- C. Furnish templates for door and frame preparation to manufacturers and fabricators of products requiring internal reinforcement for door hardware.
- D. Keying Requirements Meeting:
 - 1. Schedule meeting at project site prior to General Contractor occupancy.
 - 2. Attendance Required:
 - 3. Agenda:
 - 4. Incorporate "Keying Requirements Meeting" decisions into keying submittal upon review of door hardware keying system including, but not limited to, the following:
 - 5. Record minutes and distribute copies within two days after meeting to participants, with two copies to Architect, Metra, participants, and those affected by decisions made.
 - 6. Deliver established keying requirements to manufacturers.

1.05 SUBMITTALS

- A. See Section 01 33 00 - Submittals, for submittal procedures.
- B. Product Data: Manufacturer's catalog literature for each type of hardware, marked to clearly show products to be furnished for this project, and includes construction details, material descriptions, finishes, and dimensions and profiles of individual components.
- C. Shop Drawings - Door Hardware Schedule: Submit detailed listing that includes each item of hardware to be installed on each door. Use door numbering scheme as included in Contract Documents.
 - 1. Prepared by or under supervision of Architectural Hardware Consultant (AHC).
 - 2. Conform to DHI (H&S) using door numbers and hardware set numbers as indicated in construction documents.
 - 3. List groups and suffixes in proper sequence.
 - 4. Provide complete description for each door listed.
 - 5. Provide manufacturer's and product names, and catalog numbers; include functions, types, styles, sizes and finishes of each item.
- D. Samples for Verification:
 - 1. Submit minimum size of 2 by 4 inch for sheet samples, and minimum length of 4 inch for other products.
 - 2. Submit one (1) sample of latchset, lockset, and closer illustrating style, color, and finish.
 - 3. Return full-size samples to Contractor.
 - 4. Submit product description with samples.
- E. Manufacturer's Installation Instructions: Indicate special procedures and perimeter conditions requiring special attention.
- F. Maintenance Data: Include data on operating hardware, lubrication requirements, and inspection procedures related to preventative maintenance.
 - 1. Submit manufacturer's parts lists and templates.
 - 2. Bitting List: List of combinations as furnished.
- G. Keying Schedule:
 - 1. Submit three (3) copies of Keying Schedule in compliance with requirements established during Keying Requirements Meeting unless otherwise indicated.
- H. Warranty: Submit manufacturer's warranty and ensure that forms have been completed in Metra's name and registered with manufacturer.
- I. Project Record Documents: Record actual locations of concealed equipment, services, and conduit.

- J. Maintenance Materials and Tools: Furnish the following for Metra's use in maintenance of project.
1. See Section 01 60 00 - Product Requirements, for additional provisions.
 2. Lock Cylinders: One for each master keyed group.
 3. Tools: One set of each special wrench or tool applicable for each different or special hardware component, whether supplied by hardware component manufacturer or not.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section with minimum three years of documented experience.
- B. Installer Qualifications: Company specializing in performing work of the type specified for commercial door hardware with at least three years of documented experience.
- C. Supplier Qualifications: Company with certified Architectural Hardware Consultant (AHC) and Electrified Hardware Consultant (EHC) to assist in work of this section.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Package hardware items individually; label and identify each package with door opening code to match door hardware schedule.

1.08 WARRANTY

- A. Warranty against defects in material and workmanship for period indicated, from Date of Substantial Completion.
1. Closers: Five years, minimum.
 2. Locksets and Cylinders: Five Years, minimum.
 3. Other Hardware: Five years, minimum.

PART 2 PRODUCTS

2.01 DESIGN AND PERFORMANCE CRITERIA

- A. Provide specified door hardware as required to make doors fully functional, compliant with applicable codes, and secure to extent indicated.
- B. Provide individual items of single type, of same model, and by same manufacturer.
- C. Provide door hardware products that comply with the following requirements:
1. Applicable provisions of federal, state, and local codes.
 2. Accessibility: ADA Standards and ICC A117.1.
 3. Applicable provisions of NFPA 101.
 4. Listed and certified compliant with specified standards by BHMA (CPD).
 5. Auxiliary Hardware: BHMA A156.16.
 6. Straps and Tee Hinges: BHMA A156.20.
 7. Hardware Preparation for Wood Doors with Wood or Steel Frames: BHMA A156.115W.
 8. Products Requiring Electrical Connection: Listed and classified by UL (DIR) as suitable for the purpose specified.
- E. Lock Function: Provide lock and latch function numbers and descriptions of manufacturer's series. Refer to Door Hardware Schedule.
- F. Fasteners:
1. Provide fasteners of proper type, size, quantity, and finish that comply with commercially recognized standards for proposed applications.
 - a. Aluminum fasteners are not permitted.
 - b. Provide phillips flat-head screws with heads finished to match door surface hardware unless otherwise indicated.
 2. Provide machine screws for attachment to reinforced hollow metal and aluminum frames.
 - a. Self-drilling (Tek) type screws are not permitted.
 3. Provide stainless steel machine screws and lead expansion shields for concrete and masonry substrates.
 4. Provide wall grip inserts for hollow wall construction.

5. Fire-Rated Applications: Comply with NFPA 80.
 - a. Provide wood or machine screws for hinges mortised to doors or frames, strike plates to frames, and closers to doors and frames.
 - b. Provide steel through bolts for attachment of surface mounted closers, hinges, or exit devices to door panels unless proper door blocking is provided.
6. Concealed Fasteners: Do not use through or sex bolt type fasteners on door panel sides indicated as concealed fastener locations, unless otherwise indicated.

2.02 CYLINDRICAL LOCKS

- A. Manufacturers:
 1. Corbin Russwin, Sargent, or Yale; an Assa Abloy Group company: www.assaabloydss.com.
 2. Schlage, an Allegion brand: www.allegion.com/us. Basis of Design
 3. or equal to or superior to substitute by Architect and Owner
 4. Substitutions: See Section 01 60 00 – Product Requirements.
- B. Cylindrical Locks (Bored): Complying with BHMA A156.2, Grade 1, 4000 Series.
 1. Bored Hole: 2-1/8 inch diameter.
 2. Latchbolt Throw: 1/2 inch, minimum.
 3. Backset: 2-3/4 inch unless otherwise indicated.
 4. Strikes: Provide manufacturer's standard strike for each latchset or lockset with strike box and curved lip extending to protect frame in compliance with indicated requirements.
 - a. Finish: To match lock or latch.
 5. Provide a lock for each door, unless otherwise indicated that lock is not required.
 6. Trim: Provide lever handle or pull trim on outside of each lock, unless otherwise indicated.

2.03 LEVERSETS / LOCKSETS

- A. Manufacturers:
 1. Corbin Russwin, Sargent, or Yale; an Assa Abloy Group company: www.assaabloydss.com.
 2. Schlage, an Allegion brand: www.allegion.com/us. Basis of Design
 3. or equal to or superior to substitute by Architect and Owner.
 4. Substitutions: See Section 01 60 00 – Product Requirements.
- B. Leversets
 1. Function: Entrance lock L9453.
 2. Lever: 05
 3. Rose: A

2.04 CLOSERS

- A. Manufacturers; Surface Mounted:
 1. Corbin Russwin, Norton, Rixson, Sargent, or Yale; an Assa Abloy Group company: www.assaabloydss.com.
 2. LCN, an Allegion brand: www.allegion.com/us. Basis of Design
 3. or equal to or superior to substitute by Architect and Owner.
 4. Substitutions: See Section 01 60 00 – Product Requirements.
- B. Closers: Complying with BHMA A156.4, Grade 1.
 1. Type: Surface mounted to door with track.
 2. Provide door closer on each exterior door.
 3. At outswinging exterior doors, mount closer on interior side of door.

2.05 OVERHEAD STOPS AND HOLDERS

- A. Manufacturers:
 1. Corbin Russwin, Norton, Rixson, Sargent, or Yale; an Assa Abloy Group company: www.assaabloydss.com.
 2. LCN, an Allegion brand: www.allegion.com/us. Basis of Design
 3. or equal to or superior to substitute by Architect and Owner.

4. Substitutions: See Section 01 60 00 – Product Requirements.
- B. Overhead Stops and Holders (Door Checks): Complying with BHMA A156.8, Grade 1.
 1. Provide stop for every swinging door, unless otherwise indicated.
 2. Concealed overhead.

2.06 THRESHOLDS

- A. Manufacturers:
 1. Pemko; an Assa Abloy Group company: www.assaabloydss.com.
 2. Hager Companies: www.hagerco.com/#sle.
 3. National Guard Products, Inc: www.ngpinc.com.
 4. Zero International, Inc: www.zerointernational.com.
 5. or equal to or superior to substitute by Architect and Owner.
 6. Substitutions: See Section 01 60 00 – Product Requirements.
- B. Thresholds: Complying with BHMA A156.21.
 1. Provide threshold at each exterior door, unless otherwise indicated.
 2. Type: Flat surface.
 3. Material: Aluminum.
 4. Threshold Surface: Fluted horizontal grooves across full width.
 5. Field cut threshold to profile of frame and width of door sill for tight fit.
 6. Provide non-corroding fasteners at exterior locations.
 7. Thermally broken

2.07 WEATHERSTRIPPING AND GASKETING

- A. Manufacturers:
 1. Pemko; an Assa Abloy Group company: www.assaabloydss.com.
 2. Hager Companies: www.hagerco.com/#sle.
 3. National Guard Products, Inc: www.ngpinc.com.
 4. Zero International, Inc: www.zerointernational.com.
 5. or equal to or superior to substitute by Architect and Owner.
 6. Substitutions: See Section 01 60 00 – Product Requirements.
- B. Weatherstripping and Gasketing: Complying with BHMA A156.22.
 1. Head and Jamb Type: Adjustable.
 2. Door Sweep Type: Encased in retainer.
 3. Material: Aluminum, with brush weatherstripping.

2.08 SILENCERS

- A. Silencers: Provide at equal locations on door frame to mute sound of door's impact upon closing.
 1. Single Door: Provide three on strike jamb of frame.
 2. Pair of Doors: Provide two on head of frame, one for each door at latch side.
 3. Material: Rubber, gray color.

2.09 FINISHES

- A. Finishes: Provide door hardware of same finish, unless otherwise indicated.
 1. Primary Finish: 643E/US11; dark oxidized satin bronze, aged bronze, with steel base material (former US equivalent US10B); BHMA A156.18.
 2. Exceptions:
 - a. Where base material metal is specified to be different, provide finish that is an equivalent appearance in accordance with BHMA A156.18.
 - b. Door Closer Covers and Arms: Color as selected by Architect from manufacturer's standard colors unless otherwise indicated.
 - c. Aluminum Surface Trim and Gasket Housings: Anodized to match door panel finish, not other hardware, unless otherwise indicated.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that doors and frames are ready to receive this work; labeled, fire-rated doors and frames are properly installed, and dimensions are as indicated on shop drawings.

3.02 INSTALLATION

- A. Install hardware in accordance with manufacturer's instructions and applicable codes.
- B. Use templates provided by hardware item manufacturer.
- C. Do not install surface mounted items until application of finishes to substrate are fully completed.
- D. Door Hardware Mounting Heights: Distance from finished floor to center line of hardware item. As indicated in following list; unless noted otherwise in Door Hardware Schedule or on drawings.
 - 1. For Wood Doors: Install in compliance with DHI WDHS.3 recommendations.
 - 2. Mounting heights in compliance with ADA Standards:
 - a. Locksets: 40-5/16 inch.
 - b. Push Plates/Pull Bars: 42 inch.
 - c. Deadlocks (Deadbolts): 48 inch.
 - d. Exit Devices: 40-5/16 inch.
- E. Set exterior door thresholds with full-width bead of elastomeric sealant at each point of contact with floor providing a continuous weather seal; anchor thresholds with stainless steel countersunk screws.
 - 1. Refer to Section 07 92 00 for additional requirements.

3.03 FIELD QUALITY CONTROL

- A. Perform field inspection and testing under provisions of Section 01 40 00 - Quality Requirements.
- B. Provide an Architectural Hardware Consultant (AHC) to inspect installation and certify that hardware and installation has been furnished and installed in accordance with manufacturer's instructions and as specified.

3.04 ADJUSTING

- A. Adjust work under provisions of Section 01 70 00 - Execution and Closeout Requirements.
- B. Adjust hardware for smooth operation.
- C. Adjust gasketing for complete, continuous seal; replace if unable to make complete seal.

3.05 CLEANING

- A. Clean finished hardware in accordance with manufacturer's written instructions after final adjustments have been made.
- B. Clean adjacent surfaces soiled by hardware installation.
- C. Replace items that cannot be cleaned to manufacturer's level of finish quality at no additional cost.
- D. See Section 01 74 19 - Construction Waste Management and Disposal, for additional requirements.

3.06 PROTECTION

- A. Do not permit adjacent work to damage hardware or finish.

3.07 HARDWARE SETS

- A. Hardware sets described herein represent the design intent and are to be used for bidding.
- B. Hardware sets will be reviewed with the Hardware Consultant during the shop drawing submittal and any changes or modifications as recommended by the Hardware Consultant will be incorporated into the submittal.

C. Hardware Set 1

1. Hinges by door manufacturer.
2. 1 each leverset/lockset
3. 1 each mortise cylinder.
4. 1 each core.
5. 1 each overhead stop (in door closer).
6. 1 each door closers.
7. 1 each door sweeps.
8. 1 set weatherstripping all sides
9. 1 each threshold.
10. 1 each silencers

END OF SECTION

SECTION 09 91 13
EXTERIOR PAINTING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Surface preparation.
- B. Field application of paints.
- C. Scope: Finish exterior surfaces exposed to view, unless fully factory-finished and unless otherwise indicated, including the following:
- D. Do Not Paint or Finish the Following Items:
 - 1. Items factory-finished unless otherwise indicated; materials and products having factory-applied primers are not considered factory finished.
 - 2. Items indicated to receive other finishes.
 - 3. Items indicated to remain unfinished.
 - 4. Stainless steel, anodized aluminum, bronze, terne coated stainless steel, zinc, and lead.
 - 5. Brick, glass unit masonry, architectural concrete, cast stone, integrally colored plaster and stucco.
 - 6. Exterior insulation and finish system (EIFS).
 - 7. Glass.
 - 8. Concealed pipes, ducts, and conduits.

1.02 RELATED REQUIREMENTS

- A. Section 09 91 23 - Interior Painting.

1.03 REFERENCE STANDARDS

- A. ASTM D4442 - Standard Test Methods for Direct Moisture Content Measurement of Wood and Wood-Based Materials; 2016.
- B. MPI (APSM) - Master Painters Institute Architectural Painting Specification Manual; Current Edition.
- C. SSPC V1 (PM1) - Good Painting Practice: Painting Manual, Volume 1; 2016.
- D. SSPC V2 (PM2) - Systems and Specifications: Steel Structures Painting Manual, Volume 2; 2015.
- E. SSPC-SP 1 - Solvent Cleaning; 2015, with Editorial Revision (2016).
- F. SSPC-SP 2 - Hand Tool Cleaning; 1982, with Editorial Revision (2004).
- G. SSPC-SP 3 - Power Tool Cleaning; 1982, with Editorial Revision (2004).

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide complete list of products to be used, with the following information for each:
 - 1. Manufacturer's name, product name and/or catalog number, and general product category (e.g. "alkyd enamel").
 - 2. MPI product number (e.g. MPI #47).
 - 3. Cross-reference to specified paint system(s) product is to be used in; include description of each system.
 - 4. Manufacturer's installation instructions.
- C. Selection Samples: Submit two heavy paper "fan deck" illustrating complete range of colors available for each surface finishing product scheduled.
- D. Verification Samples: Submit three paper "draw down" samples, 8-1/2 by 11 inches (216 by 279 mm) in size, illustrating range of colors available for each finishing product specified.
 - 1. Where sheen is specified, submit samples in only that sheen.

2. Where sheen is not specified, submit each color in each sheen available.
 3. Where sheen is not specified, discuss sheen options with Architect before preparing samples, to eliminate sheens definitely not required.
 4. Allow 30 days for approval process, after receipt of complete samples by Architect.
 5. Paint color submittals will not be considered until color submittals for major materials not to be painted, such as masonry, have been approved.
- E. Maintenance Data: Submit data including finish schedule showing where each product/color/finish was used, product technical data sheets, material safety data sheets (MSDS), care and cleaning instructions, touch-up procedures, repair of painted and finished surfaces, and color samples of each color and finish used.
- F. Maintenance Materials: Furnish the following for Owner's use in maintenance of project.
1. See Section 01 60 00 - Product Requirements, for additional provisions.
 2. Extra Paint and Finish Materials: 1 gallon (4 L) of each color; from the same product run, store where directed.
 3. Label each container with color in addition to the manufacturer's label.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified, with minimum three years documented experience.
- B. Applicator Qualifications: Company specializing in performing the type of work specified with minimum three years experience.

1.06 MOCK-UP

- A. See Section 01 40 00 - Quality Requirements, for general requirements for mock-up.
- B. Provide mock-up aize as agreed upon with Owner and Architect, illustrating paint color, texture, and finish.
- C. Locate where directed by Architect.
- D. Mock-up may remain as part of the work.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Deliver products to site in sealed and labeled containers; inspect to verify acceptability.
- B. Container Label: Include manufacturer's name, type of paint, brand name, lot number, brand code, coverage, surface preparation, drying time, cleanup requirements, color designation, and instructions for mixing and reducing.
- C. Paint Materials: Store at minimum ambient temperature of 45 degrees F (7 degrees C) and a maximum of 90 degrees F (32 degrees C), in ventilated area, and as required by manufacturer's instructions.

1.08 FIELD CONDITIONS

- A. Do not apply materials when surface and ambient temperatures are outside the temperature ranges required by the paint product manufacturer.
- B. Follow manufacturer's recommended procedures for producing best results, including testing of substrates, moisture in substrates, and humidity and temperature limitations.
- C. Do not apply exterior paint and finishes during rain or snow, or when relative humidity is outside the humidity ranges required by the paint product manufacturer.
- D. Provide lighting level of 80 ft candles (860 lx) measured mid-height at substrate surface.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Provide paints and finishes used in any individual system from the same manufacturer; no exceptions.
- B. Paints:
1. Base Manufacturer: Sherwin-Williams Company: www.sherwin-williams.com/#sle..

2. Other Acceptable Manufacturers"
 3. Behr Process Corporation: www.behr.com/#sle.
 4. PPG Paints: www.ppgpaints.com/#sle.
- C. Primer Sealers: Same manufacturer as top coats.
- D. or equal to or superior to substitute approved by Architect and Owner
- E. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 PAINTS AND FINISHES - GENERAL

- A. Paints and Finishes: Ready mixed, unless required to be a field-catalyzed paint.
1. Provide paints and finishes of a soft paste consistency, capable of being readily and uniformly dispersed to a homogeneous coating, with good flow and brushing properties, and capable of drying or curing free of streaks or sags.
 2. Provide materials that are compatible with one another and the substrates indicated under conditions of service and application, as demonstrated by manufacturer based on testing and field experience.
 3. For opaque finishes, tint each coat including primer coat and intermediate coats, one-half shade lighter than succeeding coat, with final finish coat as base color.
 4. Supply each paint material in quantity required to complete entire project's work from a single production run.
 5. Do not reduce, thin, or dilute paint or finishes or add materials unless such procedure is specifically described in manufacturer's product instructions.
- B. Flammability: Comply with applicable code for surface burning characteristics.
- C. Sheens: Provide the sheens specified; where sheen is not specified, sheen will be selected later by Architect from the manufacturer's full line.
- D. Colors: As indicated in Color Schedule.

2.03 PAINT SYSTEMS - EXTERIOR

- A. Paint WE-OP-3A - Wood, Opaque, Alkyd, 3 Coat:
1. One coat of alkyd primer sealer.
 2. Semi-gloss: Two coats of alkyd enamel; _____.
- B. Paint WE-OP-2A - Wood, Opaque, Alkyd, 2 Coat:
1. One coat of alkyd primer sealer.
 2. Semi-gloss: One coat of alkyd enamel; _____.
- C. Paint WE-OP-3L - Wood, Opaque, Latex, 3 Coat:
1. One coat of latex primer sealer.
 2. Semi-gloss: Two coats of latex enamel; _____.
- D. Paint WE-OP-2L - Wood, Opaque, Latex, 2 Coat:
1. One coat of latex primer sealer.
 2. Semi-gloss: One coat of latex enamel; _____.

2.04 PRIMERS

- A. Primers: Provide the following unless other primer is required or recommended by manufacturer of top coats.

2.05 ACCESSORY MATERIALS

- A. Accessory Materials: Provide primers, sealers, cleaning agents, cleaning cloths, sanding materials, and clean-up materials as required for final completion of painted surfaces.
- B. Patching Material: Latex filler.
- C. Fastener Head Cover Material: Latex filler.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Do not begin application of paints and finishes until substrates have been properly prepared.

- B. Verify that surfaces are ready to receive work as instructed by the product manufacturer.
- C. Examine surfaces scheduled to be finished prior to commencement of work. Report any condition that may potentially effect proper application.
- D. Test shop-applied primer for compatibility with subsequent cover materials.
- E. Measure moisture content of surfaces using an electronic moisture meter. Do not apply finishes unless moisture content of surfaces are below the following maximums:
 1. Exterior Wood: 15 percent, measured in accordance with ASTM D4442.

3.02 PREPARATION

- A. Clean surfaces thoroughly and correct defects prior to application.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.
- C. Remove or repair existing paints or finishes that exhibit surface defects.
- D. Remove or mask surface appurtenances, including electrical plates, hardware, light fixture trim, escutcheons, and fittings, prior to preparing surfaces for finishing.
- E. Seal surfaces that might cause bleed through or staining of topcoat.
- F. Remove mildew from impervious surfaces by scrubbing with solution of tetra-sodium phosphate and bleach. Rinse with clean water and allow surface to dry.
- G. Exterior Wood Surfaces to Receive Opaque Finish: Remove dust, grit, and foreign matter. Seal knots, pitch streaks, and sappy sections. Fill nail holes with tinted exterior calking compound after prime coat has been applied. Back prime concealed surfaces before installation.

3.03 APPLICATION

- A. Exterior Wood to Receive Opaque Finish: If final painting must be delayed more than 2 weeks after installation of woodwork, apply primer within 2 weeks and final coating within 4 weeks.
- B. Apply products in accordance with manufacturer's written instructions and recommendations in "MPI Architectural Painting Specification Manual".
- C. Where adjacent sealant is to be painted, do not apply finish coats until sealant is applied.
- D. Do not apply finishes to surfaces that are not dry. Allow applied coats to dry before next coat is applied.
- E. Apply each coat to uniform appearance.
- F. Dark Colors and Deep Clear Colors: Regardless of number of coats specified, apply additional coats until complete hide is achieved.
- G. Vacuum clean surfaces of loose particles. Use tack cloth to remove dust and particles just prior to applying next coat.
- H. Reinstall electrical cover plates, hardware, light fixture trim, escutcheons, and fittings removed prior to finishing.

3.04 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for general requirements for field inspection.

3.05 CLEANING

- A. Collect waste material that could constitute a fire hazard, place in closed metal containers, and remove daily from site.

3.06 PROTECTION

- A. Protect finishes until completion of project.

END OF SECTION

SECTION 09 91 23
INTERIOR PAINTING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Surface preparation.
- B. Field application of paints.
- C. Materials for backpriming woodwork.
- D. Scope: Finish interior surfaces exposed to view, unless fully factory-finished and unless otherwise indicated.
- E. Do Not Paint or Finish the Following Items:
 - 1. Items factory-finished unless otherwise indicated; materials and products having factory-applied primers are not considered factory finished.
 - 2. Items indicated to receive other finishes.
 - 3. Items indicated to remain unfinished.
 - 4. Fire rating labels, equipment serial number and capacity labels, bar code labels, and operating parts of equipment.
 - 5. Stainless steel, anodized aluminum, bronze, terne coated stainless steel, and lead items.
 - 6. Marble, granite, slate, and other natural stones.
 - 7. Floors, unless specifically indicated.
 - 8. Ceramic and other tiles.
 - 9. Brick, architectural concrete, cast stone, integrally colored plaster and stucco.
 - 10. Glass.
 - 11. Acoustical materials, unless specifically indicated.
 - 12. Concealed pipes, ducts, and conduits.

1.02 RELATED REQUIREMENTS

- A. Section 09 91 13 - Exterior Painting.

1.03 REFERENCE STANDARDS

- A. 40 CFR 59, Subpart D - National Volatile Organic Compound Emission Standards for Architectural Coatings; U.S. Environmental Protection Agency; current edition.
- B. ASTM D16 - Standard Terminology for Paint, Related Coatings, Materials, and Applications; 2016.
- C. ASTM D4442 - Standard Test Methods for Direct Moisture Content Measurement of Wood and Wood-Based Materials; 2016.
- D. MPI (APSM) - Master Painters Institute Architectural Painting Specification Manual; Current Edition.
- E. SSPC V1 (PM1) - Good Painting Practice: Painting Manual, Volume 1; 2016.
- F. SSPC V2 (PM2) - Systems and Specifications: Steel Structures Painting Manual, Volume 2; 2015.
- G. SSPC-SP 1 - Solvent Cleaning; 2015, with Editorial Revision (2016).
- H. SSPC-SP 2 - Hand Tool Cleaning; 1982, with Editorial Revision (2004).
- I. SSPC-SP 3 - Power Tool Cleaning; 1982, with Editorial Revision (2004).

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide complete list of products to be used, with the following information for each:
 - 1. Manufacturer's name, product name and/or catalog number, and general product category (e.g. "alkyd enamel").

2. MPI product number (e.g. MPI #47).
 3. Cross-reference to specified paint system(s) product is to be used in; include description of each system.
 4. Manufacturer's installation instructions.
- C. Selection Samples: Submit one heavy paper "fan deck" illustrating complete range of colors available for each surface finishing product scheduled.
- D. Verification Samples: Submit two paper "draw down" samples, 8-1/2 by 11 inches (216 by 279 mm) in size, illustrating range of colors available for each finishing product specified.
1. Where sheen is specified, submit samples in only that sheen.
 2. Where sheen is not specified, submit each color in each sheen available.
 3. Where sheen is not specified, discuss sheen options with Architect before preparing samples, to eliminate sheens definitely not required.
 4. Allow 30 days for approval process, after receipt of complete samples by Architect.
 5. Paint color submittals will not be considered until color submittals for major materials not to be painted, such as masonry, have been approved.
- E. Manufacturer's Instructions: Indicate special surface preparation procedures and substrate conditions requiring special attention.
- F. Maintenance Data: Submit data including finish schedule showing where each product/color/finish was used, product technical data sheets, material safety data sheets (MSDS), care and cleaning instructions, touch-up procedures, repair of painted and finished surfaces, and color samples of each color and finish used.
- G. Maintenance Materials: Furnish the following for Owner's use in maintenance of project.
1. See Section 01 60 00 - Product Requirements, for additional provisions.
 2. Extra Paint and Finish Materials: 1 gallon (4 L) of each color; from the same product run, store where directed.
 3. Label each container with color in addition to the manufacturer's label.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified, with minimum three years documented experience.
- B. Applicator Qualifications: Company specializing in performing the type of work specified with minimum three years experience.

1.06 MOCK-UP

- A. See Section 01 40 00 - Quality Requirements, for general requirements for mock-up.
- B. Provide panel, 8 feet (8 m) long by 2.44 feet (2.44 m) wide, illustrating paint color, texture, and finish.
 1. Allow for up to (3) mock-up panels of different colors.
- C. Locate where directed by Architect.
- D. Mock-up may remain as part of the work.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Deliver products to site in sealed and labeled containers; inspect to verify acceptability.
- B. Container Label: Include manufacturer's name, type of paint, brand name, lot number, brand code, coverage, surface preparation, drying time, cleanup requirements, color designation, and instructions for mixing and reducing.
- C. Paint Materials: Store at minimum ambient temperature of 45 degrees F (7 degrees C) and a maximum of 90 degrees F (32 degrees C), in ventilated area, and as required by manufacturer's instructions.

1.08 FIELD CONDITIONS

- A. Do not apply materials when surface and ambient temperatures are outside the temperature ranges required by the paint product manufacturer.

- B. Follow manufacturer's recommended procedures for producing best results, including testing of substrates, moisture in substrates, and humidity and temperature limitations.
- C. Do not apply materials when relative humidity exceeds 85 percent; at temperatures less than 5 degrees F (3 degrees C) above the dew point; or to damp or wet surfaces.
- D. Minimum Application Temperatures for Paints: 50 degrees F (10 degrees C) for interiors unless required otherwise by manufacturer's instructions.
- E. Provide lighting level of 80 ft candles (860 lx) measured mid-height at substrate surface.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Provide paints and finishes used in any individual system from the same manufacturer; no exceptions.
- B. Paints:
 - 1. Basis of Design:
 - a. Sherwin-Williams Company: www.sherwin-williams.com/#sle.
 - 2. Other Acceptable Manufacturers:
 - a. Benjamin Moore & Company: www.benjaminmoore.com.
 - b. Behr Process Corporation: www.behr.com/#sle.
 - c. PPG Paints: www.ppgpaints.com/#sle.
 - d. Substitutions: Not permitted.
- C. Primer Sealers: Same manufacturer as top coats.
- D. or equal to or superior to substitute approved by Architect and Owner
- E. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 PAINTS AND FINISHES - GENERAL

- A. Paints and Finishes: Ready mixed, unless intended to be a field-catalyzed paint.
 - 1. Provide paints and finishes of a soft paste consistency, capable of being readily and uniformly dispersed to a homogeneous coating, with good flow and brushing properties, and capable of drying or curing free of streaks or sags.
 - 2. Provide materials that are compatible with one another and the substrates indicated under conditions of service and application, as demonstrated by manufacturer based on testing and field experience.
 - 3. For opaque finishes, tint each coat including primer coat and intermediate coats, one-half shade lighter than succeeding coat, with final finish coat as base color.
 - 4. Supply each paint material in quantity required to complete entire project's work from a single production run.
 - 5. Do not reduce, thin, or dilute paint or finishes or add materials unless such procedure is specifically described in manufacturer's product instructions.
- B. Flammability: Comply with applicable code for surface burning characteristics.
- C. Sheens: Provide the sheens specified; where sheen is not specified, sheen will be selected later by Architect from the manufacturer's full line.
- D. Colors: To be selected from manufacturer's full range of available colors.
 - 1. Selection to be made by Architect after award of contract.
 - 2. Allow for minimum of four colors for each system, unless otherwise indicated, without additional cost to Owner.
 - 3. Extend colors to surface edges; colors may change at any edge as directed by Architect.

2.03 PAINT SYSTEMS - INTERIOR

- A. Paint I-OP - Interior Surfaces to be Painted, Unless Otherwise Indicated: Including gypsum board, concrete, and concrete masonry units.
 - 1. 100% Acrylic, water reducible, corrosion resistant coating.
 - 2. At new and existing unfinished construction:

- a. Two top coats and one coat primer.
- 3. At existing, finish painted construction:
 - a. Two top coats.
- 4. Top Coat(s): High Performance Architectural Interior Latex; MPI #138, 139, 140, or 141.
- 5. Top Coat(s): Institutional Low Odor/VOC Interior Latex; MPI #143, 144, 145, 146, 147, or 148.
- 6. Top Coat Sheen:
 - a. To match existing adjacent surfaces.
- 7. Primer: As recommended by top coat manufacturer for specific substrate.
- B. Paint WI-OP-3A - Wood, Opaque, Alkyd, 3 Coat:
 - 1. One coat alkyd primer sealer.
 - 2. Semi-gloss: Two coats of alkyd enamel; _____.
- C. Paint WI-OP-2A - Wood, Opaque, Alkyd, 2 Coat:
 - 1. One coat of alkyd primer sealer.
 - 2. Semi-gloss: One coat of alkyd enamel; _____.
- D. Paint WI-OP-3L - Wood, Opaque, Latex, 3 Coat:
 - 1. One coat of latex primer sealer.
 - 2. Semi-gloss: Two coats of latex enamel; _____.
- E. Paint WI-OP-2L - Wood, Opaque, Latex, 2 Coat:
 - 1. One coat of latex primer sealer.
 - 2. Semi-gloss: One coat of latex enamel; _____.

2.04 PRIMERS

- A. Primers: Provide the following unless other primer is required or recommended by manufacturer of top coats.
 - 1. High Adhesion, Water Based, Acrylic Primer for hard to paint surfaces.
 - a. Application: Painting structural glazed facing tile.
 - b. Sherwin Williams; Product Extreme Bond Primer.
 - 1) Substitutions: Section 01 60 00 - Product Requirements.

2.05 ACCESSORY MATERIALS

- A. Accessory Materials: Provide primers, sealers, cleaning agents, cleaning cloths, sanding materials, and clean-up materials as required for final completion of painted surfaces.
- B. Patching Material: Latex filler.
- C. Fastener Head Cover Material: Latex filler.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Do not begin application of paints and finishes until substrates have been properly prepared.
- B. Verify that surfaces are ready to receive work as instructed by the product manufacturer.
- C. Examine surfaces scheduled to be finished prior to commencement of work. Report any condition that may potentially effect proper application.
- D. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.
- E. Test shop-applied primer for compatibility with subsequent cover materials.
- F. Measure moisture content of surfaces using an electronic moisture meter. Do not apply finishes unless moisture content of surfaces are below the following maximums:
 - 1. Interior Wood: 15 percent, measured in accordance with ASTM D4442.

3.02 PREPARATION

- A. Clean surfaces thoroughly and correct defects prior to application.

- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.
- C. Remove or repair existing paints or finishes that exhibit surface defects.
- D. Remove or mask surface appurtenances, including electrical plates, hardware, light fixture trim, escutcheons, and fittings, prior to preparing surfaces or finishing.
- E. Seal surfaces that might cause bleed through or staining of topcoat.
- F. Remove mildew from impervious surfaces by scrubbing with solution of tetra-sodium phosphate and bleach. Rinse with clean water and allow surface to dry.
- G. Insulated Coverings: Remove dirt, grease, and oil from canvas and cotton.
- H. Wood Surfaces to Receive Opaque Finish: Wipe off dust and grit prior to priming. Seal knots, pitch streaks, and sappy sections with sealer. Fill nail holes and cracks after primer has dried; sand between coats. Back prime concealed surfaces before installation.

3.03 APPLICATION

- A. Remove unfinished louvers, grilles, covers, and access panels on mechanical and electrical components and paint separately.
- B. Apply products in accordance with manufacturer's written instructions and recommendations in "MPI Architectural Painting Specification Manual".
- C. Where adjacent sealant is to be painted, do not apply finish coats until sealant is applied.
- D. Do not apply finishes to surfaces that are not dry. Allow applied coats to dry before next coat is applied.
- E. Apply each coat to uniform appearance in thicknesses specified by manufacturer.
- F. Dark Colors and Deep Clear Colors: Regardless of number of coats specified, apply as many coats as necessary for complete hide.
- G. Sand wood and metal surfaces lightly between coats to achieve required finish.
- H. Vacuum clean surfaces of loose particles. Use tack cloth to remove dust and particles just prior to applying next coat.
- I. Reinstall electrical cover plates, hardware, light fixture trim, escutcheons, and fittings removed prior to finishing.

3.04 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for general requirements for field inspection.

3.05 CLEANING

- A. Collect waste material that could constitute a fire hazard, place in closed metal containers, and remove daily from site.

3.06 PROTECTION

- A. Protect finishes until completion of project.
- B. Touch-up damaged finishes until Substantial Completion.

END OF SECTION